

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
B	Annex Hallw	5	<4" fiberglass w/tar PI	T	ND		58	LF	N	N	0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	6	<4" fibrous PFI on FG w/tar	T		Pos	12	EA	F	N	2	2/18/94	Allen/Archer	40%						001-94-008
B	Annex Hallw	7	<4" fibrous PFI on fiberglass	T	ND		14	EA	F	N	0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	19	12"x12" mustard w/white & brown FT	M	ND		730	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	19.5	Floor tile adhesive (sample 19)	M		Pos	730	SF	N	N	1	2/18/94	Allen/Archer	5%						001-94-008
B	Annex Hallw	32	2'x4' pinhole crater CT	M	ND		770	SF	F	L	0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	R1	<4" white fibrous PI (4/26/90)	T		Pos	3	LF	F	N	2	2/18/94	Allen/Archer	30%						001-94-008
B	Annex Hallw	R3	<4" felt w/tar PI (7/17/90)	T		Pos	26	LF	F	N	2	2/18/94	Allen/Archer	10%						001-94-008
B	Annex Hallw	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	10	EA	F	N	2	2/18/94	Allen/Archer	40%						001-94-008
B	Annex Hallw	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	8	LF	F	N	2	2/18/94	Allen/Archer	34%						001-94-008
B	Annex Hallw	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Annex Hallw	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Hallway	30	2'x2' pinhole fissured CT	M	ND		432	SF	F	N	0	2/18/94	Allen/Archer							001-94-008
B	Hallway	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Hallway	R1	<4" white fibrous PI (4/26/90)	T		Pos	38	LF	F	N	2	2/18/94	Allen/Archer	30%						001-94-008
B	Hallway	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	10	EA	F	N	2	2/18/94	Allen/Archer	30%						001-94-008
B	Hallway	R3	<4" felt w/tar PI (7/17/90)	T		Pos	64	LF	F	L	3	2/18/94	Allen/Archer	10%						001-94-008
B	Hallway	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	10	EA	F	L	3	2/18/94	Allen/Archer	40%						001-94-008
B	Hallway	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	12	LF	F	H	4	2/18/94	Allen/Archer	34%						001-94-008
B	Hallway	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Hallway	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
B	Room 05	7	<4" fibrous PFI on fiberglass	T	ND		6	EA	F	N	2	2/18/94	Allen/Archer							001-94-008
B	Room 05	12	9"x9" grey w/dark grey & cream FT	M	ND		216	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
B	Room 05	12.5	Floor tile adhesive (sample 12)	M	ND		216	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
B	Room 05	25	12"x12" pegboard CT	M	ND		216	SF	F	N	0	2/18/94	Allen/Archer							001-94-008
B	Room 05	25.5	Ceiling tile adhesive (sample 25)	M	ND		216	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
B	Room 05	R1	<4" white fibrous PI (4/26/90)	T		Pos	34	LF	F	N	2	2/18/94	Allen/Archer	30%						001-94-008

B	Room 05	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	10	EA	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
B	Room 05	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	22	LF	F	N	2	2/18/94	Allen/Archer		34%				001-94-008
B	Room 05	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	4	EA	F	N	2	2/18/94	Allen/Archer		10%				001-94-008
B	Room 05	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 05	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 07	12	9"x9" grey w/dark grey & cream FT	M	ND		160	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 07	12.5	Floor tile adhesive (sample 12)	M	ND		160	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 07	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	10	LF	F	N	2	2/18/94	Allen/Archer		34%				001-94-008
B	Room 07	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	1	EA	F	N	2	2/18/94	Allen/Archer		10%				001-94-008
B	Room 07	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 07	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09	12	9"x9" grey w/dark grey & cream FT	M	ND		150	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09	12.5	Floor tile adhesive (sample 12)	M	ND		150	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09	25	12"x12" pegboard CT	M	ND		150	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 09	25.5	Ceiling tile adhesive (sample 25)	M	ND		150	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	27	16"x16" pegboard CT	M	ND		792	SF	F	L	0	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	28	2'x2' pinhole large crater CT	M		Pos	704	SF	F	L	3	2/18/94	Allen/Arche	5%	2%				001-94-008
B	Room 09 A	30	2'x2' pinhole fissured CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	2	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
B	Room 09 A	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	1	EA	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
B	Room 09 A	R3	<4" felt w/tar PI (7/17/90)	T		Pos	34	LF	F	N	2	2/18/94	Allen/Archer		10%				001-94-008
B	Room 09 A	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	9	EA	F	N	2	2/18/94	Allen/Archer		40%				001-94-008
B	Room 09 A	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	12	LF	F	L	3	2/18/94	Allen/Archer		34%				001-94-008
B	Room 09 A	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	4	EA	F	L	3	2/18/94	Allen/Archer		10%				001-94-008
B	Room 09 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	22	Grey flooring	M		Pos	264	SF	N	N	1	2/18/94	Allen/Archer		5%				001-94-008
B	Room 09 B	22.5	Flooring adhesive (sample 22)	M		Pos	264	SF	N	N	1	2/18/94	Allen/Archer		20%				001-94-008

B	Room 09 B	25	12"x12" pegboard CT	M	ND		264	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		264	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	26	12"x12" random hole wall tile	M	ND		130	SF	F	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	26.5	Wall tile adhesive (sample 26)	M	ND		130	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	R1	<4" white fibrous PI (4/26/90)	T		Pos	56	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 09 B	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	13	EA	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 09 B	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	30	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 09 B	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	4	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 09 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	12	9"x9" grey w/dark grey & cream FT	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	12.5	Floor tile adhesive (sample 12)	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	25	12"x12" pegboard CT	M	ND		90	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	25.5	Ceiling tile adhesive (sample 25)	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	11	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 09 C	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	2	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 09 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 Ha	12	9"x9" grey w/dark grey & cream FT	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 Ha	12.5	Floor tile adhesive (sample 12)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 09 Ha	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 09 Ha	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 11	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 11	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 15	30	2'x2' pinhole fissured CT	M	ND		160	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 15	R1	<4" white fibrous PI (4/26/90)	T		Pos	40	LF	F	L	3	2/18/94	Allen/Archer	30%					001-94-008
B	Room 15	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	16	EA	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 15	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	3	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 15	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 15	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 16	16	12"x12" orange w/tan FT	M	ND		90	SF	N	N	0	2/18/94	Allen/Archer						001-94-008

B	Room 16	16.5	Floor tile adhesive (sample 16)	M	ND		90	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 16	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 16	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	22	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 16	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	2	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 16	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 16	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17 A	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17 A	39	Canvass vibration joint	M	ND		2	EA	N	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 17 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	95	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 17 A	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	53	EA	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 17 A	R3	<4" felt w/tar PI (7/17/90)	T		Pos	56	LF	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 17 A	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	23	EA	F	N	2	2/18/94	Allen/Archer	40%					001-94-008
B	Room 17 A	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	34	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 17 A	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	9	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 17 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 17 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 20	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 20	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 20	44	2'x2' pinhole crater CT	M	ND		308	SF	F	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 20	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	46	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 20	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	7	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 20	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 22	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 22	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 22	44	2'x2' pinhole crater CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 22 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 22 A	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 22 A	44	2'x2' pinhole crater CT	M	ND		396	SF	F	N	2	2/18/94	Allen/Archer						001-94-008

B	Room 22 A	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	20	LF	F	N	2	2/18/94	Allen/Archer	34%				001-94-008
B	Room 22 A	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	1	EA	F	N	2	2/18/94	Allen/Archer	10%				001-94-008
B	Room 22 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 22 B	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer					001-94-008
B	Room 22 B	44	2'x2' pinhole crater CT	M	ND		288	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
B	Room 22 B	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	24	LF	F	N	2	2/18/94	Allen/Archer	34%				001-94-008
B	Room 22 B	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	4	EA	F	N	2	2/18/94	Allen/Archer	10%				001-94-008
B	Room 22 C	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 22 C	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer					001-94-008
B	Room 22 C	44	2'x2' pinhole crater CT	M	ND		120	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
B	Room 22 C	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	10	LF	F	N	2	2/18/94	Allen/Archer	34%				001-94-008
B	Room 22 C	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	2	EA	F	N	2	2/18/94	Allen/Archer	10%				001-94-008
B	Room 24	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 51	32	2'x4' pinhole crater CT	M	ND		8	SF	F	L	2	2/18/94	Allen/Archer					001-94-008
B	Room 51	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 52	5	<4" fiberglass w/tar PI	T	ND		60	LF	N	N	1	2/18/94	Allen/Archer					001-94-008
B	Room 52	6	<4" fibrous PFI on FG w/tar	T		Pos	11	EA	F	L	3	2/18/94	Allen/Archer	40%				001-94-008
B	Room 52	17	12"x12" grey w/black & white FT	M		Pos	120	SF	N	N	1	2/18/94	Allen/Archer	3%				001-94-008
B	Room 52	17.5	Floor tile adhesive (sample 17)	M		Pos	120	SF	N	N	1	2/18/94	Allen/Archer	20%				001-94-008
B	Room 52	32	2'x4' pinhole crater CT	M	ND		120	SF	F	L	3	2/18/94	Allen/Archer					001-94-008
B	Room 52	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer					001-94-008
B	Room 52	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 53	5	<4" fiberglass w/tar PI	T	ND		6	LF	N	N	1	2/18/94	Allen/Archer					001-94-008
B	Room 53	6	<4" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	2/18/94	Allen/Archer	40%				001-94-008
B	Room 53	32	2'x4' pinhole crater CT	M	ND		10	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
B	Room 53	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
B	Room 54	5	<4" fiberglass w/tar PI	T	ND		27	LF	N	N	1	2/18/94	Allen/Archer					001-94-008
B	Room 54	6	<4" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	2/18/94	Allen/Archer	40%				001-94-008
B	Room 54	13	9"x9" light grey w/tan FT	M		Pos	938	SF	N	N	1	2/18/94	Allen/Archer	5%				001-94-008

B	Room 54	13.5	Floor tile adhesive (sample 13)	M		Pos	938	SF	N	N	1	2/18/94	Allen/Archer	15%					001-94-008
B	Room 54	32	2'x4' pinhole crater CT	M	ND		938	SF	F	L	3	2/18/94	Allen/Archer						001-94-008
B	Room 54	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 54	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 54	38	Black mastic on foam	M	ND		6	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 54	R1	<4" white fibrous PI (4/26/90)	T		Pos	172	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 54	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	61	EA	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 54	R8	4"-8" white fibrous PI (3/9/92)	T		Pos	210	LF	F	N	2	2/18/94	Allen/Archer	34%					001-94-008
B	Room 54	R9	4"-8" PFI on white fibrous (3/9/92)	T		Pos	43	EA	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
B	Room 54 (H)	7	<4" fibrous PFI on fiberglass	T	ND		20	EA	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 54 (H)	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 54 (H)	R1	<4" white fibrous PI (4/26/90)	T		Pos	20	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 54 (H)	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	12	EA	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
B	Room 60	13	9"x9" light grey w/tan FT	M		Pos	280	SF	N	L	1	2/18/94	Allen/Archer	5%					001-94-008
B	Room 60	13.5	Floor tile adhesive (sample 13)	M		Pos	280	SF	N	N	1	2/18/94	Allen/Archer	15%					001-94-008
B	Room 60	18	12"x12" beige w/olive FT	M		Pos	280	SF	N	L	1	2/18/94	Allen/Archer	5%					001-94-008
B	Room 60	18.5	Floor tile adhesive (sample 18)	M		Pos	280	SF	N	N	1	2/18/94	Allen/Archer	20%					001-94-008
B	Room 60	32	2'x4' pinhole crater CT	M	ND		560	SF	F	L	3	2/18/94	Allen/Archer						001-94-008
B	Room 60	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 60	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 62	7	<4" fibrous PFI on fiberglass	T	ND		7	EA	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 62	31	2'x2' nailhole fissured CT	M	ND		864	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
B	Room 62	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 62	41	Black lab top	M		Pos	24	SF	N	N	1	2/18/94	Allen/Archer	35%					001-94-008
B	Room 64	31	2'x2' nailhole fissured CT	M	ND		952	SF	F	N	0	2/18/94	Allen/Archer						001-94-008
B	Room 64	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
B	Room 66	14	9"x9" transite grey FT (assumed)	M		Pos	224	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 66	14.5	Floor tile adhesive (sample 14)	M		Pos	224	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
B	Room 66	32	2'x4' pinhole crater CT	M	ND		224	SF	F	L	3	2/18/94	Allen/Archer						001-94-008
B	Room 66	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
B	Room 66	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008

1	Hallway	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Hallway	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 101 A	12	9"x9" grey w/dark grey & cream FT	M	ND		225	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
1	Room 101 A	12.5	Floor tile adhesive (sample 12)	M	ND		225	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
1	Room 101 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 101 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 101/1	12	9"x9" grey w/dark grey & cream FT	M	ND		388	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
1	Room 101/1	12.5	Floor tile adhesive (sample 12)	M	ND		388	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
1	Room 101/1	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 101/1	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 101/1	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102	24	Green flooring	M	ND		625	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102	24.5	Flooring adhesive (sample 24)	M	ND		625	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102	25	12"x12" pegboard CT	M	ND		625	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
1	Room 102	25.5	Ceiling tile adhesive (sample 25)	M	ND		625	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
1	Room 102	R1	<4" white fibrous PI (4/26/90)	T		Pos	24	LF	F	N	2	2/18/94	Allen/Arche	30%						001-94-008
1	Room 102	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102 A	24	Green flooring	M	ND		55	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 A	24.5	Flooring adhesive (sample 24)	M	ND		55	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102 B	24	Green flooring	M	ND		50	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 B	24.5	Flooring adhesive (sample 24)	M	ND		50	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
1	Room 102 C	24	Green flooring	M	ND		50	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 C	24.5	Flooring adhesive (sample 24)	M	ND		50	SF	N	N	0	2/18/94	Allen/Archer							001-94-008
1	Room 102 C	R10	Ceiling plaster (4/26/90)	S	ND		r11	SF			0	2/18/94	Allen/Archer							001-94-008

1	Room 103	12	9"x9" grey w/dark grey & cream FT	M	ND		120	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 103	12.5	Floor tile adhesive (sample 12)	M	ND		120	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 103	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 103	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104	21	Brown flooring	M	ND		252	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
1	Room 104	21.5	Flooring adhesive (sample 21)	M	ND		252	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
1	Room 104	25	12"x12" pegboard CT	M	ND		252	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 104	25.5	Ceiling tile adhesive (sample 25)	M	ND		252	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104	R3	<4" felt w/tar PI (7/17/90)	T		Pos	24	LF	F	L	3	2/18/94	Allen/Archer	10%					001-94-008
1	Room 104	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	1	EA	F	N	2	2/18/94	Allen/Archer	40%					001-94-008
1	Room 104	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	21	Brown flooring	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	21.5	Flooring adhesive (sample 21)	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	25	12"x12" pegboard CT	M	ND		90	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		90	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	14	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
1	Room 104 A	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	4	EA	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
1	Room 104 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	21	Brown flooring	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	21.5	Flooring adhesive (sample 21)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	25	12"x12" pegboard CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 104 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 105	12	9"x9" grey w/dark grey & cream FT	M	ND		180	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 105	12.5	Floor tile adhesive (sample 12)	M	ND		180	SF	N	N	1	2/18/94	Allen/Archer						001-94-008

1	Room 105	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 105	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106	12	9"x9" grey w/dark grey & cream FT	M	ND		64	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106	12.5	Floor tile adhesive (sample 12)	M	ND		64	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106	25	12"x12" pegboard CT	M	ND		64	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 106	25.5	Ceiling tile adhesive (sample 25)	M	ND		64	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106	R11	Wall plaster (4/26/90)	S	ND		34	SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	12	9"x9" grey w/dark grey & cream FT	M	ND		96	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	12.5	Floor tile adhesive (sample 12)	M	ND		96	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	25	12"x12" pegboard CT	M	ND		96	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		96	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	12	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
1	Room 106 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	12	9"x9" grey w/dark grey & cream FT	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	12.5	Floor tile adhesive (sample 12)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	25	12"x12" pegboard CT	M	ND		240	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		240	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	12	9"x9" grey w/dark grey & cream FT	M	ND		56	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	12.5	Floor tile adhesive (sample 12)	M	ND		56	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	25	12"x12" pegboard CT	M	ND		56	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	25.5	Ceiling tile adhesive (sample 25)	M	ND		56	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008

1	Room 106 D	12	9"x9" grey w/dark grey & cream FT	M	ND		15	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 D	12.5	Floor tile adhesive (sample 12)	M	ND		15	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 106 D	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 106 D	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 107	12	9"x9" grey w/dark grey & cream FT	M	ND		72	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 107	12.5	Floor tile adhesive (sample 12)	M	ND		72	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 107	R1	<4" white fibrous PI (4/26/90)	T		Pos	36	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
1	Room 107	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 107	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 107 A	12	9"x9" grey w/dark grey & cream FT	M	ND		72	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 107 A	12.5	Floor tile adhesive (sample 12)	M	ND		72	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 107 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 107 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 108	21	Brown flooring	M	ND		144	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108	21.5	Flooring adhesive (sample 21)	M	ND		144	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108	25	12"x12" pegboard CT	M	ND		304	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 108	25.5	Ceiling tile adhesive (sample 25)	M	ND		304	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108	R1	<4" white fibrous PI (4/26/90)	T		Pos	25	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
1	Room 108	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	3	EA	F	L	3	2/18/94	Allen/Arche	30%					001-94-008
1	Room 108	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 108	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	21	Brown flooring	M	ND		66	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	21.5	Flooring adhesive (sample 21)	M	ND		66	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	25	12"x12" pegboard CT	M	ND		66	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		66	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 108 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 109 B	24	Green flooring	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 109 B	24.5	Flooring adhesive (sample 24)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 109 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 109 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008



1	Room 113	12	9"x9" grey w/dark grey & cream FT	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113	12.5	Floor tile adhesive (sample 12)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113	25	12"x12" pegboard CT	M	ND		100	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 113	25.5	Ceiling tile adhesive (sample 25)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	12	9"x9" grey w/dark grey & cream FT	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	12.5	Floor tile adhesive (sample 12)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	25	12"x12" pegboard CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	25	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
1	Room 113 A	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	3	EA	F	L	3	2/18/94	Allen/Arche	30%					001-94-008
1	Room 113 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	12	9"x9" grey w/dark grey & cream FT	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	12.5	Floor tile adhesive (sample 12)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	25	12"x12" pegboard CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	12	9"x9" grey w/dark grey & cream FT	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	12.5	Floor tile adhesive (sample 12)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	25	12"x12" pegboard CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	25.5	Ceiling tile adhesive (sample 25)	M	ND		80	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
1	Room 113 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Hallway	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Hallway	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200	15	9"x9" black FT	M	ND		285	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
2	Room 200	15.5	Floor tile adhesive (sample 15)	M	ND		285	SF	N	N	0	2/18/94	Allen/Archer						001-94-008
2	Room 200	25	12"x12" pegboard CT	M	ND		285	SF	F	N	2	2/18/94	Allen/Archer						001-94-008

2	Room 200	25.5	Ceiling tile adhesive (sample 25)	M	ND		285	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	15	9"x9" black FT	M	ND		180	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	15.5	Floor tile adhesive (sample 15)	M	ND		180	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	25	12"x12" pegboard CT	M	ND		180	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		180	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	R1	<4" white fibrous PI (4/26/90)	T		Pos	24	LF	F	L	3	2/18/94	Allen/Arche	30%					001-94-008
2	Room 200 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	15	9"x9" black FT	M	ND		162	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	15.5	Floor tile adhesive (sample 15)	M	ND		162	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	25	12"x12" pegboard CT	M	ND		162	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		162	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	R1	<4" white fibrous PI (4/26/90)	T		Pos	24	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
2	Room 200 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	15	9"x9" black FT	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	15.5	Floor tile adhesive (sample 15)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	25	12"x12" pegboard CT	M	ND		100	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	25.5	Ceiling tile adhesive (sample 25)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 200 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 201	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 201	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 201	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 201 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008

2	Room 201 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 C	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 D	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 D	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 D	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 E	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 E	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 201 E	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 202	25	12"x12" pegboard CT	M	ND		744	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
2	Room 202	25.5	Ceiling tile adhesive (sample 25)	M	ND		744	SF	N	N	1	2/18/94	Allen/Archer					001-94-008
2	Room 202	R3	<4" felt w/tar PI (7/17/90)	T		Pos	8	LF	F	N	2	2/18/94	Allen/Archer	10%				001-94-008
2	Room 202	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 202	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204	25	12"x12" pegboard CT	M	ND		50	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
2	Room 204	25.5	Ceiling tile adhesive (sample 25)	M	ND		50	SF	N	N	1	2/18/94	Allen/Archer					001-94-008
2	Room 204	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204 A	25	12"x12" pegboard CT	M	ND		110	SF	F	N	2	2/18/94	Allen/Archer					001-94-008
2	Room 204 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		110	SF	N	N	1	2/18/94	Allen/Archer					001-94-008
2	Room 204 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
2	Room 204 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008



2	Room 209 D	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 E	29	2'x2' pinhole crater drop CT	M	ND		168	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 209 E	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 E	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 E	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 F	29	2'x2' pinhole crater drop CT	M	ND		96	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 209 F	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 F	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 F	R1	<4" white fibrous PI (4/26/90)	T		Pos	24	LF	F	N	2	2/18/94	Allen/Archer	30%					001-94-008
2	Room 209 F	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	7	EA	F	L	3	2/18/94	Allen/Archer	30%					001-94-008
2	Room 209 F	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 F	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 G	29	2'x2' pinhole crater drop CT	M	ND		80	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 209 G	33	Wall tile adhesive	M	ND		10	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 209 G	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 G	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 H	29	2'x2' pinhole crater drop CT	M	ND		120	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 209 H	33	Wall tile adhesive	M	ND		12	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 209 H	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 209 H	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
2	Room 210	R3	<4" felt w/tar PI (7/17/90)	T		Pos	36	LF	F	N	2	2/18/94	Allen/Archer	10%					001-94-008
2	Room 210	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	15	EA	F	N	2	2/18/94	Allen/Archer	40%					001-94-008
2	Room 210	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 210	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211	25	12"x12" pegboard CT	M	ND		200	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 211	25.5	Ceiling tile adhesive (sample 25)	M	ND		200	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 211	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008

2	Room 211 A	25	12"x12" pegboard CT	M	ND		100	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 211 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 211 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211 B	25	12"x12" pegboard CT	M	ND		100	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
2	Room 211 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		100	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
2	Room 211 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
2	Room 211 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Hallway	25	12"x12" pegboard CT	M	ND		0.5	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
3	Hallway	25.5	Ceiling tile adhesive (sample 25)	M	ND		0.5	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
3	Hallway	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Hallway	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 300	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 300	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301	25	12"x12" pegboard CT	M	ND		1286	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
3	Room 301	25.5	Ceiling tile adhesive (sample 25)	M	ND		1286	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
3	Room 301	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301	R1	<4" white fibrous PI (4/26/90)	T		Pos	20	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
3	Room 301	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 A	25	12"x12" pegboard CT	M	ND		176	SF	F	N	2	2/18/94	Allen/Archer						001-94-008
3	Room 301 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		176	SF	N	N	1	2/18/94	Allen/Archer						001-94-008
3	Room 301 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
3	Room 301 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008

3	Room 302	25	12"x12" pegboard CT	M	ND		470	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302	25.5	Ceiling tile adhesive (sample 25)	M	ND		470	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302	R3	<4" felt w/tar PI (7/17/90)	T		Pos	5	LF	F	N	2	2/18/94	Allen/Archer	10%						001-94-008
3	Room 302	R4	<4" fibrous PFI on felt (7/17/90)	T		Pos	3	EA	F	N	2	2/18/94	Allen/Archer	40%						001-94-008
3	Room 302	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 A	25	12"x12" pegboard CT	M	ND		88	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302 A	25.5	Ceiling tile adhesive (sample 25)	M	ND		88	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302 A	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 B	25	12"x12" pegboard CT	M	ND		88	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302 B	25.5	Ceiling tile adhesive (sample 25)	M	ND		88	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302 B	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 B	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 B	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 C	25	12"x12" pegboard CT	M	ND		60	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302 C	25.5	Ceiling tile adhesive (sample 25)	M	ND		60	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302 C	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 C	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 C	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 D	25	12"x12" pegboard CT	M	ND		65	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302 D	25.5	Ceiling tile adhesive (sample 25)	M	ND		65	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302 D	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 D	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 D	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer							001-94-008
3	Room 302 E	25	12"x12" pegboard CT	M	ND		108	SF	F	N	2	2/18/94	Allen/Archer							001-94-008
3	Room 302 E	25.5	Ceiling tile adhesive (sample 25)	M	ND		108	SF	N	N	1	2/18/94	Allen/Archer							001-94-008
3	Room 302 E	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer							001-94-008

3	Room 302 E	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 302 E	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 303	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 303	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 304	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 304	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 304 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 304 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 305	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 305	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 307	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 307	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 307 (H	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 307 A	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 307 A	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
3	Room 308	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Hallway	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Hallway	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Hallway (Hat	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Hallway (Hat	36	Concrete block mortar	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Hallway (Hat	39	Canvass vibration joint	M	ND		2	EA	N	N	1	2/18/94	Allen/Archer					001-94-008
4	Hallway (Hat	R40	Transite panels (assumed)	M		Pos	140	SF	N	N	1	2/18/94	Allen/Archer					001-94-008
4	Hallway (Hat	R42	Blown-in cellulose (5/23/90)	M	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Room 400	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008
4	Room 400	R11	Wall plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer					001-94-008

4	Room 400 (H)	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
4	Room 400 (H)	R10	Ceiling plaster (4/26/90)	S	ND			SF			0	2/18/94	Allen/Archer						001-94-008
4	Room 401	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
4	Room 401	35	Baseboard adhesive	M	ND			LF			0	2/18/94	Allen/Archer						001-94-008
4	Room 401	R1	<4" white fibrous PI (4/26/90)	T		Pos	12	LF	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
4	Room 401	R2	<4" PFI on white fibrous (4/26/90)	T		Pos	2	EA	F	N	2	2/18/94	Allen/Arche	30%					001-94-008
4	Room 402	0	No Suspect Material Visable		ND						0	2/18/94	Allen/Archer						001-94-008
4	Room 403	34	Sheetrock & taping compound	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008
4	Room 403	37	Red brick mortar	M	ND			SF			0	2/18/94	Allen/Archer						001-94-008