

Fir	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
B	Crawl Space	0.1	<4" aircell PI (assumed)	T		Pos	1	LF	F	L	3	3/14/94	Allen/Archer							003-94-017
B	Crawl Space	8	4"-8" white fibrous PI	T		Pos	73	LF	F	N	2	3/14/94	Allen/Arche	10%	25%					003-94-017
B	Crawl Space	9	4"-8" PFI on white fibrous	T		Pos	7	EA	F	N	2	3/14/94	Allen/Archer		25%			<1%		003-94-017
B	Crawl Space	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Crawl Space	39	Tar on fiberglass batting	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Crawl Space	R1	<4" white fibrous PI (4/12/90)	T		Pos	4	LF	F	N	2	3/14/94	Allen/Archer		25%					003-94-017
B	Crawl Space	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	1	EA	F	N	2	3/14/94	Allen/Arche	10%	25%					003-94-017
B	Crawl Space	R3	<4" felt w/tar PI (4/9/90)	T		Pos	225	LF	F	N	2	3/14/94	Allen/Archer		3%					003-94-017
B	Crawl Space	R4	<4" fibrous PFI on felt (4/9/90)	T		Pos	85	EA	F	N	2	3/14/94	Allen/Archer		25%					003-94-017
B	Hallway	8	4"-8" white fibrous PI	T		Pos	4	LF	F	N	2	3/14/94	Allen/Arche	10%	25%					003-94-017
B	Hallway	9	4"-8" PFI on white fibrous	T		Pos	3	EA	F	N	2	3/14/94	Allen/Archer		25%			<1%		003-94-017
B	Hallway	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Hallway	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Hallway	12	12"x12" pegboard CT	M	ND		230	SF	F	N	0	3/14/94	Allen/Archer							003-94-017
B	Hallway	12.5	Ceiling tile adhesive (sample 12)	M	ND		230	SF	N	N	0	3/14/94	Allen/Archer							003-94-017
B	Hallway	13	12"x12" fissured CT	M	ND		265	SF	F	N	0	3/14/94	Allen/Archer							003-94-017
B	Hallway	13.5	Ceiling tile adhesive (sample 13)	M	ND		265	SF	N	N	0	3/14/94	Allen/Archer							003-94-017
B	Hallway	23	12"x12" light grey w/grey & white FT	M		Pos	715	SF	N	L	1	3/14/94	Allen/Archer		5%					003-94-017
B	Hallway	23.5	Floor tile adhesive (sample 23)	M		Pos	715	SF	N	N	1	3/14/94	Allen/Archer		10%					003-94-017
B	Hallway	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Hallway	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer							003-94-017
B	Room 01	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 01	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 02	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 02	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 03	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 03	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 03	41	Canvass vibration joint	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 04 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 04 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
B	Room 04 A	47	9"x9" beige w/brown & cream FT	M		Pos	102	SF	N	N	1	3/14/94	Allen/Archer		5%					003-94-017

B	Room 04 A	47.5	Floor tile adhesive (sample 47)	M	ND		102	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 04	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 04	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 04	23	12"x12" light grey w/grey & white FT	M		Pos	20	SF	N	N	1	3/14/94	Allen/Archer	5%					003-94-017
B	Room 04	23.5	Floor tile adhesive (sample 23)	M		Pos	20	SF	N	N	1	3/14/94	Allen/Archer	10%					003-94-017
B	Room 05 A	8	4"-8" white fibrous PI	T		Pos	32	LF	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
B	Room 05 A	9	4"-8" PFI on white fibrous	T		Pos	11	EA	F	N	2	3/14/94	Allen/Archer	25%			<1%		003-94-017
B	Room 05 A	38	Fiberboard	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05 A	40	Pipe putty	M	ND		2	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 05 A	R1	<4" white fibrous PI (4/12/90)	T		Pos	48	LF	F	N	2	3/14/94	Allen/Archer	25%					003-94-017
B	Room 05 A	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	15	EA	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
B	Room 05 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05	8	4"-8" white fibrous PI	T		Pos	68	LF	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
B	Room 05	9	4"-8" PFI on white fibrous	T		Pos	6	EA	F	N	2	3/14/94	Allen/Archer	25%			<1%		003-94-017
B	Room 05	15	12"x12" nailhole fissured CT	M	ND		1065	SF	F	L	0	3/14/94	Allen/Archer						003-94-017
B	Room 05	15.5	Ceiling tile adhesive (sample 15)	M	ND		1065	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 05	26	12"x12" tan w/grey & white FT	M	ND		1065	SF	N	L	0	3/14/94	Allen/Archer						003-94-017
B	Room 05	26.5	Floor tile adhesive (sample 26)	M		Pos	1065	SF	N	N	1	3/14/94	Allen/Archer	15%					003-94-017
B	Room 05	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05	38	Fiberboard	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 05	R1	<4" white fibrous PI (4/12/90)	T		Pos	123	LF	F	N	2	3/14/94	Allen/Archer	25%					003-94-017
B	Room 05	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	34	EA	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
B	Room 05	R3	<4" felt w/tar PI (4/9/90)	T		Pos	16	LF	F	N	2	3/14/94	Allen/Archer	3%					003-94-017
B	Room 05	R4	<4" fibrous PFI on felt (4/9/90)	T		Pos	5	EA	F	N	2	3/14/94	Allen/Archer	25%					003-94-017
B	Room 06 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 06 A	R1	<4" white fibrous PI (4/12/90)	T		Pos	40	LF	F	N	2	3/14/94	Allen/Archer	25%					003-94-017
B	Room 06 A	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	16	EA	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
B	Room 06 A	R3	<4" felt w/tar PI (4/9/90)	T		Pos	24	LF	F	N	2	3/14/94	Allen/Archer	3%					003-94-017
B	Room 06 A	R4	<4" fibrous PFI on felt (4/9/90)	T		Pos	8	EA	F	N	2	3/14/94	Allen/Archer	25%					003-94-017

B	Room 06 B	10	Ceiling plaster	S	ND			SF		0	3/14/94	Allen/Archer							003-94-017
B	Room 06 B	11	Wall plaster	S	ND			SF		0	3/14/94	Allen/Archer							003-94-017
B	Room 06 B	33	Baseboard adhesive	M	ND			LF		0	3/14/94	Allen/Archer							003-94-017
B	Room 06 B	34	Concrete block mortar	M	ND			SF		0	3/14/94	Allen/Archer							003-94-017
B	Room 06	5	<4" fiberglass w/tar PI	T	ND		10	LF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 06	6	<4" fibrous PFI on FG w/tar	T		Pos	2	EA	F	N	2	3/14/94	Allen/Archer		15%				003-94-017
B	Room 06	8	4"-8" white fibrous PI	T		Pos	158	LF	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 06	9	4"-8" PFI on white fibrous	T		Pos	34	EA	F	N	2	3/14/94	Allen/Archer		25%			<1%	003-94-017
B	Room 06	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 06	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 06	12	12"x12" pegboard CT	M	ND		1972	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
B	Room 06	12.5	Ceiling tile adhesive (sample 12)	M	ND		1972	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
B	Room 06	14	12"x12" random hole CT	M	ND		680	SF	F	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 06	14.5	Ceiling tile adhesive (sample 14)	M		Pos	680	SF	N	N	1	3/14/94	Allen/Archer		2%				003-94-017
B	Room 06	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
B	Room 06	R1	<4" white fibrous PI (4/12/90)	T		Pos	194	LF	F	L	3	3/14/94	Allen/Archer		25%				003-94-017
B	Room 06	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	62	EA	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 06	R3	<4" felt w/tar PI (4/9/90)	T		Pos	318	LF	F	N	2	3/14/94	Allen/Archer		3%				003-94-017
B	Room 06	R4	<4" fibrous PFI on felt (4/9/90)	T		Pos	46	EA	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
B	Room 11	7	<4" fibrous PFI on fiberglass	T	ND		9	EA	F	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 11	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 11	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 11	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 11	36	Red clay tile mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 12	8	4"-8" white fibrous PI	T		Pos	22	LF	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 12	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 12	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 12	23	12"x12" light grey w/grey & white FT	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		5%				003-94-017
B	Room 12	23.5	Floor tile adhesive (sample 23)	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		10%				003-94-017
B	Room 12	R1	<4" white fibrous PI (4/12/90)	T		Pos	22	LF	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
B	Room 12	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	15	EA	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 13	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017

B	Room 13	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 13	13	12"x12" fissured CT	M	ND		224	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
B	Room 13	13.5	Ceiling tile adhesive (sample 13)	M	ND		224	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
B	Room 13	28	12"x12" white w/black & grey FT	M		Pos	224	SF	N	N	1	3/14/94	Allen/Archer		3%				003-94-017
B	Room 13	28.5	Floor tile adhesive (sample 28)	M		Pos	224	SF	N	N	1	3/14/94	Allen/Archer		5%				003-94-017
B	Room 13	R1	<4" white fibrous PI (4/12/90)	T		Pos	58	LF	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
B	Room 13	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	10	EA	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 13	R3	<4" felt w/tar PI (4/9/90)	T		Pos	30	LF	F	N	2	3/14/94	Allen/Archer		3%				003-94-017
B	Room 14	8	4"-8" white fibrous PI	T		Pos	15	LF	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 14	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 14	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 14	23	12"x12" light grey w/grey & white FT	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		5%				003-94-017
B	Room 14	23.5	Floor tile adhesive (sample 23)	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		10%				003-94-017
B	Room 15	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 15	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 15	50	12"x12" white w/black & light grey FT	M	ND		180	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 15	50.5	Floor tile adhesive (sample 50)	M	ND		180	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
B	Room 15	R1	<4" white fibrous PI (4/12/90)	T		Pos	51	LF	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
B	Room 15	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	6	EA	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 15	R3	<4" felt w/tar PI (4/9/90)	T		Pos	15	LF	F	N	2	3/14/94	Allen/Archer		3%				003-94-017
B	Room 16	8	4"-8" white fibrous PI	T		Pos	34	LF	F	L	3	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 16	9	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2	3/14/94	Allen/Archer		25%			<1%	003-94-017
B	Room 16	13	12"x12" fissured CT	M	ND		240	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
B	Room 16	13.5	Ceiling tile adhesive (sample 13)	M	ND		240	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
B	Room 16	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 16	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 16	36	Red clay tile mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 16	R1	<4" white fibrous PI (4/12/90)	T		Pos	1	LF	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
B	Room 16	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	3	EA	F	N	2	3/14/94	Allen/Archer	10%	25%				003-94-017
B	Room 17	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 17	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
B	Room 17	19	9"x9" grey w/tan & charcoal FT	M	ND		60	SF	N	L	0	3/14/94	Allen/Archer						003-94-017
B	Room 17	19.5	Floor tile adhesive (sample 19)	M	ND		60	SF	N	N	0	3/14/94	Allen/Archer						003-94-017

B	Room 17	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
B	Room 17	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
	East Stairwa	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
	East Stairwa	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
	East Stairwa	29	12"x12" grey w/tan & black FT	M	ND		56	SF	N	L	0	3/14/94	Allen/Archer					003-94-017
	East Stairwa	29.5	Floor tile adhesive (sample 29)	M	ND		56	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
	East Stairwa	30	12"x12" black w/tan FT	M		Pos	10	SF	N	L	1	3/14/94	Allen/Archer		2%			003-94-017
	East Stairwa	30.5	Floor tile adhesive (sample 30)	M		Pos	10	SF	N	N	1	3/14/94	Allen/Archer		5%			003-94-017
	Elevator	25	12"x12" white w/tan FT	M	ND		34	SF	N	L	0	3/14/94	Allen/Archer					003-94-017
	Elevator	25.5	Floor tile adhesive (sample 25)	M	ND		34	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
	North Stairw	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
	North Stairw	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
	North Stairw	23	12"x12" light grey w/grey & white FT	M		Pos	32	SF	N	N	1	3/14/94	Allen/Archer		5%			003-94-017
	North Stairw	23.5	Floor tile adhesive (sample 23)	M		Pos	32	SF	N	N	1	3/14/94	Allen/Archer		10%			003-94-017
	North Stairw	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
	North Stairw	R1	<4" white fibrous PI (4/12/90)	T		Pos	12	LF	F	L	3	3/14/94	Allen/Archer		25%			003-94-017
	North Stairw	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	1	EA	F	N	2	3/14/94	Allen/Arche	10%	25%			003-94-017
	South Stairw	7	<4" fibrous PFI on fiberglass	T	ND		3	EA	F	N	2	3/14/94	Allen/Archer					003-94-017
	South Stairw	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
	South Stairw	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Hallway	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Hallway	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Hallway	13	12"x12" fissured CT	M	ND		240	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Hallway	13.5	Ceiling tile adhesive (sample 13)	M	ND		240	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Hallway	27	12"x12" toffee w/black FT	M	ND		510	SF	N	L	0	3/14/94	Allen/Archer					003-94-017
1	Hallway	27.5	Floor tile adhesive (sample 27)	M		Pos	510	SF	N	N	1	3/14/94	Allen/Archer		20%			003-94-017
1	Hallway	31	Brown flooring	M	ND		660	SF	N	L	0	3/14/94	Allen/Archer					003-94-017
1	Room 100 (H	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 100 (H	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 100 (H	12	12"x12" pegboard CT	M	ND		84	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 100 (H	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017

1	Room 100	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 100	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 100	19	9"x9" grey w/tan & charcoal FT	M	ND		84	SF	N	L	1	3/14/94	Allen/Archer						003-94-017
1	Room 100	19.5	Floor tile adhesive (sample 19)	M	ND		84	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 100	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 100	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 A	22	12"x12" white w/beige FT	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		3%				003-94-017
1	Room 101 A	22.5	Floor tile adhesive (sample 22)	M		Pos	168	SF	N	N	1	3/14/94	Allen/Archer		20%				003-94-017
1	Room 101 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 B	12	12"x12" pegboard CT	M	ND		140	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 101 B	12.5	Ceiling tile adhesive (sample 12)	M	ND		140	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 101 B	22	12"x12" white w/beige FT	M		Pos	140	SF	N	N	1	3/14/94	Allen/Archer		3%				003-94-017
1	Room 101 B	22.5	Floor tile adhesive (sample 22)	M		Pos	140	SF	N	N	1	3/14/94	Allen/Archer		20%				003-94-017
1	Room 101 B	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 C	22	12"x12" white w/beige FT	M		Pos	96	SF	N	N	1	3/14/94	Allen/Archer		3%				003-94-017
1	Room 101 C	22.5	Floor tile adhesive (sample 22)	M		Pos	96	SF	N	N	1	3/14/94	Allen/Archer		20%				003-94-017
1	Room 101 C	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 C	43	2'x4' pinhole fissured CT	M	ND		96	SF	F	N	0	3/14/94	Allen/Archer						003-94-017
1	Room 101 D	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 D	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 101 D	12	12"x12" pegboard CT	M	ND		210	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 101 D	12.5	Ceiling tile adhesive (sample 12)	M	ND		210	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 101 D	22	12"x12" white w/beige FT	M		Pos	210	SF	N	N	1	3/14/94	Allen/Archer		3%				003-94-017
1	Room 101 D	22.5	Floor tile adhesive (sample 22)	M		Pos	210	SF	N	N	1	3/14/94	Allen/Archer		20%				003-94-017
1	Room 101 D	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017

1	Room 101 E	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 E	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 E	12	12"x12" pegboard CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 101 E	12.5	Ceiling tile adhesive (sample 12)	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 101 E	22	12"x12" white w/beige FT	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	3%				003-94-017
1	Room 101 E	22.5	Floor tile adhesive (sample 22)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	20%				003-94-017
1	Room 101 E	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 F	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 F	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 F	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101 F	46	Grey flooring	M	ND		50	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
1	Room 101 F	46.5	Flooring adhesive (sample 46)	M	ND		50	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
1	Room 101	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 101	22	12"x12" white w/beige FT	M		Pos	90	SF	N	L	1	3/14/94	Allen/Archer	3%				003-94-017
1	Room 101	22.5	Floor tile adhesive (sample 22)	M		Pos	90	SF	N	N	1	3/14/94	Allen/Archer	20%				003-94-017
1	Room 101	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 A	19	9"x9" grey w/tan & charcoal FT	M	ND		144	SF	N	L	1	3/14/94	Allen/Archer					003-94-017
1	Room 102 A	19.5	Floor tile adhesive (sample 19)	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 102 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 D	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 D	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 D	27	12"x12" toffee w/black FT	M	ND		308	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 102 D	27.5	Floor tile adhesive (sample 27)	M		Pos	308	SF	N	N	1	3/14/94	Allen/Archer	20%				003-94-017
1	Room 102 D	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102 D	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	19	9"x9" grey w/tan & charcoal FT	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	19.5	Floor tile adhesive (sample 19)	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	27	12"x12" toffee w/black FT	M	ND		612	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	27.5	Floor tile adhesive (sample 27)	M		Pos	612	SF	N	N	1	3/14/94	Allen/Archer	20%				003-94-017

1	Room 102/M	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 102/M	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 103	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 103	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 103	45	12"x12" light grey w/white FT	M		Pos	108	SF	N	L	1	3/14/94	Allen/Archer	3%				003-94-017
1	Room 103	45.5	Floor tile adhesive (sample 45)	M	ND		108	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	12	12"x12" pegboard CT	M	ND		126	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	12.5	Ceiling tile adhesive (sample 12)	M	ND		126	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	31	Brown flooring	M	ND		126	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104 A	R1	<4" white fibrous PI (4/12/90)	T		Pos	36	LF	F	N	2	3/14/94	Allen/Archer	25%				003-94-017
1	Room 104 A	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	1	EA	F	N	2	3/14/94	Allen/Arche	10%	25%			003-94-017
1	Room 104	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104	12	12"x12" pegboard CT	M	ND		510	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 104	12.5	Ceiling tile adhesive (sample 12)	M	ND		510	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 104	31	Brown flooring	M	ND		146	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 104	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 104	R1	<4" white fibrous PI (4/12/90)	T		Pos	16	LF	F	L	3	3/14/94	Allen/Archer	25%				003-94-017
1	Room 104	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	2	EA	F	N	2	3/14/94	Allen/Arche	10%	25%			003-94-017
1	Room 105	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 105	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 105	14	12"x12" random hole CT	M	ND		144	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 105	14.5	Ceiling tile adhesive (sample 14)	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
1	Room 105	21	9"x9" beige w/grey & tan FT	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer	5%				003-94-017
1	Room 105	21.5	Floor tile adhesive (sample 21)	M	ND		144	SF	N	N	0	3/14/94	Allen/Archer					003-94-017
1	Room 105	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 106	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 106	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 106	31	Brown flooring	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer					003-94-017

1	Room 107	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 107	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 107	14	12"x12" random hole CT	M	ND		144	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 107	14.5	Ceiling tile adhesive (sample 14)	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer		2%				003-94-017
1	Room 107	21	9"x9" beige w/grey & tan FT	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer		5%				003-94-017
1	Room 107	21.5	Floor tile adhesive (sample 21)	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 107	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108 A	31	Brown flooring	M	ND		128	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 108	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108	31	Brown flooring	M	ND		112	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 108	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 108	37	Grey mastic on metal duct	M	ND		20	SF	N	N	0	3/14/94	Allen/Archer						003-94-017
1	Room 108	48	Fiberglass duct w/canvass wrap	T	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 109 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 109 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 109 A	31	Brown flooring	M	ND		128	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 109	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 109	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 109	12	12"x12" pegboard CT	M	ND		256	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 109	12.5	Ceiling tile adhesive (sample 12)	M	ND		256	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 109	31	Brown flooring	M	ND		256	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 109	R1	<4" white fibrous PI (4/12/90)	T		Pos	46	LF	F	N	2	3/14/94	Allen/Archer		25%				003-94-017
1	Room 109	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	13	EA	F	N	2	3/14/94	Allen/Arche	10%	25%				003-94-017
1	Room 110 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 110 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 110 A	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer		2%				003-94-017
1	Room 110 A	18	2'x2' nail hole worm CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 110 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017

1	Room 110 A	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 A	46	Grey flooring	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110 A	46.5	Flooring adhesive (sample 46)	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
1	Room 110 B	18	2'x2' nail hole worm CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	46	Grey flooring	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110 B	46.5	Flooring adhesive (sample 46)	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
1	Room 110 C	18	2'x2' nail hole worm CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	46	Grey flooring	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110 C	46.5	Flooring adhesive (sample 46)	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110	14.5	Ceiling tile adhesive (sample 14)	M		Pos	660	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
1	Room 110	18	2'x2' nail hole worm CT	M	ND		660	SF	F	N	0	3/14/94	Allen/Archer					003-94-017
1	Room 110	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
1	Room 110	46	Grey flooring	M	ND		660	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 110	46.5	Flooring adhesive (sample 46)	M	ND		660	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 111 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 111 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
1	Room 111 A	14.5	Ceiling tile adhesive (sample 14)	M		Pos	120	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
1	Room 111 A	18	2'x2' nail hole worm CT	M	ND		120	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
1	Room 111 A	31	Brown flooring	M	ND		120	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
1	Room 111 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017

1	Room 111 A	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
1	Room 111 B	18	2'x2' nail hole worm CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	31	Brown flooring	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 B	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
1	Room 111 C	18	2'x2' nail hole worm CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	31	Brown flooring	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111 C	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111	14.5	Ceiling tile adhesive (sample 14)	M		Pos	660	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
1	Room 111	18	2'x2' nail hole worm CT	M	ND		660	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
1	Room 111	31	Brown flooring	M	ND		660	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 111	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 111	37	Grey mastic on metal duct	M	ND		24	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 112	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 112	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 112	45	12"x12" light grey w/white FT	M		Pos	120	SF	N	N	1	3/14/94	Allen/Archer	3%					003-94-017
1	Room 118 (f	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118 (f	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118	12	12"x12" pegboard CT	M	ND		264	SF	F	N	2	3/14/94	Allen/Archer						003-94-017

1	Room 118	12.5	Ceiling tile adhesive (sample 12)	M	ND		264	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
1	Room 118	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
1	Room 118	49	9"x9" light grey w/black & tan FT	M		Pos	264	SF	N	N	1	3/14/94	Allen/Archer	5%					003-94-017
1	Room 118	49.5	Floor tile adhesive (sample 49)	M		Pos	264	SF	N	N	1	3/14/94	Allen/Archer	20%					003-94-017
1	Room 150	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 150	44	fiberboard w/suspect paper	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
1	Room 150	48	Fiberglass duct w/canvass wrap	T	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Hallway	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Hallway	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Hallway	24	12"x12" light grey w/black & white FT	M		Pos	210	SF	N	L	1	3/14/94	Allen/Archer	2%					003-94-017
2	Hallway	24.5	Floor tile adhesive (sample 24)	M		Pos	210	SF	N	N	1	3/14/94	Allen/Archer	10%					003-94-017
2	Hallway	28	12"x12" white w/black & grey FT	M		Pos	300	SF	N	L	1	3/14/94	Allen/Archer	3%					003-94-017
2	Hallway	28.5	Floor tile adhesive (sample 28)	M		Pos	300	SF	N	N	1	3/14/94	Allen/Archer	5%					003-94-017
2	Hallway	31	Brown flooring	M	ND		420	SF	N	L	1	3/14/94	Allen/Archer						003-94-017
2	Room 201	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 201	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 201	47	9"x9" beige w/brown & cream FT	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer	5%					003-94-017
2	Room 201	47.5	Floor tile adhesive (sample 47)	M	ND		144	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	7	<4" fibrous PFI on fiberglass	T	ND		4	EA	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	13	12"x12" fissured CT	M	ND		252	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	13.5	Ceiling tile adhesive (sample 13)	M	ND		252	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	14	12"x12" random hole CT	M	ND		2562	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	14.5	Ceiling tile adhesive (sample 14)	M		Pos	2562	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 202,2	19	9"x9" grey w/tan & charcoal FT	M	ND		1324	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	19.5	Floor tile adhesive (sample 19)	M	ND		1324	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 202,2	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 203	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 203	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 203	12	12"x12" pegboard CT	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017

2	Room 203	12.5	Ceiling tile adhesive (sample 12)	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 203	16	2'x2' nail hole fissured CT	M	ND		280	SF	F	N	0	3/14/94	Allen/Archer					003-94-017
2	Room 203	24	12"x12" light grey w/black & white FT	M		Pos	280	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 203	24.5	Floor tile adhesive (sample 24)	M		Pos	280	SF	N	N	1	3/14/94	Allen/Archer	10%				003-94-017
2	Room 203	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	12	12"x12" pegboard CT	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	12.5	Ceiling tile adhesive (sample 12)	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	19	9"x9" grey w/tan & charcoal FT	M	ND		1356	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	19.5	Floor tile adhesive (sample 19)	M	ND		1356	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
2	Room 204/2	R1	<4" white fibrous PI (4/12/90)	T		Pos	1	LF	F	N	2	3/14/94	Allen/Archer	25%				003-94-017
2	Room 204/2	R2	<4" PFI on white fibrous (4/12/90)	T		Pos	1	EA	F	N	2	3/14/94	Allen/Archer	10%	25%			003-94-017
2	Room 205 (H)	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205 (H)	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205 (H)	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205 (H)	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205	24	12"x12" light grey w/black & white FT	M		Pos	90	SF	N	L	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 205	24.5	Floor tile adhesive (sample 24)	M		Pos	90	SF	N	N	1	3/14/94	Allen/Archer	10%				003-94-017
2	Room 205	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
2	Room 205	34	Concrete block mortar	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 206 (H)	0	No Suspect Material Visable		ND						0	3/14/94	Allen/Archer					003-94-017
2	Room 206	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 206	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 207/M	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 207/M	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 207/M	12	12"x12" pegboard CT	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 207/M	12.5	Ceiling tile adhesive (sample 12)	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 207/M	31	Brown flooring	M	ND		408	SF	N	N	1	3/14/94	Allen/Archer					003-94-017

2	Room 208 (C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 208 (C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 208 (C	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 208 (C	37	Grey mastic on metal duct	M	ND		30	SF	N	N	1	3/14/94	Allen/Archer							003-94-017
2	Room 208 (V	0	No Suspect Material Visable		ND						0	3/14/94	Allen/Archer							003-94-017
2	Room 208	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 208	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 209	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 209	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 209	12	12"x12" pegboard CT	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 209	12.5	Ceiling tile adhesive (sample 12)	M	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 209	31	Brown flooring	M	ND		176	SF	N	N	1	3/14/94	Allen/Archer							003-94-017
2	Room 210 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210 A	31	Brown flooring	M	ND		72	SF	N	N	1	3/14/94	Allen/Archer							003-94-017
2	Room 210 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210 B	31	Brown flooring	M	ND		72	SF	N	N	1	3/14/94	Allen/Archer							003-94-017
2	Room 210	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 210	31	Brown flooring	M	ND		126	SF	N	N	1	3/14/94	Allen/Archer							003-94-017
2	Room 211	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 211	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 211	20	9"x9" tan w/beige FT	M		Pos	100	SF	N	L	1	3/14/94	Allen/Archer		10%					003-94-017
2	Room 211	20.5	Floor tile adhesive (sample 20)	M	ND		100	SF	N	N	0	3/14/94	Allen/Archer							003-94-017
2	Room 211	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer							003-94-017
2	Room 212	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017
2	Room 212	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer							003-94-017

2	Room 212	12	12"x12" pegboard CT	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 212	12.5	Ceiling tile adhesive (sample 12)	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 212	31	Brown flooring	M	ND		256	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
2	Room 213	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 213	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 213	20	9"x9" tan w/beige FT	M		Pos	150	SF	N	L	1	3/14/94	Allen/Archer	10%				003-94-017
2	Room 213	20.5	Floor tile adhesive (sample 20)	M	ND		150	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
2	Room 213	37	Grey mastic on metal duct	M	ND		30	SF	N	N	1	3/14/94	Allen/Archer					003-94-017
2	Room 214 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 A	14.5	Ceiling tile adhesive (sample 14)	M		Pos	156	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 214 A	17	2'x2' pinhole fissured CT	M	ND		156	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
2	Room 214 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 A	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 B	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 214 B	17	2'x2' pinhole fissured CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
2	Room 214 B	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 B	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 C	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 214 C	17	2'x2' pinhole fissured CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
2	Room 214 C	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 C	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 D	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 D	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 D	14.5	Ceiling tile adhesive (sample 14)	M		Pos	100	SF	N	N	1	3/14/94	Allen/Archer	2%				003-94-017
2	Room 214 D	17	2'x2' pinhole fissured CT	M	ND		100	SF	F	N	2	3/14/94	Allen/Archer					003-94-017
2	Room 214 D	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer					003-94-017
2	Room 214 D	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer					003-94-017

2	Room 214 E	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214 E	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214	14.5	Ceiling tile adhesive (sample 14)	M		Pos	200	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 214	17	2'x2' pinhole fissured CT	M	ND		460	SF	F	N	0	3/14/94	Allen/Archer						003-94-017
2	Room 214	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 214	37	Grey mastic on metal duct	M	ND		110	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 215 A	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 A	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 A	14.5	Ceiling tile adhesive (sample 14)	M		Pos	180	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 215 A	17	2'x2' pinhole fissured CT	M	ND		180	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 215 A	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 A	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 B	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 B	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 B	14.5	Ceiling tile adhesive (sample 14)	M		Pos	144	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 215 B	17	2'x2' pinhole fissured CT	M	ND		144	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 215 B	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 B	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 C	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 C	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 C	14.5	Ceiling tile adhesive (sample 14)	M		Pos	130	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 215 C	17	2'x2' pinhole fissured CT	M	ND		130	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 215 C	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 C	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 D	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215 D	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017

2	Room 215	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215	14.5	Ceiling tile adhesive (sample 14)	M		Pos	492	SF	N	N	1	3/14/94	Allen/Archer	2%					003-94-017
2	Room 215	17	2'x2' pinhole fissured CT	M	ND		492	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 215	32	Sheetrock & taping compound	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 215	37	Grey mastic on metal duct	M	ND		45	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 218	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 218	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 218	13	12"x12" fissured CT	M	ND		336	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 218	13.5	Ceiling tile adhesive (sample 13)	M	ND		336	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 218	17	2'x2' pinhole fissured CT	M	ND		128	SF	F	N	2	3/14/94	Allen/Archer						003-94-017
2	Room 218	33	Baseboard adhesive	M	ND			LF			0	3/14/94	Allen/Archer						003-94-017
2	Room 218	37	Grey mastic on metal duct	M	ND		25	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
2	Room 222	10	Ceiling plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
2	Room 222	11	Wall plaster	S	ND			SF			0	3/14/94	Allen/Archer						003-94-017
3	Attic	35	Red brick mortar	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
3	Attic	37	Grey mastic on metal duct	M	ND		100	SF	N	N	1	3/14/94	Allen/Archer						003-94-017
3	Attic	41	Canvass vibration joint	M	ND			SF			0	3/14/94	Allen/Archer						003-94-017
3	Attic	42	Tar paper in attic	M	ND		150	SF	N	N	0	3/14/94	Allen/Archer						003-94-017