

| Flr | Location | Samp# | Description | Code | N.D. | Pos | Quan | Unit | Fri | Cond | Rate | Samp Date | Survey | Amos | Chrys | Croc | Trem | Actin | Anth | Project # |
|-----|-------------|-------|-------------------------------------|------|------|-----|------|------|-----|------|------|-----------|---------|------|-------|------|------|-------|------|------------|
| B | Hallway | 1 | <4" white fibrous PI | T | | Pos | 10 | LF | F | N | 2 | 11/15/99 | DCK/JAG | | 20% | | | | | 017-95-111 |
| B | Hallway | 2 | <4" PFI on white fibrous | T | | Pos | 5 | EA | F | N | 2 | 11/15/99 | DCK/JAG | | 25% | | | | | 017-95-111 |
| B | Hallway | 3 | <4" aircell PI | T | | Pos | 34 | LF | F | N | 2 | 11/15/99 | DCK/JAG | | 5% | | | | | 017-95-111 |
| B | Hallway | 4 | <4" fibrous PFI on aircell | T | | Pos | 6 | EA | F | N | 2 | 11/15/99 | DCK/JAG | | 20% | | | | | 017-95-111 |
| B | Hallway | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 10 | <4" fibrous PFI on FG | T | ND | | 13 | EA | F | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 35 | wall plaster | S | ND | | | SF | F | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 41 | 9"x9" FT tan w/white&grey streaks | M | ND | | 846 | SF | N | N | 0 | 11/15/99 | DCK/JAG | | | | | | | 017-95-111 |
| B | Hallway | 41.5 | floor tile adhesive (sample 41) | M | ND | | 846 | SF | N | N | 0 | 11/15/99 | | | | | | | | |
| B | Hallway | 137 | brown fiberboard | M | ND | | 8 | SF | N | N | 0 | | | | | | | | | |
| B | Room 1 | 1 | <4" white fibrous PI | T | | Pos | 8 | LF | F | N | 2 | | | | 20% | | | | | |
| B | Room 1 | 2 | <4" PFI on white fibrous | T | | Pos | 8 | EA | F | N | 2 | | | | 25% | | | | | |
| B | Room 1 | 3 | <4" aircell PI | T | | Pos | 105 | LF | F | N | 2 | | | | 5% | | | | | |
| B | Room 1 | 4 | <4" fibrous PFI on aircell | T | | Pos | 30 | EA | F | N | 2 | | | | 20% | | | | | |
| B | Room 1 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | | |
| B | Room 1 | 10 | <4" fibrous PFI on FG | T | ND | | 25 | EA | F | N | 0 | | | | | | | | | |
| B | Room 1 | 11 | 4"-8" white fibrous PI | T | | Pos | 50 | LF | F | N | 2 | | | | 15% | | | | | |
| B | Room 1 | 12 | 4"-8" PFI on white fibrous | T | | Pos | 6 | EA | F | N | 2 | | | 5% | 10% | | | | | |
| B | Room 1 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 1 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 1 | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | | | | | | | | | |
| B | Room 1 | 42 | 9"x9" FT beige w/brown & white stre | M | | Pos | 432 | SF | N | N | 1 | | | | 5% | | | | | |
| B | Room 1 | 42.5 | floor tile adhesive (sample 42) | M | | Pos | 432 | SF | N | N | 1 | | | | 3% | | | | | |
| B | Room 1 | 138 | black windowsills | M | ND | | 20 | SF | N | N | 0 | | | | | | | | | |
| B | Room 1(clos | 199 | INACCESSIBLE | | | | | | | | | | | | | | | | | |
| B | Room 2 | 1 | <4" white fibrous PI | T | | Pos | 14 | LF | F | N | 2 | | | | 20% | | | | | |

| | | | | | | | | | | | | | | | | | | | |
|---|--------|------|--------------------------------------|---|----|-----|-----|----|---|---|---|--|--|----|-----|--|--|--|--|
| B | Room 2 | 2 | <4" PFI on white fibrous | T | | Pos | 9 | EA | F | N | 2 | | | | 25% | | | | |
| B | Room 2 | 3 | <4" aircell PI | T | | Pos | 92 | LF | F | N | 2 | | | | 5% | | | | |
| B | Room 2 | 4 | <4" fibrous PFI on aircell | T | | Pos | 19 | EA | F | N | 2 | | | | 20% | | | | |
| B | Room 2 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | |
| B | Room 2 | 10 | <4" fibrous PFI on FG | T | ND | | 38 | EA | F | N | 0 | | | | | | | | |
| B | Room 2 | 10 | <4" fibrous PFI on FG | T | ND | | 2 | EA | F | M | 0 | | | | | | | | |
| B | Room 2 | 11 | 4"-8" white fibrous PI | T | | Pos | 47 | LF | F | N | 2 | | | | 15% | | | | |
| B | Room 2 | 12 | 4"-8" PFI on white fibrous | T | | Pos | 8 | EA | F | N | 2 | | | 5% | 10% | | | | |
| B | Room 2 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| B | Room 2 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| B | Room 2 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | |
| B | Room 2 | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | | | | | | | | |
| B | Room 2 | 42 | 9"x9" FT beige w/brown & white stre. | M | | Pos | 750 | SF | N | N | 1 | | | | 5% | | | | |
| B | Room 2 | 42.5 | floor tile adhesive (sample 42) | M | | Pos | 750 | SF | N | N | 1 | | | | 3% | | | | |
| B | Room 2 | 138 | black windowsills | M | ND | | 50 | SF | N | N | 0 | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| B | Room 4 | 1 | <4" white fibrous PI | T | | Pos | 25 | LF | F | N | 2 | | | | 20% | | | | |
| B | Room 4 | 2 | <4" PFI on white fibrous | T | | Pos | 15 | EA | F | N | 2 | | | | 25% | | | | |
| B | Room 4 | 3 | <4" aircell PI | T | | Pos | 39 | LF | F | N | 2 | | | | 5% | | | | |
| B | Room 4 | 4 | <4" fibrous PFI on aircell | T | | Pos | 22 | EA | F | N | 2 | | | | 20% | | | | |
| B | Room 4 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | |
| B | Room 4 | 10 | <4" fibrous PFI on FG | T | ND | | 4 | EA | F | N | 0 | | | | | | | | |
| B | Room 4 | 10 | <4" fibrous PFI on FG | T | ND | | 6 | EA | F | M | 0 | | | | | | | | |
| B | Room 4 | 11 | 4"-8" white fibrous PI | T | | Pos | 45 | LF | F | N | 2 | | | | 15% | | | | |
| B | Room 4 | 12 | 4"-8" PFI on white fibrous | T | | Pos | 7 | EA | F | N | 2 | | | 5% | 10% | | | | |
| B | Room 4 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| B | Room 4 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | |
| B | Room 4 | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|---|-------------|------|-------------------------------------|---|----|-----|-----|----|---|---|---|--|--|--|--|--|--|--|----|-----|
| | | | | | | | | | | | | | | | | | | | | |
| B | Room 8 | 1 | <4" white fibrous PI | T | | Pos | 25 | LF | F | N | 2 | | | | | | | | | 20% |
| B | Room 8 | 2 | <4" PFI on white fibrous | T | | Pos | 4 | EA | F | N | 2 | | | | | | | | | 25% |
| B | Room 8 | 3 | <4" aircell PI | T | | Pos | 65 | LF | F | N | 2 | | | | | | | | | 5% |
| B | Room 8 | 4 | <4" fibrous PFI on aircell | T | | Pos | 17 | EA | F | N | 2 | | | | | | | | | 20% |
| B | Room 8 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 8 | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | | | | | | | | | |
| B | Room 8 | 42 | 9"x9" FT beige w/brown & white stre | M | | Pos | 324 | SF | N | N | 1 | | | | | | | | | 5% |
| B | Room 8 | 42.5 | floor tile adhesive (sample 42) | M | | Pos | 324 | SF | N | N | 1 | | | | | | | | | 3% |
| B | Room 8 | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | | |
| B | Room 8(wall | 199 | INACCESSIBLE | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| B | Room 9 | 1 | <4" white fibrous PI | T | | Pos | 55 | LF | F | N | 2 | | | | | | | | | 20% |
| B | Room 9 | 2 | <4" PFI on white fibrous | T | | Pos | 8 | EA | F | N | 2 | | | | | | | | | 25% |
| B | Room 9 | 3 | <4" aircell PI | T | | Pos | 36 | LF | F | N | 2 | | | | | | | | | 5% |
| B | Room 9 | 4 | <4" fibrous PFI on aircell | T | | Pos | 3 | EA | F | N | 2 | | | | | | | | | 20% |
| B | Room 9 | 11 | 4"-8" white fibrous PI | T | | Pos | 12 | LF | F | N | 2 | | | | | | | | | 15% |
| B | Room 9 | 12 | 4"-8" PFI on white fibrous | T | | Pos | 2 | EA | F | N | 2 | | | | | | | | 5% | 10% |
| B | Room 9 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 9 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 9 | 40 | baseboard adhesive | M | ND | | | LF | N | N | 0 | | | | | | | | | |
| B | Room 9 | 42 | 9"x9" FT beige w/brown & white stre | M | | Pos | 324 | SF | N | N | 1 | | | | | | | | | 5% |
| B | Room 9 | 42.5 | floor tile adhesive (sample 42) | M | | Pos | 324 | SF | N | N | 1 | | | | | | | | | 3% |
| B | Room 9 | 138 | black windowsills | M | ND | | 8 | SF | N | N | 0 | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| B | Room 10 | 1 | <4" white fibrous PI | T | | Pos | 12 | LF | F | N | 2 | | | | | | | | | 20% |
| B | Room 10 | 2 | <4" PFI on white fibrous | T | | Pos | 6 | EA | F | N | 2 | | | | | | | | | 25% |
| B | Room 10 | 3 | <4" aircell PI | T | | Pos | 45 | LF | F | N | 2 | | | | | | | | | 5% |
| B | Room 10 | 4 | <4" fibrous PFI on aircell | T | | Pos | 8 | EA | F | N | 2 | | | | | | | | | 20% |
| B | Room 10 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | | |
| B | Room 10 | 10 | <4" fibrous PFI on FG | T | ND | | 31 | EA | F | N | 0 | | | | | | | | | |
| B | Room 10 | 10 | <4" fibrous PFI on FG | T | ND | | 4 | EA | F | M | 0 | | | | | | | | | |
| B | Room 10 | 11 | 4"-8" white fibrous PI | T | | Pos | 45 | LF | F | N | 2 | | | | | | | | | 15% |

| | | | | | | | | | | | | | | | | | | | | |
|---|--------------|-----|-------------------------------|---|----|-----|-----|----|---|---|---|--|--|----|--|-----|--|--|--|--|
| B | Room 13 | 1 | <4" white fibrous PI | T | | Pos | 3 | LF | F | N | 2 | | | | | 20% | | | | |
| B | Room 13 | 2 | <4" PFI on white fibrous | T | | Pos | 3 | EA | F | N | 2 | | | | | 25% | | | | |
| B | Room 13 | 3 | <4" aircell PI | T | | Pos | 80 | LF | F | N | 2 | | | | | 5% | | | | |
| B | Room 13 | 4 | <4" fibrous PFI on aircell | T | | Pos | 25 | EA | F | N | 2 | | | | | 20% | | | | |
| B | Room 13 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | | |
| B | Room 13 | 10 | <4" fibrous PFI on FG | T | ND | | 15 | EA | F | N | 0 | | | | | | | | | |
| B | Room 13 | 11 | 4"-8" white fibrous PI | T | | Pos | 12 | LF | F | N | 2 | | | | | 15% | | | | |
| B | Room 13 | 12 | 4"-8" PFI on white fibrous | T | | Pos | 2 | EA | F | N | 2 | | | 5% | | 10% | | | | |
| B | Room 13 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 13 | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Room 13(clo | 3 | <4" aircell PI | T | | Pos | 40 | LF | F | N | 2 | | | | | 5% | | | | |
| B | Room 13(clo | 4 | <4" fibrous PFI on aircell | T | | Pos | 17 | EA | F | N | 2 | | | | | 20% | | | | |
| B | Room 13(clo | 11 | 4"-8" white fibrous PI | T | | Pos | 10 | LF | F | N | 2 | | | | | 15% | | | | |
| B | Room 13(clo | 11 | 4"-8" white fibrous PI | T | | Pos | 5 | LF | F | H | 4 | | | | | 15% | | | | |
| B | Room 13(clo | 12 | 4"-8" PFI on white fibrous | T | | Pos | 3 | EA | F | H | 4 | | | 5% | | 10% | | | | |
| B | Room 13(clo | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 3 | <4" aircell PI | T | | Pos | 5 | LF | F | N | 2 | | | | | 5% | | | | |
| B | Tunnel(surve | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 36 | yellow brick mortar | M | ND | | | SF | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 140 | <4" cal-sil pipe insulation | T | ND | | 15 | LF | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 141 | <4" PFI on cal-sil PI | T | ND | | 16 | EA | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 142 | 4"-8" cal-sil pipe insulation | T | ND | | 12 | LF | F | N | 0 | | | | | | | | | |
| B | Tunnel(surve | 143 | 4"-8" PFI on cal-sil PI | T | ND | | 9 | EA | F | N | 0 | | | | | | | | | |
| 0 | Stairway | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| 0 | Stairway | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| 0 | Stairway | 100 | 12"x12" CT patterned nailhole | M | ND | | 180 | SF | F | N | 0 | | | | | | | | | |
| 1 | Hallway | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| 1 | Hallway | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | | |
| 1 | Room 101 | 3 | <4" aircell PI | T | | Pos | 38 | LF | F | N | 2 | | | | | 5% | | | | |
| 1 | Room 101 | 3 | <4" aircell PI | T | | Pos | 1 | LF | F | M | 3 | | | | | 5% | | | | |
| 1 | Room 101 | 4 | <4" fibrous PFI on aircell | T | | Pos | 13 | EA | F | N | 2 | | | | | 20% | | | | |
| 1 | Room 101 | 29 | black foam PI | T | ND | | | SF | F | N | 0 | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | |
|---|------------|-----|-----------------------------|---|----|-----|----|----|---|---|---|--|--|--|--|--|--|--|-----|
| 1 | Room 106A | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 106A | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 106B | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 106B | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 106B | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 107 | 3 | <4" aircell PI | T | | Pos | 45 | LF | F | N | 2 | | | | | | | | 5% |
| 1 | Room 107 | 4 | <4" fibrous PFI on aircell | T | | Pos | 9 | EA | F | N | 2 | | | | | | | | 20% |
| 1 | Room 107 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 107 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 107 | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 107(w | 3 | <4" aircell PI | T | | Pos | 55 | LF | F | N | 2 | | | | | | | | 5% |
| 1 | Room 107(w | 4 | <4" fibrous PFI on aircell | T | | Pos | 10 | EA | F | N | 2 | | | | | | | | 20% |
| 1 | Room 108 & | 3 | <4" aircell PI | T | | Pos | 40 | LF | F | N | 2 | | | | | | | | 5% |
| 1 | Room 108 & | 4 | <4" fibrous PFI on aircell | T | | Pos | 8 | EA | F | N | 2 | | | | | | | | 20% |
| 1 | Room 108 & | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 108 & | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 108 & | 39 | sheetrock & taping compound | M | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 108 & | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 108A | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 108A | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 108A | 138 | black windowsills | M | ND | | 30 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 109 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 109 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 109 | 131 | black lab top | M | ND | | 40 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 109 | 138 | black windowsills | M | ND | | 70 | SF | N | N | 0 | | | | | | | | |
| 1 | Room 109(w | 199 | INACCESSIBLE | | | | | | | | | | | | | | | | |
| 1 | Room 111 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 111 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 111 | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | |
|---|-----------|------|--|---|----|-----|------|----|---|---|---|--|--|--|--|--|--|--|-----|
| 1 | Room 112 | 9 | <4" FG PI | T | ND | | | LF | F | N | 0 | | | | | | | | |
| 1 | Room 112 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 112 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 113 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 1 | Room 113 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Hallway | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Hallway | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Hallway | 100 | 12"x12" CT patterned nailhole | M | ND | | 228 | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200A | 3 | <4" aircell PI | T | | Pos | 11 | LF | F | N | 2 | | | | | | | | 5% |
| 2 | Room 200A | 4 | <4" fibrous PFI on aircell | T | | Pos | 4 | EA | F | N | 2 | | | | | | | | 20% |
| 2 | Room 200A | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200A | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200A | 70 | 12"x12" FT biege w/brn&wht flecks | M | | Pos | 1767 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 200A | 70.5 | floor tile adhesive (sample 70) 8/29/0 | M | | Pos | 1767 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 200A | 100 | 12"x12" CT patterned nailhole | M | ND | | 1809 | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200C | 3 | <4" aircell PI | T | | Pos | 3 | LF | F | N | 2 | | | | | | | | 5% |
| 2 | Room 200C | 4 | <4" fibrous PFI on aircell | T | | Pos | 4 | EA | F | N | 2 | | | | | | | | 20% |
| 2 | Room 200C | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200C | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200D | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200D | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200D | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200D | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200E | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200E | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 200E | 39 | sheetrock & taping compound | M | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 201 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | |
|---|-----------|------|--|---|----|-----|-----|----|---|---|---|--|--|--|--|--|--|--|-----|
| 2 | Room 201 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 201 | 138 | black windowsills | M | ND | | 20 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 202 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 202 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 202 | 138 | black windowsills | M | ND | | 30 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 203 | 3 | <4" aircell PI | T | | Pos | 5 | LF | F | N | 2 | | | | | | | | 5% |
| 2 | Room 203 | 4 | <4" fibrous PFI on aircell | T | | Pos | 8 | EA | F | N | 2 | | | | | | | | 20% |
| 2 | Room 203 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203 | 70 | 12"x12" FT biege w/brn&wht flecks | M | | Pos | 171 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 203 | 70.5 | floor tile adhesive (sample 70) 8/29/0 | M | | Pos | 171 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 203 | 138 | black windowsills | M | ND | | 10 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 203A | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203A | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203A | 138 | black windowsills | M | ND | | 40 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 203B | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203B | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 203B | 70 | 12"x12" FT biege w/brn&wht flecks | M | | Pos | 380 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 203B | 70.5 | floor tile adhesive (sample 70) 8/29/0 | M | | Pos | 380 | SF | N | N | 1 | | | | | | | | 5% |
| 2 | Room 203B | 138 | black windowsills | M | ND | | 20 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 204 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 204 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 204 | 39 | sheetrock & taping compound | M | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207A | 3 | <4" aircell PI | T | | Pos | 3 | LF | F | N | 2 | | | | | | | | 5% |
| 2 | Room 207A | 4 | <4" fibrous PFI on aircell | T | | Pos | 4 | EA | F | N | 2 | | | | | | | | 20% |
| 2 | Room 207A | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207A | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207A | 137 | brown fiberboard | M | ND | | 200 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 207A | 138 | black windowsills | M | ND | | 50 | SF | N | N | 0 | | | | | | | | |
| 2 | Room 207A | 3 | <4" aircell PI | T | | Pos | 60 | LF | F | N | 2 | | | | | | | | 5% |

| | | | | | | | | | | | | | | | | | | | |
|---|-----------|-----|-----------------------------|---|----|-----|----|----|---|---|---|--|--|--|-----|--|--|--|--|
| 2 | Room 207A | 4 | <4" fibrous PFI on aircell | T | | Pos | 10 | EA | F | N | 2 | | | | 20% | | | | |
| 2 | Room 207A | 4 | <4" fibrous PFI on aircell | T | | Pos | 10 | EA | F | M | 3 | | | | 20% | | | | |
| | | | | | | | | | | | | | | | | | | | |
| 2 | Room 207B | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207B | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207B | 138 | black windowsills | M | ND | | 50 | SF | N | N | 0 | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| 2 | Room 207C | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207C | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 207C | 39 | sheetrock & taping compound | M | ND | | | SF | F | N | 0 | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| 2 | Room 209 | 34 | ceiling plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 209 | 35 | wall plaster | S | ND | | | SF | F | N | 0 | | | | | | | | |
| 2 | Room 209 | 138 | black windowsills | M | ND | | 20 | SF | N | N | 0 | | | | | | | | |