

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
S	Room S01	1	<4" white fibrous PI	T		Pos	7	LF	F	N	2	8/18/99	Allen/Archer	20%						051-95-074
S	Room S01	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2				25%					
S	Room S01	7	<4" fiberglass w/tar PI	T	ND		100	LF	F	N	0									
S	Room S01	8	<4" fibrous PFI on FG w/tar	T		Pos	32	EA	F	N	2				80%					
S	Room S01	8	<4" fibrous PFI on FG w/tar	T		Pos	1	EA	F	H	4				80%					
S	Room S01	11	4"-8" white fibrous PI	T		Pos	22	LF	F	N	2			10%	25%					
S	Room S01	12	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2			20%	5%					
S	Room S01	37	clay tile mortar	M	ND			SF	F	N	0									
S	Room S01	38	concrete block mortar	M	ND			SF	F	N	0									
S	Room S01		elevator brake pads(assumed)	M		Pos	2	SF	F	N	2									
S	Room S01(h	36	red brick mortar	M	ND			SF	F	N	0									
S	Room S01(h	37	clay tile mortar	M	ND			SF	F	N	0									
S	Room S03	37	clay tile mortar	M	ND			SF	F	N	0									
S	Room S05		<4" aircell PI(assumed)	T		Pos	270	LF	F	N	2									
S	Room S05		<4" fibrous PFI on aircell(assumed)	T		Pos	74	EA	F	N	2									
S	Room S05	5	<4" felt with tar PI	T		Pos	35	LF	F	N	2			5%	10%					
S	Room S05	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2			5%	10%					
S	Room S05	7	<4" fiberglass w/tar PI	T	ND		140	LF	F	N	0									
S	Room S05	8	<4" fibrous PFI on FG w/tar	T		Pos	19	EA	F	N	2				80%					
S	Room S05		4"-8" aircell PI(assumed)	T		Pos	220	LF	F	N	2									
S	Room S05		4"-8" fibrous PFI on aircell(assumed)	T		Pos	52	EA	F	N	2									
S	Room S05	37	clay tile mortar	M	ND			SF	F	N	0									
S	Room S05	38	concrete block mortar	M	ND			SF	F	N	0									
S	Room S05(hatch)		4"-8" aircell PI(assumed)	T		Pos	12	LF	F	L	3									
S	Room S05(hatch)		4"-8" fibrous PFI on aircell(assumed)	T		Pos	4	EA	F	L	3									
S	Room S05(h	37	clay tile mortar	M	ND			SF	F	N	0									
S	Room S05(h	38	concrete block mortar	M	ND			SF	F	N	0									
S	Room S05(hatch)		contaminated soil	M		Pos	300	SF	F	H	4									
S	Room S10	1	<4" white fibrous PI	T		Pos	95	LF	F	N	2			20%						
S	Room S10	2	<4" PFI on white fibrous	T		Pos	31	EA	F	N	2				25%					
S	Room S10		<4" aircell PI(assumed)	T		Pos	190	LF	F	N	2									

S	Room S15(t	36	red brick mortar	M	ND			SF	F	N	0								
S	Room S15(t	38	concrete block mortar	M	ND			SF	F	N	0								
S	Room S20	1	<4" white fibrous PI	T		Pos	45	LF	F	N	2		20%						
S	Room S20	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2			25%					
S	Room S20	5	<4" felt with tar PI	T		Pos	70	LF	F	N	2		5%	10%					
S	Room S20	6	<4" fibrous PFI on felt	T		Pos	15	EA	F	N	2		5%	10%					
S	Room S20	7	<4" fiberglass w/tar PI	T	ND		84	LF	F	N	0								
S	Room S20	8	<4" fibrous PFI on FG w/tar	T		Pos	30	EA	F	N	2			80%					
S	Room S20	9	<4" fiberglass PI	T	ND			LF	F	N	0								
S	Room S20	10	<4" fibrous PFI on FG	T	ND		7	EA	F	N	0								
S	Room S20	11	4"-8" white fibrous PI	T		Pos	124	LF	F	N	2		10%	25%					
S	Room S20	12	4"-8" PFI on white fibrous	T		Pos	27	EA	F	N	2		20%	5%					
S	Room S20	25	<4" pink fibrous PI	T		Pos	35	LF	F	N	2		25%						
S	Room S20	26	<4" PFI on pink fibrous	T		Pos	6	EA	F	N	2			25%					
S	Room S20	38	concrete block mortar	M	ND			SF	F	N	0								
S	Room S22		inaccessible																
S	Room S50		<4" aircell PI(assumed)	T		Pos	126	LF	F	N	2								
S	Room S50		<4" fibrous PFI on aircell(assumed)	T		Pos	44	EA	F	N	2								
S	Room S50	5	<4" felt with tar PI	T		Pos	104	LF	F	N	2		5%	10%					
S	Room S50	6	<4" fibrous PFI on felt	T		Pos	16	EA	F	N	2		5%	10%					
S	Room S50	7	<4" fiberglass w/tar PI	T	ND		368	LF	F	N	0								
S	Room S50	8	<4" fibrous PFI on FG w/tar	T		Pos	56	EA	F	N	2			80%					
S	Room S50	9	<4" fiberglass PI	T	ND			LF	F	N	0								
S	Room S50	10	<4" fibrous PFI on FG	T	ND		47	EA	F	N	0								
S	Room S50	11	4"-8" white fibrous PI	T		Pos	85	LF	F	N	2		10%	25%					
S	Room S50	12	4"-8" PFI on white fibrous	T		Pos	12	EA	F	L	3		20%	5%					
S	Room S50		4"-8" aircell PI(assumed)	T		Pos	358	LF	F	N	2								
S	Room S50		4"-8" fibrous PFI on aircell(assumed)	T		Pos	59	EA	F	N	2								
S	Room S50	37	clay tile mortar	M	ND			SF	F	N	0								
S	Room S50	38	concrete block mortar	M	ND			SF	F	N	0								
S	Room S50A	1	<4" white fibrous PI	T		Pos	48	LF	F	L	3		20%						
S	Room S50A	2	<4" PFI on white fibrous	T		Pos	12	EA	F	L	3			25%					
S	Room S50A	5	<4" felt with tar PI	T		Pos	56	LF	F	N	2		5%	10%					

B	Room B01/B	80	12"x12" pegboard CT	M	ND		1080	SF	F	N	0								
B	Room B01/B	80.5	ceiling tile adhesive (sample 80)	M	ND		1080	SF	N	N	0								
B	Room B03	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B03	35	wall plaster	S	ND			SF	F	N	0								
B	Room B06	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B06	35	wall plaster	S	ND			SF	F	N	0								
B	Room B07	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B07	35	wall plaster	S	ND			SF	F	N	0								
B	Room B07	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B12	1	<4" white fibrous PI	T		Pos	45	LF	F	N	2			20%					
B	Room B12	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2				25%				
B	Room B12	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B12	35	wall plaster	S	ND			SF	F	N	0								
B	Room B12	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B12	42	9"x9" light grey w/black & white FT	M		Pos	2000	SF	N	N	1					5%			
B	Room B12	42.5	floor tile adhesive (sample 42)	M		Pos	2000	SF	N	N	1					10%			
B	Room B12		metal pan ceiling(inaccessible above)																
B	Room B13	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B13	35	wall plaster	S	ND			SF	F	N	0								
B	Room B13	42	9"x9" light grey w/black & white FT	M		Pos	70	SF	N	N	1					5%			
B	Room B13	42.5	floor tile adhesive (sample 42)	M		Pos	70	SF	N	N	1					10%			
B	Room B13A	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B13A	35	wall plaster	S	ND			SF	F	N	0								
B	Room B13A	42	9"x9" light grey w/black & white FT	M		Pos	36	SF	N	N	1					5%			
B	Room B13A	42.5	floor tile adhesive (sample 42)	M		Pos	36	SF	N	N	1					10%			
B	Room B14	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B14	35	wall plaster	S	ND			SF	F	N	0								
B	Room B15	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B15	35	wall plaster	S	ND			SF	F	N	0								

B	Room B15	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B15	42	9"x9" light grey w/black & white FT	M		Pos	216	SF	N	N	1								5%
B	Room B15	42.5	floor tile adhesive (sample 42)	M		Pos	216	SF	N	N	1								10%
B	Room B20	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B20	35	wall plaster	S	ND			SF	F	N	0								
B	Room B20	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B20	65	12"x12" off white w/charcoal FT	M	ND		880	SF	N	N	0								
B	Room B20	65.5	floor tile adhesive (sample 65)	M		Pos	880	SF	N	N	1								5%
B	Room B20	80	12"x12" pegboard CT	M	ND		880	SF	F	N	0								
B	Room B20	80.5	ceiling tile adhesive (sample 80)	M	ND		880	SF	N	N	0								
B	Room B25	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B25	35	wall plaster	S	ND			SF	F	N	0								
B	Room B25	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B25	64	12"x12" off white w/black FT	M		Pos	880	SF	N	N	1								5%
B	Room B25	64.5	floor tile adhesive (sample 64)	M		Pos	880	SF	N	N	1								10%
B	Room B25	80	12"x12" pegboard CT	M	ND		880	SF	F	N	0								
B	Room B25	80.5	ceiling tile adhesive (sample 80)	M	ND		880	SF	N	N	0								
B	Room B27	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B27	35	wall plaster	S	ND			SF	F	N	0								
B	Room B29/B	1	<4" white fibrous PI	T		Pos	24	LF	F	N	2								20%
B	Room B29/B	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2								25%
B	Room B29/B	5	<4" felt with tar PI	T		Pos	100	LF	F	N	2								5% 10%
B	Room B29/B	6	<4" fibrous PFI on felt	T		Pos	13	EA	F	M	4								5% 10%
B	Room B29/B	11	4"-8" white fibrous PI	T		Pos	12	LF	F	N	2								10% 25%
B	Room B29/B	12	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2								20% 5%
B	Room B29/B	35	wall plaster	S	ND			SF	F	N	0								
B	Room B29/B	36	red brick mortar	M	ND			SF	F	N	0								
B	Room B29/B	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room B33	1	<4" white fibrous PI	T		Pos	20	LF	F	N	2								20%
B	Room B33	2	<4" PFI on white fibrous	T		Pos	6	EA	F	L	3								25%
B	Room B33	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room B33	35	wall plaster	S	ND			SF	F	N	0								

B	Room B39	79.5	ceiling tile adhesive (sample 79)	M	ND		192	SF	N	N	0									
B	Room B41	1	<4" white fibrous PI	T		Pos	48	LF	F	N	2		20%							
B	Room B41	2	<4" PFI on white fibrous	T		Pos	14	EA	F	N	2			25%						
B	Room B41	35	wall plaster	S	ND			SF	F	N	0									
B	Room B41	40	baseboard adhesive	M	ND			LF	N	N	0									
B	Room B41	46	9"x9" beige w/white FT	M		Pos	192	SF	N	N	1			10%						
B	Room B41	46.5	floor tile adhesive (sample 46)	M		Pos	192	SF	N	N	1			10%						
B	Room B41	79	12"x12" pinhole crater CT	M		Pos	192	SF	F	N	2		5%							
B	Room B41	79.5	ceiling tile adhesive (sample 79)	M	ND		192	SF	N	N	0									
B	Room B46	34	ceiling plaster	S	ND			SF	F	N	0									
B	Room B46	35	wall plaster	S	ND			SF	F	N	0									
B	Room B50	1	<4" white fibrous PI	T		Pos	42	LF	F	L	3		20%							
B	Room B50	2	<4" PFI on white fibrous	T		Pos	27	EA	F	N	2			25%						
B	Room B50	5	<4" felt with tar PI	T		Pos	14	LF	F	N	2		5%	10%						
B	Room B50	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2		5%	10%						
B	Room B50	7	<4" fiberglass w/tar PI	T	ND		122	LF	F	N	0									
B	Room B50	8	<4" fibrous PFI on FG w/tar	T		Pos	33	EA	F	N	2			80%						
B	Room B50	9	<4" fiberglass PI	T	ND			LF	F	N	0									
B	Room B50	11	4"-8" white fibrous PI	T		Pos	32	LF	F	N	2		10%	25%						
B	Room B50	12	4"-8" PFI on white fibrous	T		Pos	7	EA	F	N	2		20%	5%						
B	Room B50	35	wall plaster	S	ND			SF	F	N	0									
B	Room B50	36	red brick mortar	M	ND			SF	F	N	0									
B	Room B50	37	clay tile mortar	M	ND			SF	F	N	0									
B	Room B50	39	sheetrock & taping compound	M	ND			SF	F	N	0									
B	Room B50(h	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2		20%							
B	Room B50(h	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			25%						
B	Room B50(h	11	4"-8" white fibrous PI	T		Pos	12	LF	F	N	2		10%	25%						
B	Room B50(h	12	4"-8" PFI on white fibrous	T		Pos	1	EA	F	N	2		20%	5%						
B	Room B50(h	37	clay tile mortar	M	ND			SF	F	N	0									
B	Room B67	1	<4" white fibrous PI	T		Pos	33	LF	F	M	4		20%							
B	Room B67	2	<4" PFI on white fibrous	T		Pos	8	EA	F	M	4			25%						
B	Room B67	46	9"x9" beige w/white FT	M		Pos	270	SF	N	N	1			10%						

B	Room B67	46.5	floor tile adhesive (sample 46)	M		Pos	270	SF	N	N	1				10%				
B	Room B67	80	12"x12" pegboard CT	M	ND		270	SF	F	N	0								
B	Room B67	80.5	ceiling tile adhesive (sample 80)	M	ND		10	SF	N	N	0								
B	Room B68	1	<4" white fibrous PI	T		Pos	9	LF	F	N	2			20%					
B	Room B68	2	<4" PFI on white fibrous	T		Pos	5	EA	F	N	2				25%				
B	Room B68	35	wall plaster	S	ND			SF	F	N	0								
B	Room B68	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room B68	46	9"x9" beige w/white FT	M		Pos	192	SF	N	N	1				10%				
B	Room B68	46.5	floor tile adhesive (sample 46)	M		Pos	192	SF	N	N	1				10%				
B	Room B68	80	12"x12" pegboard CT	M	ND		192	SF	F	N	0								
B	Room B68	80.5	ceiling tile adhesive (sample 80)	M	ND		10	SF	N	N	0								
G	Hallway(hatc	1	<4" white fibrous PI	T		Pos	4	LF	F	N	2			20%					
G	Hallway(hatc	34	ceiling plaster	S	ND			SF	F	N	0								
G	Hallway(hatc	35	wall plaster	S	ND			SF	F	N	0								
G	Hallway	1	<4" white fibrous PI	T		Pos	8	LF	F	N	2			20%					
G	Hallway	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2				25%				
G	Hallway	34	ceiling plaster	S	ND			SF	F	N	0								
G	Hallway	35	wall plaster	S	ND			SF	F	N	0								
G	Hallway	39	sheetrock & taping compound	M	ND			SF	F	N	0								
G	Hallway	40	baseboard adhesive	M	ND			LF	N	N	0								
G	Hallway	60	12"x12" beige w/brown & cream FT	M		Pos	220	SF	N	N	1				5%				
G	Hallway	60.5	floor tile adhesive (sample 60)	M		Pos	220	SF	N	N	1				10%				
G	Room 20	1	<4" white fibrous PI	T		Pos	1	LF	F	N	2			20%					
G	Room 20	11	4"-8" white fibrous PI	T		Pos	18	LF	F	N	2			10%	25%				
G	Room 20	12	4"-8" PFI on white fibrous	T		Pos	3	EA	F	N	2			20%	5%				
G	Room 20	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 20	35	wall plaster	S	ND			SF	F	N	0								
G	Room 20	36	red brick mortar	M	ND			SF	F	N	0								
G	Room 20	39	sheetrock & taping compound	M	ND			SF	F	N	0								
G	Room 20	40	baseboard adhesive	M	ND			LF	N	N	0								
G	Room 20	67	12"x12" cream w/brown FT	M	ND		180	SF	N	N	0								
G	Room 20	67.5	floor tile adhesive (sample 67)	M	ND		180	SF	N	N	0								
G	Room 20	83	12"x12" computer board CT	M	ND		594	SF	F	N	0								

G	Room 20	83.5	ceiling tile adhesive (sample 83)	M	ND		594	SF	N	N	0								
G	Room 20	103	brown & cream linoleum	M	ND		350	SF	N	N	0								
G	Room 20(ha	36	red brick mortar	M	ND			SF	F	N	0								
G	Room 24	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 24	35	wall plaster	S	ND			SF	F	N	0								
G	Room 24	61	12"x12" carmel w/brown & white FT	M	ND		30	SF	N	N	0								
G	Room 24	61.5	floor tile adhesive (sample 61)	M	ND		30	SF	N	N	0								
G	Room 24	83	12"x12" computer board CT	M	ND		30	SF	F	N	0								
G	Room 24	83.5	ceiling tile adhesive (sample 83)	M	ND		30	SF	N	N	0								
G	Room 25	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 25	35	wall plaster	S	ND			SF	F	N	0								
G	Room 26	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 26	35	wall plaster	S	ND			SF	F	N	0								
G	Room 26	41	9"x9" light brown w/brown & white F	M		Pos	192	SF	N	N	1							10%	
G	Room 26	41.5	floor tile adhesive (sample 41)	M		Pos	192	SF	N	N	1							10%	
G	Room 26A		inaccessible																
G	Room 26B	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 26B	35	wall plaster	S	ND			SF	F	N	0								
G	Room 28	1	<4" white fibrous PI	T		Pos	37	LF	F	N	2							20%	
G	Room 28	2	<4" PFI on white fibrous	T		Pos	13	EA	F	N	2								25%
G	Room 28	11	4"-8" white fibrous PI	T		Pos	12	LF	F	N	2							10%	25%
G	Room 28	12	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2							20%	5%
G	Room 28	25	<4" pink fibrous PI	T		Pos	42	LF	F	N	2							25%	
G	Room 28	36	red brick mortar	M	ND			SF	F	N	0								
G	Room 28	37	clay tile mortar	M	ND			SF	F	N	0								
G	Room 33	1	<4" white fibrous PI	T		Pos	6	LF	F	N	2							20%	
G	Room 33	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2								25%
G	Room 33	34	ceiling plaster	S	ND			SF	F	N	0								
G	Room 33	35	wall plaster	S	ND			SF	F	N	0								

M	Room M139	1	<4" white fibrous PI	T		Pos	18	LF	F	N	2			20%						
M	Room M139	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2				25%					
M	Room M139	34	ceiling plaster	S	ND			SF	F	N	0									
M	Room M139	35	wall plaster	S	ND			SF	F	N	0									
M	Room M139	40	baseboard adhesive	M	ND			LF	N	N	0									
M	Room M139	45	9"x9" emerald green w/white FT	M		Pos	192	SF	N	N	1				10%					
M	Room M139	45.5	floor tile adhesive (sample 45)	M		Pos	192	SF	N	N	1				5%					
M	Room M141	1	<4" white fibrous PI	T		Pos	3	LF	F	N	2			20%						
M	Room M141	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2				25%					
M	Room M141	34	ceiling plaster	S	ND			SF	F	N	0									
M	Room M141	35	wall plaster	S	ND			SF	F	N	0									
M	Room M141	40	baseboard adhesive	M	ND			LF	N	N	0									
M	Room M141	45	9"x9" emerald green w/white FT	M		Pos	160	SF	N	N	1				10%					
M	Room M141	45.5	floor tile adhesive (sample 45)	M		Pos	160	SF	N	N	1				5%					
M	Room M150	1	<4" white fibrous PI	T		Pos	35	LF	F	N	2			20%						
M	Room M150	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2				25%					
M	Room M150	36	red brick mortar	M	ND			SF	F	N	0									
M	Room M150	37	clay tile mortar	M	ND			SF	F	N	0									
M	Room M150	39	sheetrock & taping compound	M	ND			SF	F	N	0									
M	Room M150	40	baseboard adhesive	M	ND			LF	N	N	0									
M	Room M165	34	ceiling plaster	S	ND			SF	F	N	0									
M	Room M165	35	wall plaster	S	ND			SF	F	N	0									
M	Room M165	103	brown & cream linoleum	M	ND		188	SF	N	N	0									
M	Room M167	34	ceiling plaster	S	ND			SF	F	N	0									
M	Room M167	35	wall plaster	S	ND			SF	F	N	0									
M	Room M167	103	brown & cream linoleum	M	ND		130	SF	N	N	0									
M	Room M169	34	ceiling plaster	S	ND			SF	F	N	0									
M	Room M169	35	wall plaster	S	ND			SF	F	N	0									
M	Room M169	103	brown & cream linoleum	M	ND		130	SF	N	N	0									
	Stairs South	11	4"-8" white fibrous PI	T		Pos	6	LF	F	N	2			10%	25%					

	Stairs South	12	4"-8" PFI on white fibrous	T		Pos	3	EA	F	N	2			20%	5%				
	Stairs South	34	ceiling plaster	S	ND			SF	F	N	0								
	Stairs South	35	wall plaster	S	ND			SF	F	N	0								
	Stairs South	38	concrete block mortar	M	ND			SF	F	N	0								
	Stairs South	40	baseboard adhesive	M	ND			LF	N	N	0								
	Stairs South	60	12"x12" beige w/brown & cream FT	M		Pos	70	SF	N	N	1				5%				
	Stairs South	60.5	floor tile adhesive (sample 60)	M		Pos	70	SF	N	N	1				10%				
	Stairs to Per	34	ceiling plaster	S	ND			SF	F	N	0								
	Stairs to Per	35	wall plaster	S	ND			SF	F	N	0								
	Stairs to Per	40	baseboard adhesive	M	ND			LF	N	N	0								
	Stairs to Penthouse 34		inaccessible																
1	Hallway(hatc	1	<4" white fibrous PI	T		Pos	31	LF	F	N	2			20%					
1	Hallway(hatc	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2				25%				
1	Hallway(hatc	34	ceiling plaster	S	ND			SF	F	N	0								
1	Hallway(hatc	35	wall plaster	S	ND			SF	F	N	0								
1	Hallway(hatc	36	red brick mortar	M	ND			SF	F	N	0								
1	Hallway	34	ceiling plaster	S	ND			SF	F	N	0								
1	Hallway	35	wall plaster	S	ND			SF	F	N	0								
1	Hallway	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Hallway	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Hallway	81	6"x12" pegboard CT	M	ND		1050	SF	F	N	0								
1	Hallway	81.5	ceiling tile adhesive (sample 81)	M	ND		1050	SF	N	N	0								
1	Room 101	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101	35	wall plaster	S	ND			SF	F	N	0								
1	Room 101	80	12"x12" pegboard CT	M	ND		2700	SF	F	N	0								
1	Room 101	80.5	ceiling tile adhesive (sample 80)	M	ND		2700	SF	N	N	0								
1	Room 101	84	2'x2' pinhole fissured CT	M	ND		1500	SF	F	N	0								
1	Room 110	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 110	35	wall plaster	S	ND			SF	F	N	0								
1	Room 111	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 111	35	wall plaster	S	ND			SF	F	N	0								

1	Room 120	11	4"-8" white fibrous PI	T		Pos	8	LF	F	N	2			10%	25%					
1	Room 120	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 120	35	wall plaster	S	ND			SF	F	N	0									
1	Room 120	36	red brick mortar	M	ND			SF	F	N	0									
1	Room 120	40	baseboard adhesive	M	ND			LF	N	N	0									
1	Room 120	83	12"x12" computer board CT	M	ND		480	SF	F	N	0									
1	Room 120	83.5	ceiling tile adhesive (sample 83)	M	ND		480	SF	N	N	0									
1	Room 120		12"x12" black & white FT(installed 7/	M	ND			SF	N	N	0									
1	Room 120(hatches)		inaccessible																	
1	Room 121	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			20%						
1	Room 121	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 121	35	wall plaster	S	ND			SF	F	N	0									
1	Room 121	82	12"x12" fissured CT/WT	M	ND		120	SF	F	N	0									
1	Room 121	82.5	ceiling tile adhesive (sample 82)	M	ND		120	SF	N	N	0									
1	Room 123	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 123	35	wall plaster	S	ND			SF	F	N	0									
1	Room 123	40	baseboard adhesive	M	ND			LF	N	N	0									
1	Room 123	83	12"x12" computer board CT	M	ND		130	SF	F	N	0									
1	Room 123	83.5	ceiling tile adhesive (sample 83)	M	ND		130	SF	N	N	0									
1	Room 123(hatch)		NSMP		ND															
1	Room 123A	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 123A	35	wall plaster	S	ND			SF	F	N	0									
1	Room 123A	40	baseboard adhesive	M	ND			LF	N	N	0									
1	Room 123A	83	12"x12" computer board CT	M	ND		144	SF	F	N	0									
1	Room 123A	83.5	ceiling tile adhesive (sample 83)	M	ND		144	SF	N	N	0									
1	Room 125	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 125	35	wall plaster	S	ND			SF	F	N	0									
1	Room 125	40	baseboard adhesive	M	ND			LF	N	N	0									
1	Room 125	83	12"x12" computer board CT	M	ND		560	SF	F	N	0									
1	Room 125	83.5	ceiling tile adhesive (sample 83)	M	ND		560	SF	N	N	0									

1	Room 125A	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 125A	35	wall plaster	S	ND			SF	F	N	0										
1	Room 125A	40	baseboard adhesive	M	ND			LF	N	N	0										
1	Room 125A	83	12"x12" computer board CT	M	ND		144	SF	F	N	0										
1	Room 125A	83.5	ceiling tile adhesive (sample 83)	M	ND		144	SF	N	N	0										
1	Room 127	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 127	35	wall plaster	S	ND			SF	F	N	0										
1	Room 127	40	baseboard adhesive	M	ND			LF	N	N	0										
1	Room 127	83	12"x12" computer board CT	M	ND		144	SF	F	N	0										
1	Room 127	83.5	ceiling tile adhesive (sample 83)	M	ND		144	SF	N	N	0										
1	Room 129	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 129	35	wall plaster	S	ND			SF	F	N	0										
1	Room 129A	1	<4" white fibrous PI	T		Pos	8	LF	F	H	4									20%	
1	Room 129A	11	4"-8" white fibrous PI	T		Pos	8	LF	F	H	4										10% 25%
1	Room 129A	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 129A	35	wall plaster	S	ND			SF	F	N	0										
1	Room 131	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 131	35	wall plaster	S	ND			SF	F	N	0										
1	Room 131	37	clay tile mortar	M	ND			SF	F	N	0										
1	Room 131	103	brown & cream linoleum	M	ND		75	SF	N	N	0										
1	Room 131A	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 131A	35	wall plaster	S	ND			SF	F	N	0										
1	Room 131A	39	sheetrock & taping compound	M	ND			SF	F	N	0										
1	Room 131A	40	baseboard adhesive	M	ND			LF	N	N	0										
1	Room 131A	85	2'x2' pinhole mini-fissure CT	M	ND		64	SF	F	N	0										
1	Room 131A	103	brown & cream linoleum	M	ND		75	SF	N	N	0										
1	Room 133	34	ceiling plaster	S	ND			SF	F	N	0										
1	Room 133	35	wall plaster	S	ND			SF	F	N	0										
1	Room 133	40	baseboard adhesive	M	ND			LF	N	N	0										
1	Room 133	41	9"x9" light brown w/brown & white F	M		Pos	180	SF	N	N	1										10%

1	Room 133	41.5	floor tile adhesive (sample 41)	M		Pos	180	SF	N	N	1				10%				
1	Room 133	82	12"x12" fissured CT/WT	M	ND		30	SF	F	N	0								
1	Room 133	82.5	ceiling tile adhesive (sample 82)	M	ND		30	SF	N	N	0								
1	Room 133-1	35	wall plaster	S	ND			SF	F	N	0								
1	Room 133-1	36	red brick mortar	M	ND			SF	F	N	0								
1	Room 133-1	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 133-1	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Room 133-1	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 133-1	85	2'x2' pinhole mini-fissure CT	M	ND		264	SF	F	N	0								
1	Room 133-1	11	4"-8" white fibrous PI	T		Pos	12	LF	F	N	2			10%	25%				
1	Room 133-1	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 133-141 Hall(ha		felt debris	T		Pos	3	SF	F	H	4								
1	Room 135	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 135	35	wall plaster	S	ND			SF	F	N	0								
1	Room 135	82	12"x12" fissured CT/WT	M	ND		20	SF	F	N	0								
1	Room 135	82.5	ceiling tile adhesive (sample 82)	M	ND		20	SF	N	N	0								
1	Room 135	103	brown & cream linoleum	M	ND		300	SF	N	N	0								
1	Room 137	1	<4" white fibrous PI	T		Pos	22	LF	F	N	2			20%					
1	Room 137	2	<4" PFI on white fibrous	T		Pos	5	EA	F	N	2				25%				
1	Room 137	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 137	35	wall plaster	S	ND			SF	F	N	0								
1	Room 137	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 137	41	9"x9" light brown w/brown & white F	M		Pos	216	SF	N	N	1				10%				
1	Room 137	41.5	floor tile adhesive (sample 41)	M		Pos	216	SF	N	N	1				10%				
1	Room 137	82	12"x12" fissured CT/WT	M	ND		36	SF	F	N	0								
1	Room 137	82.5	ceiling tile adhesive (sample 82)	M	ND		36	SF	N	N	0								
1	Room 137	83	12"x12" computer board CT	M	ND		216	SF	F	N	0								
1	Room 137	83.5	ceiling tile adhesive (sample 83)	M	ND		216	SF	N	N	0								
1	Room 139	1	<4" white fibrous PI	T		Pos	14	LF	F	N	2			20%					
1	Room 139	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2				25%				
1	Room 139	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 139	35	wall plaster	S	ND			SF	F	N	0								

1	Room 139	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 139	41	9"x9" light brown w/brown & white F	M		Pos	216	SF	N	N	1								10%
1	Room 139	41.5	floor tile adhesive (sample 41)	M		Pos	216	SF	N	N	1								10%
1	Room 139	82	12"x12" fissured CT/WT	M	ND		36	SF	F	N	0								
1	Room 139	82.5	ceiling tile adhesive (sample 82)	M	ND		36	SF	N	N	0								
1	Room 139	83	12"x12" computer board CT	M	ND		216	SF	F	N	0								
1	Room 139	83.5	ceiling tile adhesive (sample 83)	M	ND		216	SF	N	N	0								
1	Room 141	1	<4" white fibrous PI	T		Pos	3	LF	F	N	2								20%
1	Room 141	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2								25%
1	Room 141	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 141	35	wall plaster	S	ND			SF	F	N	0								
1	Room 141	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 141	41	9"x9" light brown w/brown & white F	M		Pos	216	SF	N	N	1								10%
1	Room 141	41.5	floor tile adhesive (sample 41)	M		Pos	216	SF	N	N	1								10%
1	Room 141	82	12"x12" fissured CT/WT	M	ND		36	SF	F	N	0								
1	Room 141	82.5	ceiling tile adhesive (sample 82)	M	ND		36	SF	N	N	0								
1	Room 141	83	12"x12" computer board CT	M	ND		216	SF	F	N	0								
1	Room 141	83.5	ceiling tile adhesive (sample 83)	M	ND		216	SF	N	N	0								
1	Room 165	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 165	35	wall plaster	S	ND			SF	F	N	0								
1	Room 165	82	12"x12" fissured CT/WT	M	ND		50	SF	F	N	0								
1	Room 165	82.5	ceiling tile adhesive (sample 82)	M	ND		50	SF	N	N	0								
1	Room 165	103	brown & cream linoleum	M	ND		270	SF	N	N	0								
1	Room 165-1	35	wall plaster	S	ND			SF	F	N	0								
1	Room 165-1	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Room 167	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 167	35	wall plaster	S	ND			SF	F	N	0								
1	Room 167	103	brown & cream linoleum	M	ND		180	SF	N	N	0								
1	Room 169	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 169	35	wall plaster	S	ND			SF	F	N	0								
1	Room 169	82	12"x12" fissured CT/WT	M	ND		42	SF	F	N	0								
1	Room 169	82.5	ceiling tile adhesive (sample 82)	M	ND		42	SF	N	N	0								

1	Room 169	103	brown & cream linoleum	M	ND		180	SF	N	N	0								
2	Room 202/2	9	<4" fiberglass PI	T	ND			LF	F	N	0								
2	Room 202/2	11	4"-8" white fibrous PI	T		Pos	30	LF	F	N	2		10%	25%					
2	Room 202/2	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 202/2	35	wall plaster	S	ND			SF	F	N	0								
2	Room 202/2	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 202/2	62	12"x12" beige w/peach & cream FT	M	ND		5500	SF	N	N	0								
2	Room 202/2	62.5	floor tile adhesive (sample 62)	M	ND		5500	SF	N	N	0								
2	Room 202/2	63	12"x12" blue w/white FT	M	ND		500	SF	N	N	0								
2	Room 202/2	63.5	floor tile adhesive (sample 63)	M	ND		500	SF	N	N	0								
2	Room 212	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 212	35	wall plaster	S	ND			SF	F	N	0								
2	Room 212	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 212	45	9"x9" emerald green w/white FT	M		Pos	200	SF	N	N	1		10%						
2	Room 212	45.5	floor tile adhesive (sample 45)	M		Pos	200	SF	N	N	1		5%						
2	Room 212	62	12"x12" beige w/peach & cream FT	M	ND		80	SF	N	N	0								
2	Room 212	62.5	floor tile adhesive (sample 62)	M	ND		80	SF	N	N	0								
2	Room 212	79	12"x12" pinhole crater CT	M		Pos	195	SF	F	N	2		5%						
2	Room 212	79.5	ceiling tile adhesive (sample 79)	M	ND		195	SF	N	N	0								
2	Room 220 o	11	4"-8" white fibrous PI	T		Pos	20	LF	F	N	2		10%	25%					
2	Room 220 o	12	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2		20%	5%					
2	Room 220 o	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220 o	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220 o	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 220 o	66	12"x12" off white w/olive FT	M	ND		2750	SF	N	N	0								
2	Room 220 o	66.5	floor tile adhesive (sample 66)	M		Pos	2750	SF	N	N	1		10%						
2	Room 220 o	79	12"x12" pinhole crater CT	M		Pos	2750	SF	F	N	2		5%						
2	Room 220 o	79.5	ceiling tile adhesive (sample 79)	M	ND			SF	N	N	0								
2	Room 220 o	11	4"-8" white fibrous PI	T		Pos	13	LF	F	N	2		10%	25%					
2	Room 220 o	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220 o	36	red brick mortar	M	ND			SF	F	N	0								
2	Room 220 o	39	sheetrock & taping compound	M	ND			SF	F	N	0								

2	Room 220A	11	4"-8" white fibrous PI	T		Pos	8	LF	F	N	2			10%	25%				
2	Room 220A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220A	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 220A	45	9"x9" emerald green w/white FT	M		Pos	56	SF	N	N	1				10%				
2	Room 220A	45.5	floor tile adhesive (sample 45)	M		Pos	56	SF	N	N	1				5%				
2	Room 220A	83	12"x12" computer board CT	M	ND		56	SF	F	N	0								
2	Room 220A	83.5	ceiling tile adhesive (sample 83)	M	ND		56	SF	N	N	0								
2	Room 237	11	4"-8" white fibrous PI	T		Pos	10	LF	F	N	2			10%	25%				
2	Room 237	12	4"-8" PFI on white fibrous	T		Pos	1	EA	F	N	2			20%	5%				
2	Room 237	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 237	35	wall plaster	S	ND			SF	F	N	0								
2	Room 237	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Room 237	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 237	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1				10%				
2	Room 237	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1				5%				
2	Room 237	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 237	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 237		inaccessible above ceiling																
2	Room 237-2	5	<4" felt with tar PI	T		Pos	42	LF	F	L	3			5%	10%				
2	Room 237-2	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	L	3			5%	10%				
2	Room 237-2	11	4"-8" white fibrous PI	T		Pos	83	LF	F	M	4			10%	25%				
2	Room 237-2	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 237-2	35	wall plaster	S	ND			SF	F	N	0								
2	Room 237-2	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Room 237-2	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 237-2	45	9"x9" emerald green w/white FT	M		Pos	250	SF	N	N	1				10%				
2	Room 237-2	45.5	floor tile adhesive (sample 45)	M		Pos	250	SF	N	N	1				5%				
2	Room 237-2	62	12"x12" beige w/peach & cream FT	M	ND		180	SF	N	N	0								
2	Room 237-2	62.5	floor tile adhesive (sample 62)	M	ND		180	SF	N	N	0								
2	Room 237-2	83.5	ceiling tile adhesive (sample 83)	M	ND		80	SF	N	N	0								
2	Room 237-2	90	2'x4' pinhole crater CT	M	ND		80	SF	F	N	0								
2	Room 239	11	4"-8" white fibrous PI	T		Pos	10	LF	F	N	2			10%	25%				
2	Room 239	12	4"-8" PFI on white fibrous	T		Pos	1	EA	F	N	2			20%	5%				

2	Room 239	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 239	35	wall plaster	S	ND			SF	F	N	0								
2	Room 239	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Room 239	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 239	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1							10%	
2	Room 239	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1							5%	
2	Room 239	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 239	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 241	9	<4" fiberglass PI	T	ND			LF	F	N	0								
2	Room 241	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 241	35	wall plaster	S	ND			SF	F	N	0								
2	Room 241	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 241	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1							10%	
2	Room 241	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1							5%	
2	Room 241	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 241	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 243	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 243	35	wall plaster	S	ND			SF	F	N	0								
2	Room 243	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 243	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1							10%	
2	Room 243	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1							5%	
2	Room 243	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 243	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 245	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 245	35	wall plaster	S	ND			SF	F	N	0								
2	Room 245	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 245	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1							10%	
2	Room 245	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1							5%	
2	Room 245	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 245	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 247	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 247	35	wall plaster	S	ND			SF	F	N	0								
2	Room 247	39	sheetrock & taping compound	M	ND			SF	F	N	0								

2	Room 247	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 247	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1				10%				
2	Room 247	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1				5%				
2	Room 247	83	12"x12" computer board CT	M	ND		150	SF	F	N	0								
2	Room 247	83.5	ceiling tile adhesive (sample 83)	M	ND		150	SF	N	N	0								
2	Room 248	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 248	35	wall plaster	S	ND			SF	F	N	0								
2	Room 248(h	5	<4" felt with tar PI	T		Pos	28	LF	F	N	2			5%	10%				
2	Room 248(h	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	M	4			5%	10%				
2	Room 248(h	36	red brick mortar	M	ND			SF	F	N	0								
2	Room 248(h	37	clay tile mortar	M	ND			SF	F	N	0								
2	Room 259	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 259	35	wall plaster	S	ND			SF	F	N	0								
2	Room 259	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 259	45	9"x9" emerald green w/white FT	M		Pos	154	SF	N	N	1				10%				
2	Room 259	45.5	floor tile adhesive (sample 45)	M		Pos	154	SF	N	N	1				5%				
2	Room 259	83	12"x12" computer board CT	M	ND		154	SF	F	N	0								
2	Room 259	83.5	ceiling tile adhesive (sample 83)	M	ND		154	SF	N	N	0								
2	Room 261/2	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 261/2	35	wall plaster	S	ND			SF	F	N	0								
2	Room 261/2	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 261/2	45	9"x9" emerald green w/white FT	M		Pos	264	SF	N	N	1				10%				
2	Room 261/2	45.5	floor tile adhesive (sample 45)	M		Pos	264	SF	N	N	1				5%				
2	Room 261/2	83	12"x12" computer board CT	M	ND		264	SF	F	N	0								
2	Room 261/2	83.5	ceiling tile adhesive (sample 83)	M	ND		264	SF	N	N	0								
2	Room 265	35	wall plaster	S	ND			SF	F	N	0								
2	Room 265	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 265	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 265	45	9"x9" emerald green w/white FT	M		Pos	160	SF	N	N	1				10%				
2	Room 265	45.5	floor tile adhesive (sample 45)	M		Pos	160	SF	N	N	1				5%				
2	Room 265	88	2'x2' nailhole fissure CT	M	ND		160	SF	F	N	0								

2	Room 267	35	wall plaster	S	ND			SF	F	N	0								
2	Room 267	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 267	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 267	45	9"x9" emerald green w/white FT	M		Pos	160	SF	N	N	1								10%
2	Room 267	45.5	floor tile adhesive (sample 45)	M		Pos	160	SF	N	N	1								5%
2	Room 267	88	2'x2' nailhole fissure CT	M	ND		160	SF	F	N	0								
2	Room 269	35	wall plaster	S	ND			SF	F	N	0								
2	Room 269	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 269	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 269	88	2'x2' nailhole fissure CT	M	ND		180	SF	F	N	0								
2	Room 271	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 271	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Room 271	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 271	88	2'x2' nailhole fissure CT	M	ND		180	SF	F	N	0								
2	Room 273	35	wall plaster	S	ND			SF	F	N	0								
2	Room 273	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 273	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Room 273	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 273	90	2'x4' pinhole crater CT	M	ND		160	SF	F	N	0								
2	Room 281	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 281	35	wall plaster	S	ND			SF	F	N	0								
2	Room 281	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 283	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 283	35	wall plaster	S	ND			SF	F	N	0								
2	Room 283	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 285	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 285	35	wall plaster	S	ND			SF	F	N	0								
2	Room 285	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Rooms 252-	1	<4" white fibrous PI	T		Pos	19	LF	F	M	4								20%
2	Rooms 252-	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2								25%

2	Rooms 252-	11	4"-8" white fibrous PI	T		Pos	14	LF	F	N	2			10%	25%				
2	Rooms 252-	12	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2			20%	5%				
2	Rooms 252-	34	ceiling plaster	S	ND			SF	F	N	0								
2	Rooms 252-	35	wall plaster	S	ND			SF	F	N	0								
2	Rooms 252-	36	red brick mortar	M	ND			SF	F	N	0								
2	Rooms 252-	37	clay tile mortar	M	ND			SF	F	N	0								
2	Rooms 252-	38	concrete block mortar	M	ND			SF	F	N	0								
2	Rooms 252-	39	sheetrock & taping compound	M	ND			SF	F	N	0								
2	Rooms 252-	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Rooms 252-	83	12"x12" computer board CT	M	ND		680	SF	F	N	0								
2	Rooms 252-	83.5	ceiling tile adhesive (sample 83)	M	ND		680	SF	N	N	0								
2	Rooms 252-	90	2'x4' pinhole crater CT	M	ND		1200	SF	F	N	0								
2	Rooms 252-	91	2'x4' pinhole worm CT	M	ND		200	SF	F	N	0								
3	Hallway(hatch)	35	wall plaster	S	ND			SF	F	N	0								
3	Hallway(hatch)	37	clay tile mortar	M	ND			SF	F	N	0								
3	Hallway(hatch)	80	12"x12" pegboard CT	M	ND		140	SF	F	N	0								
3	Hallway(hatch)	80.5	ceiling tile adhesive (sample 80)	M	ND		140	SF	N	N	0								
3	Hallway	34	ceiling plaster	S	ND			SF	F	N	0								
3	Hallway	35	wall plaster	S	ND			SF	F	N	0								
3	Hallway	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Hallway	42	9"x9" light grey w/black & white FT	M		Pos	12	SF	N	N	1				5%				
3	Hallway	42.5	floor tile adhesive (sample 42)	M		Pos	12	SF	N	N	1				10%				
3	Hallway	43	9"x9" grey w/black & white FT	M		Pos	48	SF	N	N	1				10%				
3	Hallway	43.5	floor tile adhesive (sample 43)	M		Pos	48	SF	N	N	1				10%				
3	Room 301	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 301	35	wall plaster	S	ND			SF	F	N	0								
3	Room 301	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 301	45	9"x9" emerald green w/white FT	M		Pos	120	SF	N	N	1				10%				
3	Room 301	45.5	floor tile adhesive (sample 45)	M		Pos	120	SF	N	N	1				5%				
3	Room 301(hatch)		inaccessible																
3	Room 310	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 310	35	wall plaster	S	ND			SF	F	N	0								

3	Room 310	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 310	45	9"x9" emerald green w/white FT	M		Pos	150	SF	N	N	1					10%			
3	Room 310	45.5	floor tile adhesive (sample 45)	M		Pos	150	SF	N	N	1					5%			
3	Room 325	11	4"-8" white fibrous PI	T		Pos	20	LF	F	L	3				10%	25%			
3	Room 325	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 325	35	wall plaster	S	ND			SF	F	N	0								
3	Room 327	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 327	35	wall plaster	S	ND			SF	F	N	0								
3	Room 329	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 329	35	wall plaster	S	ND			SF	F	N	0								
3	Room 333	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 333	35	wall plaster	S	ND			SF	F	N	0								
3	Room 333	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 333	43	9"x9" grey w/black & white FT	M		Pos	196	SF	N	N	1					10%			
3	Room 333	43.5	floor tile adhesive (sample 43)	M		Pos	196	SF	N	N	1					10%			
3	Room 333	80	12"x12" pegboard CT	M	ND		196	SF	F	N	0								
3	Room 333	80.5	ceiling tile adhesive (sample 80)	M	ND		196	SF	N	N	0								
3	Room 333	86	2'x2' pinhole worm CT	M	ND		196	SF	F	N	0								
3	Room 335	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 335	35	wall plaster	S	ND			SF	F	N	0								
3	Room 335	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 335	43	9"x9" grey w/black & white FT	M		Pos	196	SF	N	N	1					10%			
3	Room 335	43.5	floor tile adhesive (sample 43)	M		Pos	196	SF	N	N	1					10%			
3	Room 335	80	12"x12" pegboard CT	M	ND		196	SF	F	N	0								
3	Room 335	80.5	ceiling tile adhesive (sample 80)	M	ND		196	SF	N	N	0								
3	Room 335	86	2'x2' pinhole worm CT	M	ND		196	SF	F	N	0								
3	Room 339	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 339	35	wall plaster	S	ND			SF	F	N	0								
3	Room 339	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 339	43	9"x9" grey w/black & white FT	M		Pos	350	SF	N	N	1					10%			
3	Room 339	43.5	floor tile adhesive (sample 43)	M		Pos	350	SF	N	N	1					10%			

3	Room 339	80	12"x12" pegboard CT	M	ND		350	SF	F	N	0								
3	Room 339	80.5	ceiling tile adhesive (sample 80)	M	ND		350	SF	N	N	0								
3	Room 339	86	2'x2' pinhole worm CT	M	ND		350	SF	F	N	0								
3	Room 340	1	<4" white fibrous PI	T		Pos	27	LF	F	N	2		20%						
3	Room 340	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2			25%					
3	Room 340	11	4"-8" white fibrous PI	T		Pos	34	LF	F	N	2		10%	25%					
3	Room 340	12	4"-8" PFI on white fibrous	T		Pos	10	EA	F	N	2		20%	5%					
3	Room 340	30	white fibrous duct insulation	T		Pos	220	SF	F	L	3			20%					
3	Room 340	37	clay tile mortar	M	ND			SF	F	N	0								
3	Room 340	95	canvass vibration joint	M	ND		2	EA	N	N	0								
3	Room 345	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 345	35	wall plaster	S	ND			SF	F	N	0								
3	Room 345	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 345	43	9"x9" grey w/black & white FT	M		Pos	840	SF	N	N	1			10%					
3	Room 345	43.5	floor tile adhesive (sample 43)	M		Pos	840	SF	N	N	1			10%					
3	Room 345	80	12"x12" pegboard CT	M	ND		840	SF	F	N	0								
3	Room 345	80.5	ceiling tile adhesive (sample 80)	M	ND		840	SF	N	N	0								
3	Room 345	86	2'x2' pinhole worm CT	M	ND		840	SF	F	N	0								
3	Room 349	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 349	35	wall plaster	S	ND			SF	F	N	0								
3	Room 349	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 349	43	9"x9" grey w/black & white FT	M		Pos	220	SF	N	N	1			10%					
3	Room 349	43.5	floor tile adhesive (sample 43)	M		Pos	220	SF	N	N	1			10%					
3	Room 349	80	12"x12" pegboard CT	M	ND		220	SF	F	N	0								
3	Room 349	80.5	ceiling tile adhesive (sample 80)	M	ND		220	SF	N	N	0								
3	Room 349	86	2'x2' pinhole worm CT	M	ND		220	SF	F	N	0								
3	Room 351	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 351	35	wall plaster	S	ND			SF	F	N	0								
3	Room 351(h	38	concrete block mortar	M	ND			SF	F	N	0								
3	Room 352	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 352	35	wall plaster	S	ND			SF	F	N	0								

