

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
SB	Room S-30/3	1	<4" white fibrous PI	T		Pos	213	LF	F	N	2			10%						
SB	Room S-30/3	2	<4" PFI on white fibrous	T		Pos	130	EA	F	N	2				15%					
SB	Room S-30/3	3	<4" aircell PI (Assumed)	T		Pos	840	LF	F	N	2									
SB	Room S-30/3	4	<4" fibrous PFI on aircell (Assumed)	T		Pos	389	EA	F	N	2									
SB	Room S-30/3	5	<4" felt with tar PI	T		Pos	85	LF	F	N	2				19%					
SB	Room S-30/3	6	<4" fibrous PFI on felt	T		Pos	45	EA	F	N	2				18%					
SB	Room S-30/3	9	<4" FG PI	T	ND			LF	F	N	0									
SB	Room S-30/3	10	<4" fibrous PFI on FG	T		Pos	5	EA	F	N	2				10%					
SB	Room S-30/3	11	4"-8" white fibrous PI	T		Pos	130	LF	F	N	2			20%						
SB	Room S-30/3	12	4"-8" PFI on white fibrous	T		Pos	34	EA	F	N	2				15%					
SB	Room S-30/3	13	4"-8" aircell PI (Assumed)	T		Pos	920	LF	F	N	2				15%					
SB	Room S-30/3	14	4"-8" fibrous PFI on aircell (Assumed)	T		Pos	251	EA	F	N	2									
SB	Room S-30/3	15	4"-8" felt with tar PI	T		Pos	65	LF	F	N	2				15%					
SB	Room S-30/3	16	4"-8" fibrous PFI on felt	T		Pos	25	EA	F	N	2				15%					
SB	Room S-30/3	19	4"-8" FG PI	T	ND			LF	F	N	0									
SB	Room S-30/3	20	4"-8" fibrous PFI on FG	T	ND		8	EA	F	N	0									
SB	Room S-30/3	21	9"-14" white fibrous PI	T	ND		50	LF	F	N	0									
SB	Room S-30/3	22	9"-14" PFI on white fibrous	T	ND		45	EA	F	N	0									
SB	Room S-30/3	23	9"-14" FG PI	T	ND			LF	F	N	0									
SB	Room S-30/3	24	9"-14" fibrous PFI on FG	T	ND		1	EA	F	N	0									
SB	Room S-30/3	32	white fibrous tank	T		Pos	150	SF	F	N	2				15%					
SB	Room S-30/3	130	canvass vibration joint	M			10	EA	N	N	0									
SB	Room S-30/3	139	debris	M		Pos	60	SF	N	H	4				25%					
B	Hall 4-20	5	<4" felt with tar PI	T		Pos	44	LF	F	N	2				19%					
B	Hall 4-20	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2				18%					
B	Hall 4-20	9	<4" FG PI	T	ND			LF	F	N	0									
B	Hall 4-20	19	4"-8" FG PI	T	ND			LF	F	N	0									
B	Hall 4-20	36	red brick mortar	M	ND			SF	F	N	0									
B	Hall 4-20	37	clay tile mortar	M	ND			SF	F	N	0									
B	Hall 4-20	38	concrete block mortar	M	ND			SF	F	N	0									
B	Hall 4-20	39	sheetrock & taping compound	M	ND			SF	F	N	0									
B	Hall 4-20	40	baseboard adhesive	M	ND			LF	N	N	0									
B	Hall 4-20	142	textured paint	S	ND			SF	N	N	0				5%					
B	Hall 13-30	34	ceiling plaster	S	ND			SF	F	N	0									

B	Hall 13-30	37	clay tile mortar	M	ND			SF	F	N	0								
B	Hall 13-30	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Hall 13-30	142	textured paint	S	ND			SF	N	N	0								5%
B	NW. Stair Ha	1	<4" white fibrous PI	T		Pos	180	LF	F	N	2								10%
B	NW. Stair Ha	2	<4" PFI on white fibrous	T		Pos	11	EA	F	N	2								15%
B	NW. Stair Ha	9	<4" FG PI	T	ND			LF	F	N	0								
B	NW. Stair Ha	36	red brick mortar	M	ND			SF	F	N	0								
B	Room 1	199	Inaccessible																
B	Room 1A	199	Inaccessible																
B	Room 2	3	<4" aircell PI (Assumed)	T		Pos	7	LF	F	H	4								
B	Room 2	4	<4" fibrous PFI on aircell (Assumed)	T		Pos	4	EA	F	H	4								
B	Room 2	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 2	10	<4" fibrous PFI on FG	T		Pos	19	EA	F	N	2								10%
B	Room 2	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 2	20	4"-8" fibrous PFI on FG	T	ND		16	EA	F	N	0								
B	Room 2	203	carpet adhesive	M		Pos	432	SF	N	N	1								5%
B	Room 2A	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 2A	20	4"-8" fibrous PFI on FG	T	ND		7	EA	F	N	0								
B	Room 2A	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 2B	5	<4" felt with tar PI	T		Pos	15	LF	F	N	2								19%
B	Room 2B	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2								18%
B	Room 2B	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 2B	20	4"-8" fibrous PFI on FG	T	ND		3	EA	F	N	0								
B	Room 2B	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 3	5	<4" felt with tar PI	T		Pos	50	LF	F	N	2								19%
B	Room 3	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2								18%
B	Room 3	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 3	10	<4" fibrous PFI on FG	T		Pos	12	EA	F	N	2								10%
B	Room 3	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 3	20	4"-8" fibrous PFI on FG	T	ND		3	EA	F	N	0								

B	Room 3	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 3	35	wall plaster	S	ND			SF	F	N	0								
B	Room 3A	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 3B	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 4	5	<4" felt with tar PI	T		Pos	45	LF	F	N	2								19%
B	Room 4	6	<4" fibrous PFI on felt	T		Pos	17	EA	F	N	2								18%
B	Room 4	13	4"-8" aircell PI (Assumed)	T		Pos	10	LF	F	N	2								15%
B	Room 4	14	4"-8" fibrous PFI on aircell (Assumed)	T		Pos	2	EA	F	N	2								
B	Room 4	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 4	20	4"-8" fibrous PFI on FG	T	ND		4	EA	F	N	0								
B	Room 5A/14	25	black foam PI	T	ND			LF	F	N	0								
B	Room 5A/14	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 5A/14	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 5A/14	142	textured paint	S	ND			SF	N	N	0								5%
B	Room 5B	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 5B	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 5B	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 5C	5	<4" felt with tar PI	T		Pos	35	LF	F	N	2								19%
B	Room 5C	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2								18%
B	Room 5C	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 5C	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room 5D	5	<4" felt with tar PI	T		Pos	16	LF	F	N	2								19%
B	Room 5D	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2								18%
B	Room 5D	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 5D	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room 10	36	red brick mortar	M	ND			SF	F	N	0								
B	Room 10	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 10	100	12"x12" CT white pencilhole	M	ND		3225	SF	F	N	0								
B	Room 10	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	3225	SF	N	N	1								7%

B	Room 10A	1	<4" white fibrous PI	T		Pos	90?	LF	F	N	2			10%					
B	Room 10A	2	<4" PFI on white fibrous	T		Pos	4?	EA	F	N	2				15%				
B	Room 10A	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 10A	199	Inaccessible																
B	Room 13	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 13	10	<4" fibrous PFI on FG	T		Pos	2	EA	F	N	2				10%				
B	Room 13	35	wall plaster	S	ND			SF	F	N	0								
B	Room 13	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 13	139	debris	M		Pos	5	SF	N	H	4				25%				
B	Room 14		See Room 5A/14/20/20B																
B	Room 20		See Room 5A/14/20/20B																
B	Room 20A	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 20A	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 20B		See Room 5A/14/20/20B																
B	Room 20C	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 20C	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 20D	5	<4" felt with tar PI	T		Pos	275	LF	F	N	2				19%				
B	Room 20D	6	<4" fibrous PFI on felt	T		Pos	52	EA	F	N	2				18%				
B	Room 20D	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 20D	10	<4" fibrous PFI on FG	T		Pos	53	EA	F	N	2				10%				
B	Room 20D	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 20D	20	4"-8" fibrous PFI on FG	T	ND		82	EA	F	N	0								
B	Room 20D	38	concrete block mortar	M	ND			SF	F	N	0								
B	Room 20D	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 20D	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room 20D	203	carpet adhesive	M		Pos	1560	SF	N	N	1				5%				
B	Room 20E	5	<4" felt with tar PI	T		Pos	80	LF	F	N	2				19%				
B	Room 20E	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2				18%				

B	Room 20E	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 20E	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room 25	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 30	9	<4" FG PI	T	ND			LF	F	N	0								
B	Room 30	19	4"-8" FG PI	T	ND			LF	F	N	0								
B	Room 30	25	black foam PI	T	ND			LF	F	N	0								
B	Room 30	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 30	35	wall plaster	S	ND			SF	F	N	0								
B	Room 30	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 30	39	sheetrock & taping compound	M	ND			SF	F	N	0								
B	Room 30	40	baseboard adhesive	M	ND			LF	N	N	0								
B	Room 30A V	1	<4" white fibrous PI	T		Pos	40	LF	F	N	2			10%					
B	Room 30A V	2	<4" PFI on white fibrous	T		Pos	7	EA	F	N	2				15%				
B	Room 30A V	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 30A V	139	debris	M		Pos	40	SF	N	H	4				25%				
B	Room 30A	5	<4" felt with tar PI	T		Pos	1	LF	F	N	2				19%				
B	Room 30A	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	N	2				18%				
B	Room 30A	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 30A	37	clay tile mortar	M	ND			SF	F	N	0								
	Lobby & NE.	9	<4" FG PI	T	ND			LF	F	N	0								
	Lobby & NE.	10	<4" fibrous PFI on FG	T		Pos	20	EA	F	N	2				10%				
	Lobby & NE.	34	ceiling plaster	S	ND			SF	F	N	0								
	Lobby & NE.	36	red brick mortar	M	ND			SF	F	N	0								
	Lobby & NE.	38	concrete block mortar	M	ND			SF	F	N	0								
	Lobby & NE.	40	baseboard adhesive	M	ND			LF	N	N	0								
	Lobby & NE.	71	12"x12" FT beige w/white streaks	M	ND		1100	SF	N	N	0								
	Lobby & NE.	71.5	floor tile adhesive (sample 71)	M		Pos	1100	SF	N	N	1				10%				
	Lobby & SE.	9	<4" FG PI	T	ND			LF	F	N	0								
	Lobby & SE.	10	<4" fibrous PFI on FG	T		Pos	38	EA	F	N	2				10%				
	Lobby & SE.	34	ceiling plaster	S	ND			SF	F	N	0								
	Lobby & SE.	36	red brick mortar	M	ND			SF	F	N	0								

	Lobby & SE.	38	concrete block mortar	M	ND			SF	F	N	0								
	Lobby & SE.	43	9"x9" FT grey & white	M	ND		692	SF	N	N	0								
	Lobby & SE.	43.5	floor tile adhesive (sample 43)	M	ND		692	SF	N	N	0								
	Lobby & SE.	91	grey white stair tread	M	ND		320	SF	N	N	0								
	Lobby & SE.	91.5	floor tile adhesive (sample 91)	M	ND		320	SF	N	N	0								
	NW. Stair	3	<4" aircell PI (Assumed)	T		Pos	10	LF	F	N	2								
	NW. Stair	4	<4" fibrous PFI on aircell (Assumed)	T		Pos	2	EA	F	N	2								
	NW. Stair	36	red brick mortar	M	ND			SF	F	N	0								
	NW. Stair	130	canvass vibration joint	M			1	EA	N	N	0								
	SW. Stair	9	<4" FG PI	T	ND			LF	F	N	0								
	SW. Stair	10	<4" fibrous PFI on FG	T		Pos	12	EA	F	N	2							10%	
	SW. Stair	36	red brick mortar	M	ND			SF	F	N	0								
	SW. Stair	38	concrete block mortar	M	ND			SF	F	N	0								
1	Hall 106-113	9	<4" FG PI	T	ND			LF	F	N	0								
1	Hall 106-113	34	ceiling plaster	S	ND			SF	F	N	0								
1	Hall 106-113	35	wall plaster	S	ND			SF	F	N	0								
1	Hall 106-113	41	9"x9" FT brown	M		Pos	265	SF	N	N	1								5%
1	Hall 106-113	41.5	floor tile adhesive (sample 41)	M	ND		265	SF	N	N	0								
1	Hall 106-113	42	9"x9" FT red	M		Pos	265	SF	N	N	1								5%
1	Hall 106-113	42.5	floor tile adhesive (sample 42)	M	ND		265	SF	N	N	0								
1	Hall 106-113	90	black border tile	M		Pos	90	SF	N	N	1								10%
1	Hall 106-113	90.5	floor tile adhesive (sample 90)	M		Pos	90	SF	N	N	1								5%
1	Lobby & Hall	9	<4" FG PI	T	ND			LF	F	N	0								
1	Lobby & Hall	34	ceiling plaster	S	ND			SF	F	N	0								
1	Lobby & Hall	35	wall plaster	S	ND			SF	F	N	0								
1	Lobby & Hall	36	red brick mortar	M	ND			SF	F	N	0								
1	Lobby & Hall	136	4"x4" ceramic FT	M	ND			SF	N	N	0								
1	Pool Hall No	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2								19%
1	Pool Hall No	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2								18%
1	Pool Hall No	36	red brick mortar	M	ND			SF	F	N	0								
1	Pool Hall No	37	clay tile mortar	M	ND			SF	F	N	0								

1	Room 100A/	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 100A/	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 100A/	100	12"x12" CT white pencilhole	M	ND		160	SF	F	N	0								
1	Room 100A/	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	160	SF	N	N	1								7%
1	Room 100A/	111	2'x2' CT chicken scratch	M	ND		256	SF	F	N	0								
1	Room 100A/	203	carpet adhesive	M		Pos	256	SF	N	N	1								5%
1	Room 101 V	199	Inaccessible																
1	Room 101	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 101	25	black foam PI	T	ND			LF	F	N	0								
1	Room 101	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101	35	wall plaster	S	ND			SF	F	N	0								
1	Room 101	202	FT under carpet (Assumed)	M		Pos	144	SF	N	N	1								
1	Room 101	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	144	SF	N	N	1								
1	Room 101	203	carpet adhesive	M		Pos	144	SF	N	N	1								5%
1	Room 102	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 102	25	black foam PI	T	ND			LF	F	N	0								
1	Room 102	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 102	35	wall plaster	S	ND			SF	F	N	0								
1	Room 103	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 103	35	wall plaster	S	ND			SF	F	N	0								
1	Room 103	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 103	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 104	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 104	10	<4" fibrous PFI on FG	T		Pos	15	EA	F	N	2								10%
1	Room 104	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 104	35	wall plaster	S	ND			SF	F	N	0								
1	Room 104	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 104	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 105	36	red brick mortar	M	ND			SF	F	N	0								
1	Room 106A	9	<4" FG PI	T	ND			LF	F	N	0								

1	Room 106A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 106A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 106A	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 106A	100	12"x12" CT white pencilhole	M	ND		140	SF	F	N	0								
1	Room 106A	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	140	SF	N	N	1							7%	
1	Room 106A	111	2'x2' CT chicken scratch	M	ND			SF	F	N	0								
1	Room 106A	202	FT under carpet (Assumed)	M		Pos	140	SF	N	N	1								
1	Room 106A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	140	SF	N	N	1								
1	Room 106A	203	carpet adhesive	M		Pos	140	SF	N	N	1								5%
1	Room 107	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 107	25	black foam PI	T	ND			LF	F	N	0								
1	Room 107	31	FG duct insulation	T	ND			SF	F	N	0								
1	Room 107	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 107	35	wall plaster	S	ND			SF	F	N	0								
1	Room 107	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 107	100	12"x12" CT white pencilhole	M	ND		171	SF	F	N	0								
1	Room 107	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	171	SF	N	N	1								7%
1	Room 107	111	2'x2' CT chicken scratch	M	ND			SF	F	N	0								
1	Room 107	202	FT under carpet (Assumed)	M		Pos	171	SF	N	N	1								
1	Room 107	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	171	SF	N	N	1								
1	Room 107	203	carpet adhesive	M		Pos	171	SF	N	N	1								5%
1	Room 107A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 107A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 107A	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 107A	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 107A	100	12"x12" CT white pencilhole	M	ND		126	SF	F	N	0								
1	Room 107A	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	126	SF	N	N	1								7%
1	Room 107A	111	2'x2' CT chicken scratch	M	ND		126	SF	F	N	0								
1	Room 107A	202	FT under carpet (Assumed)	M		Pos	126	SF	N	N	1								
1	Room 107A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	126	SF	N	N	1								
1	Room 107A	203	carpet adhesive	M		Pos	126	SF	N	N	1								5%
1	Room 108	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 108	35	wall plaster	S	ND			SF	F	N	0								
1	Room 108	40	baseboard adhesive	M	ND			LF	N	N	0								

1	Room 109A	90	black border tile	M		Pos	6	SF	N	N	1					10%				
1	Room 109A	90.5	floor tile adhesive (sample 90)	M		Pos	6	SF	N	N	1					5%				
1	Room 110	9	<4" FG PI	T	ND			LF	F	N	0									
1	Room 110	25	black foam PI	T	ND			LF	F	N	0									
1	Room 110	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 110	35	wall plaster	S	ND			SF	F	N	0									
1	Room 110	100	12"x12" CT white pencilhole	M	ND		333	SF	F	N	0									
1	Room 110	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	333	SF	N	N	1					7%				
1	Room 110	202	FT under carpet (Assumed)	M		Pos	333	SF	N	N	1									
1	Room 110	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	333	SF	N	N	1									
1	Room 110	203	carpet adhesive	M		Pos	333	SF	N	N	1					5%				
1	Room 110A	9	<4" FG PI	T	ND			LF	F	N	0									
1	Room 110A	25	black foam PI	T	ND			LF	F	N	0									
1	Room 110A	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 110A	35	wall plaster	S	ND			SF	F	N	0									
1	Room 110A	100	12"x12" CT white pencilhole	M	ND		270	SF	F	N	0									
1	Room 110A	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	270	SF	N	N	1					7%				
1	Room 110A	202	FT under carpet (Assumed)	M		Pos	270	SF	N	N	1									
1	Room 110A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	270	SF	N	N	1									
1	Room 110A	203	carpet adhesive	M		Pos	270	SF	N	N	1					5%				
1	Room 110B	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 110B	35	wall plaster	S	ND			SF	F	N	0									
1	Room 110B	41	9"x9" FT brown	M		Pos	40	SF	N	N	1					5%				
1	Room 110B	41.5	floor tile adhesive (sample 41)	M	ND		40	SF	N	N	0									
1	Room 110B	42	9"x9" FT red	M		Pos	40	SF	N	N	1					5%				
1	Room 110B	42.5	floor tile adhesive (sample 42)	M	ND		40	SF	N	N	0									
1	Room 110B	90	black border tile	M		Pos	20	SF	N	N	1					10%				
1	Room 110B	90.5	floor tile adhesive (sample 90)	M		Pos	20	SF	N	N	1					5%				
1	Room 110C	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 110C	35	wall plaster	S	ND			SF	F	N	0									
1	Room 110C	90	black border tile	M		Pos	30	SF	N	N	1					10%				
1	Room 110C	90.5	floor tile adhesive (sample 90)	M		Pos	30	SF	N	N	1					5%				

1	Room 111	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 111	25	black foam PI	T	ND			LF	F	N	0								
1	Room 111	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 111	35	wall plaster	S	ND			SF	F	N	0								
1	Room 111	100	12"x12" CT white pencilhole	M	ND		225	SF	F	N	0								
1	Room 111	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	225	SF	N	N	1							7%	
1	Room 111	202	FT under carpet (Assumed)	M		Pos	225	SF	N	N	1								
1	Room 111	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	225	SF	N	N	1								
1	Room 111	203	carpet adhesive	M		Pos	225	SF	N	N	1								5%
1	Room 111A	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 111A	25	black foam PI	T	ND			LF	F	N	0								
1	Room 111A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 111A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 111A	100	12"x12" CT white pencilhole	M	ND		180	SF	F	N	0								
1	Room 111A	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	180	SF	N	N	1								7%
1	Room 111A	202	FT under carpet (Assumed)	M		Pos	180	SF	N	N	1								
1	Room 111A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	180	SF	N	N	1								
1	Room 111A	203	carpet adhesive	M		Pos	180	SF	N	N	1								5%
1	Room 113	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 113	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 113	35	wall plaster	S	ND			SF	F	N	0								
1	Room 113	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 114	9	<4" FG PI	T	ND			LF	F	N	0								
1	Room 114	25	black foam PI	T	ND			LF	F	N	0								
1	Room 114	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 114	35	wall plaster	S	ND			SF	F	N	0								
1	Room 114	38	concrete block mortar	M	ND			SF	F	N	0								
1	Room 114	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Room 114	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 114	110	2'x2' CT white pinhole fissure	M	ND		280	SF	F	N	0								
1	Room 114	202	FT under carpet (Assumed)	M		Pos	280	SF	N	N	1								
1	Room 114	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	280	SF	N	N	1								
1	Room 114	203	carpet adhesive	M		Pos	252	SF	N	N	1								5%

1	Room 116	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 116	35	wall plaster	S	ND			SF	F	N	0								
1	Room 116	37	clay tile mortar	M	ND			SF	F	N	0								
1	Room 116	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Room 116	40	baseboard adhesive	M	ND			LF	N	N	0								
1	Room 116	110	2'x2' CT white pinhole fissure	M	ND		160	SF	F	N	0								
1	Room 116	202	FT under carpet (Assumed)	M		Pos	160	SF	N	N	1								
1	Room 116	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	160	SF	N	N	1								
1	Room 116	203	carpet adhesive	M		Pos	160	SF	N	N	1							5%	
2	N. Stair & Ha	9	<4" FG PI	T	ND			LF	F	N	0								
2	N. Stair & Ha	10	<4" fibrous PFI on FG	T		Pos	4	EA	F	N	2							10%	
2	N. Stair & Ha	34	ceiling plaster	S	ND			SF	F	N	0								
2	N. Stair & Ha	35	wall plaster	S	ND			SF	F	N	0								
2	N. Stair & Ha	41	9"x9" FT brown	M		Pos	942	SF	N	N	1							5%	
2	N. Stair & Ha	41.5	floor tile adhesive (sample 41)	M	ND		942	SF	N	N	0								
2	N. Stair & Ha	42	9"x9" FT red	M		Pos	942	SF	N	N	1							5%	
2	N. Stair & Ha	42.5	floor tile adhesive (sample 42)	M	ND		942	SF	N	N	0								
2	N. Stair & Ha	43	9"x9" FT grey & white	M	ND		150	SF	N	N	0								
2	N. Stair & Ha	43.5	floor tile adhesive (sample 43)	M	ND		150	SF	N	N	0								
2	N. Stair & Ha	70	12"x12" FT cream w/brown streaks	M	ND		240	SF	N	N	0								
2	N. Stair & Ha	70.5	floor tile adhesive (sample 70)	M		Pos	240	SF	N	N	1							10%	
2	N. Stair & Ha	90	black border tile	M		Pos	314	SF	N	N	1							10%	
2	N. Stair & Ha	90.5	floor tile adhesive (sample 90)	M		Pos	314	SF	N	N	1							5%	
2	N. Stair & Ha	91	grey white stair tread	M	ND		54	SF	N	N	0								
2	N. Stair & Ha	91.5	floor tile adhesive (sample 91)	M	ND		54	SF	N	N	0								
2	N. Stair Hall	34	ceiling plaster	S	ND			SF	F	N	0								
2	N. Stair Hall	35	wall plaster	S	ND			SF	F	N	0								
2	Room 201	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 201	35	wall plaster	S	ND			SF	F	N	0								
2	Room 202	5	<4" felt with tar PI	T		Pos	10	LF	F	N	2							19%	
2	Room 202	6	<4" fibrous PFI on felt	T		Pos	3	EA	F	N	2							18%	
2	Room 202	19	4"-8" FG PI	T	ND			LF	F	N	0								

2	Room 202	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 202	35	wall plaster	S	ND			SF	F	N	0								
2	Room 202	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 202	202	FT under carpet (Assumed)	M		Pos	420	SF	N	N	1								
2	Room 202	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	420	SF	N	N	1								
2	Room 202	203	carpet adhesive	M		Pos	420	SF	N	N	1							5%	
2	Room 202A	19	4"-8" FG PI	T	ND		25	LF	F	N	0								
2	Room 202A	20	4"-8" fibrous PFI on FG	T	ND		2	EA	F	N	0								
2	Room 202A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 202A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 202A	41	9"x9" FT brown	M		Pos	15	SF	N	N	1							5%	
2	Room 202A	41.5	floor tile adhesive (sample 41)	M	ND		15	SF	N	N	0								
2	Room 202A	42	9"x9" FT red	M		Pos	15	SF	N	N	1							5%	
2	Room 202A	42.5	floor tile adhesive (sample 42)	M	ND		15	SF	N	N	0								
2	Room 202A	90	black border tile	M		Pos	15	SF	N	N	1							10%	
2	Room 202A	90.5	floor tile adhesive (sample 90)	M		Pos	15	SF	N	N	1							5%	
2	Room 203	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 203	10	<4" fibrous PFI on FG	T		Pos	5	EA	F	N	2							10%	
2	Room 203	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 203	35	wall plaster	S	ND			SF	F	N	0								
2	Room 203	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 203	102	12"x12" CT pencil/nail hole	M	ND		255	SF	F	N	0								
2	Room 203	102.5	ceiling tile adhesive (sample 102)	M	ND		255	SF	N	N	0								
2	Room 203	202	FT under carpet (Assumed)	M		Pos	255	SF	N	N	1								
2	Room 203	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	255	SF	N	N	1								
2	Room 203	203	carpet adhesive	M		Pos	255	SF	N	N	1							5%	
2	Room 203A	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 203A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 203A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 203A	102	12"x12" CT pencil/nail hole	M	ND		255	SF	F	N	0								
2	Room 203A	102.5	ceiling tile adhesive (sample 102)	M	ND		255	SF	N	N	0								
2	Room 203A	202	FT under carpet (Assumed)	M		Pos	255	SF	N	N	1								
2	Room 203A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	255	SF	N	N	1								
2	Room 203A	203	carpet adhesive	M		Pos	255	SF	N	N	1							5%	

2	Room 203B	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 203B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 203B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 203B	202	FT under carpet (Assumed)	M		Pos	20	SF	N	N	1								
2	Room 203B	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	20	SF	N	N	1								
2	Room 203B	203	carpet adhesive	M		Pos	20	SF	N	N	1								5%
2	Room 203C	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 203C	35	wall plaster	S	ND			SF	F	N	0								
2	Room 203C	202	FT under carpet (Assumed)	M		Pos	40	SF	N	N	1								
2	Room 203C	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	40	SF	N	N	1								
2	Room 203C	203	carpet adhesive	M		Pos	40	SF	N	N	1								5%
2	Room 203D	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 203D	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 203D	35	wall plaster	S	ND			SF	F	N	0								
2	Room 203D	202	FT under carpet (Assumed)	M		Pos	270	SF	N	N	1								
2	Room 203D	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	270	SF	N	N	1								
2	Room 203D	203	carpet adhesive	M		Pos	270	SF	N	N	1								5%
2	Room 204	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 204	35	wall plaster	S	ND			SF	F	N	0								
2	Room 204	41	9"x9" FT brown	M		Pos	70	SF	N	N	1								5%
2	Room 204	41.5	floor tile adhesive (sample 41)	M	ND		70	SF	N	N	0								
2	Room 204	42	9"x9" FT red	M		Pos	70	SF	N	N	1								5%
2	Room 204	42.5	floor tile adhesive (sample 42)	M	ND		70	SF	N	N	0								
2	Room 204	90	black border tile	M		Pos	60	SF	N	N	1								10%
2	Room 204	90.5	floor tile adhesive (sample 90)	M		Pos	60	SF	N	N	1								5%
2	Room 204	101	12"x12" CT white deep fissure	M	ND		180	SF	F	N	0								
2	Room 204	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	180	SF	N	N	1								7%
2	Room 204A	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 204A	10	<4" fibrous PFI on FG	T		Pos		EA	F	N	2								10%
2	Room 204A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 204A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 204A	41	9"x9" FT brown	M		Pos	45	SF	N	N	1								5%

2	Room 204A	41.5	floor tile adhesive (sample 41)	M	ND		45	SF	N	N	0								
2	Room 204A	42	9"x9" FT red	M		Pos	45	SF	N	N	1								5%
2	Room 204A	42.5	floor tile adhesive (sample 42)	M	ND		45	SF	N	N	0								
2	Room 204A	90	black border tile	M		Pos	45	SF	N	N	1								10%
2	Room 204A	90.5	floor tile adhesive (sample 90)	M		Pos	45	SF	N	N	1								5%
2	Room 204A	101	12"x12" CT white deep fissure	M	ND		112	SF	F	N	0								
2	Room 204A	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	112	SF	N	N	1								7%
2	Room 204B	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 204B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 204B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 204B	41	9"x9" FT brown	M		Pos	45	SF	N	N	1								5%
2	Room 204B	41.5	floor tile adhesive (sample 41)	M	ND		45	SF	N	N	0								
2	Room 204B	42	9"x9" FT red	M		Pos	45	SF	N	N	1								5%
2	Room 204B	42.5	floor tile adhesive (sample 42)	M	ND		45	SF	N	N	0								
2	Room 204B	90	black border tile	M		Pos	45	SF	N	N	1								10%
2	Room 204B	90.5	floor tile adhesive (sample 90)	M		Pos	45	SF	N	N	1								5%
2	Room 204B	101	12"x12" CT white deep fissure	M	ND		112	SF	F	N	0								
2	Room 204B	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	112	SF	N	N	1								7%
2	Room 205/2	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 205/2	10	<4" fibrous PFI on FG	T		Pos	2	EA	F	N	2								10%
2	Room 205/2	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 205/2	35	wall plaster	S	ND			SF	F	N	0								
2	Room 205/2	41	9"x9" FT brown	M		Pos	400	SF	N	H	4								5%
2	Room 205/2	41.5	floor tile adhesive (sample 41)	M	ND		400	SF	N	N	0								
2	Room 205/2	42	9"x9" FT red	M		Pos	400	SF	N	H	4								5%
2	Room 205/2	42.5	floor tile adhesive (sample 42)	M	ND		400	SF	N	N	0								
2	Room 205/2	90	black border tile	M		Pos	160	SF	N	N	1								10%
2	Room 205/2	90.5	floor tile adhesive (sample 90)	M		Pos	160	SF	N	N	1								5%
2	Room 205/2	101	12"x12" CT white deep fissure	M	ND		800	SF	F	N	0								
2	Room 205/2	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	800	SF	N	N	0								7%
2	Room 207	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 207	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 207	35	wall plaster	S	ND			SF	F	N	0								
2	Room 207	40	baseboard adhesive	M	ND			LF	N	N	0								

2	Room 207	70	12"x12" FT cream w/brown streaks	M	ND		186	SF	N	N	0								
2	Room 207	70.5	floor tile adhesive (sample 70)	M		Pos	186	SF	N	N	1								10%
2	Room 208	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 208	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 208	35	wall plaster	S	ND			SF	F	N	0								
2	Room 208	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 208	70	12"x12" FT cream w/brown streaks	M	ND		180	SF	N	N	0								
2	Room 208	70.5	floor tile adhesive (sample 70)	M		Pos	180	SF	N	N	1								10%
2	Room 209	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 209	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 209	35	wall plaster	S	ND			SF	F	N	0								
2	Room 209	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 209	70	12"x12" FT cream w/brown streaks	M	ND		180	SF	N	N	0								
2	Room 209	70.5	floor tile adhesive (sample 70)	M		Pos	180	SF	N	N	1								10%
2	Room 210	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 210	35	wall plaster	S	ND			SF	F	N	0								
2	Room 210	41	9"x9" FT brown	M		Pos	93	SF	N	N	1								5%
2	Room 210	41.5	floor tile adhesive (sample 41)	M	ND		93	SF	N	N	1								
2	Room 210	42	9"x9" FT red	M		Pos	93	SF	N	N	1								5%
2	Room 210	42.5	floor tile adhesive (sample 42)	M	ND		93	SF	N	N	0								
2	Room 210	90	black border tile	M		Pos	30	SF	N	N	1								10%
2	Room 210	90.5	floor tile adhesive (sample 90)	M		Pos	30	SF	N	N	1								5%
2	Room 211	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 211	35	wall plaster	S	ND			SF	F	N	0								
2	Room 211	41	9"x9" FT brown	M		Pos	95	SF	N	N	1								5%
2	Room 211	41.5	floor tile adhesive (sample 41)	M	ND		95	SF	N	N	0								
2	Room 211	42	9"x9" FT red	M		Pos	95	SF	N	N	1								5%
2	Room 211	42.5	floor tile adhesive (sample 42)	M	ND		95	SF	N	N	0								
2	Room 211	90	black border tile	M		Pos	64	SF	N	N	1								10%
2	Room 211	90.5	floor tile adhesive (sample 90)	M		Pos	64	SF	N	N	1								5%
2	Room 211W	199	Inaccessable																

2	Room 212	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 212	35	wall plaster	S	ND			SF	F	N	0								
2	Room 212	37	clay tile mortar	M	ND			SF	F	N	0								
2	Room 214/2	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 214/2	19	4"-8" FG PI	T	ND			LF	F	N	0								
2	Room 214/2	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 214/2	35	wall plaster	S	ND			SF	F	N	0								
2	Room 214/2	41	9"x9" FT brown	M		Pos	854	SF	N	L	1							5%	
2	Room 214/2	41.5	floor tile adhesive (sample 41)	M	ND		854	SF	N	N	0								
2	Room 214/2	42	9"x9" FT red	M		Pos	854	SF	N	L	1							5%	
2	Room 214/2	42.5	floor tile adhesive (sample 42)	M	ND		854	SF	N	N	0								
2	Room 214/2	46	9"x9" FT chocolate w/whitestreaks	M	ND			SF	N	N	0								
2	Room 214/2	46.5	floor tile adhesive (sample 46)	M	ND		324	SF	N	N	0								
2	Room 214/2	70	12"x12" FT cream w/brown streaks	M	ND		108	SF	N	N	0								
2	Room 214/2	70.5	floor tile adhesive (sample 70)	M		Pos	108	SF	N	N	1							10%	
2	Room 214/2	72	12"x12" FT blue grey w/ dark specks	M	ND		126	SF	N	N	0								
2	Room 214/2	72.5	floor tile adhesive (sample 72)	M	ND		126	SF	N	N	0								
2	Room 214/2	90	black border tile	M		Pos	180	SF	N	M	1							10%	
2	Room 214/2	90.5	floor tile adhesive (sample 90)	M		Pos	180	SF	N	N	1							5%	
2	Room 214/2	100	12"x12" CT white pencilhole	M	ND		1204	SF	F	N	0								
2	Room 214/2	100.5	ceiling tile adhesive (sample 100)(10	M		Pos	1204	SF	N	N	1							7%	
2	Room 214/2	101	12"x12" CT white deep fissure	M	ND		504	SF	F	N	0								
2	Room 214/2	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	504	SF	N	N	1							7%	
2	Room 217	19	4"-8" FG PI	T	ND			LF	F	N	0								
2	Room 217	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 217	35	wall plaster	S	ND			SF	F	N	0								
2	Room 217	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 217	73	12"x12" FT offwhite w/black specks	M	ND		178	SF	N	N	0								
2	Room 217	73.5	floor tile adhesive (sample 73)	M	ND		178	SF	N	N	0								
2	Room 217	90	black border tile	M		Pos	60	SF	N	N	1							10%	
2	Room 217	90.5	floor tile adhesive (sample 90)	M		Pos	60	SF	N	N	1							5%	
2	Room 217	101	12"x12" CT white deep fissure	M	ND		238	SF	F	N	0								
2	Room 217	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	238	SF	N	N	1							7%	
2	Room 217A	34	ceiling plaster	S	ND			SF	F	N	0								

2	Room 217A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 217A	38	concrete block mortar	M	ND			SF	F	N	0								
2	Room 217A	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 217A	73	12"x12" FT offwhite w/black specks	M	ND		25	SF	N	N	0								
2	Room 217A	73.5	floor tile adhesive (sample 73)	M	ND		25	SF	N	N	0								
2	Room 217A	90	black border tile	M		Pos	20	SF	N	N	1							10%	
2	Room 217A	90.5	floor tile adhesive (sample 90)	M		Pos	20	SF	N	N	1							5%	
2	Room 218	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 218	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 218	35	wall plaster	S	ND			SF	F	N	0								
2	Room 218	41	9"x9" FT brown	M		Pos	95	SF	N	N	1							5%	
2	Room 218	41.5	floor tile adhesive (sample 41)	M	ND		95	SF	N	N	0								
2	Room 218	42	9"x9" FT red	M		Pos	95	SF	N	N	1							5%	
2	Room 218	42.5	floor tile adhesive (sample 42)	M	ND		95	SF	N	N	0								
2	Room 218	90	black border tile	M		Pos	65	SF	N	N	1							10%	
2	Room 218	90.5	floor tile adhesive (sample 90)	M		Pos	65	SF	N	N	1							5%	
2	Room 218	101	12"x12" CT white deep fissure	M	ND		255	SF	F	N	0								
2	Room 218	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	255	SF	N	N	1							7%	
2	Room 219	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 219	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 219	35	wall plaster	S	ND			SF	F	N	0								
2	Room 219	102	12"x12" CT pencil/nail hole	M	ND		204	SF	F	N	0								
2	Room 219	102.5	ceiling tile adhesive (sample 102)	M	ND		204	SF	N	N	0								
2	Room 219	140	cork wallboard w/tar (Assumed)	M		Pos	9	SF	N	N	1								
2	Room 219	202	FT under carpet (Assumed)	M		Pos	204	SF	N	N	1								
2	Room 219	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	204	SF	N	N	1								
2	Room 219	203	carpet adhesive	M		Pos		SF	N	N	1							5%	
2	Room 219A	199	Inaccessible																
2	Room 220	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220	41	9"x9" FT brown	M		Pos	85	SF	N	N	1							5%	
2	Room 220	41.5	floor tile adhesive (sample 41)	M	ND		85	SF	N	N	0								
2	Room 220	42	9"x9" FT red	M		Pos	85	SF	N	N	1							5%	

2	Room 220	42.5	floor tile adhesive (sample 42)	M	ND		85	SF	N	N	0								
2	Room 220	90	black border tile	M		Pos	60	SF	N	N	1								10%
2	Room 220	90.5	floor tile adhesive (sample 90)	M		Pos	60	SF	N	N	1								5%
2	Room 220	102	12"x12" CT pencil/nail hole	M	ND		225	SF	F	N	0								
2	Room 220	102.5	ceiling tile adhesive (sample 102)	M	ND		225	SF	N	N	0								
2	Room 220B	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 220B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220B	41	9"x9" FT brown	M		Pos	85	SF	N	N	1								5%
2	Room 220B	41.5	floor tile adhesive (sample 41)	M	ND		85	SF	N	N	0								
2	Room 220B	42	9"x9" FT red	M		Pos	85	SF	N	N	1								5%
2	Room 220B	42.5	floor tile adhesive (sample 42)	M	ND		85	SF	N	N	0								
2	Room 220B	90	black border tile	M		Pos	60	SF	N	N	1								10%
2	Room 220B	90.5	floor tile adhesive (sample 90)	M		Pos	60	SF	N	N	1								5%
2	Room 220B	102	12"x12" CT pencil/nail hole	M	ND		225	SF	F	N	0								
2	Room 220B	102.5	ceiling tile adhesive (sample 102)	M	ND		225	SF	N	N	0								
2	Room 221	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 221	35	wall plaster	S	ND			SF	F	N	0								
2	Room 221	101	12"x12" CT white deep fissure	M	ND			SF	F	N	0								
2	Room 221	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	180	SF	N	N	1								7%
2	Room 221	202	FT under carpet (Assumed)	M		Pos	180	SF	N	N	1								
2	Room 221	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	180	SF	N	N	1								
2	Room 221A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 221A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 221A	101	12"x12" CT white deep fissure	M	ND		120	SF	F	N	0								
2	Room 221A	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	120	SF	N	N	1								7%
2	Room 221A	202	FT under carpet (Assumed)	M		Pos	120	SF	N	N	1								
2	Room 221A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	120	SF	N	N	1								
2	Room 221B	19	4"-8" FG PI	T	ND			LF	F	N	0								
2	Room 221B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 221B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 221B	101	12"x12" CT white deep fissure	M	ND		104	SF	F	N	0								
2	Room 221B	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	104	SF	N	N	1								7%

2	Room 221B	202	FT under carpet (Assumed)	M		Pos	104	SF	N	N	1								
2	Room 221B	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	104	SF	N	N	1								
2	Room 222	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 222	35	wall plaster	S	ND			SF	F	N	0								
2	Room 222	41	9"x9" FT brown	M		Pos	85	SF	N	N	1							5%	
2	Room 222	41.5	floor tile adhesive (sample 41)	M	ND		85	SF	N	N	0								
2	Room 222	42	9"x9" FT red	M		Pos	85	SF	N	N	1							5%	
2	Room 222	42.5	floor tile adhesive (sample 42)	M	ND		85	SF	N	N	0								
2	Room 222	90	black border tile	M		Pos	54	SF	N	N	1							10%	
2	Room 222	90.5	floor tile adhesive (sample 90)	M		Pos	54	SF	N	N	1							5%	
2	Room 222	101	12"x12" CT white deep fissure	M	ND		170	SF	F	N	0								
2	Room 222	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	170	SF	N	N	1							7%	
2	Room 222	140	cork wallboard w/tar (Assumed)	M		Pos	90	SF	N	N	1								
2	Room 222A	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 222A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 222A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 222A	41	9"x9" FT brown	M		Pos	38	SF	N	N	1							5%	
2	Room 222A	41.5	floor tile adhesive (sample 41)	M	ND		38	SF	N	N	0								
2	Room 222A	42	9"x9" FT red	M		Pos	38	SF	N	N	1							5%	
2	Room 222A	42.5	floor tile adhesive (sample 42)	M	ND		38	SF	N	N	0								
2	Room 222A	90	black border tile	M		Pos	42	SF	N	N	1							10%	
2	Room 222A	90.5	floor tile adhesive (sample 90)	M		Pos	42	SF	N	N	1							5%	
2	Room 222A	101	12"x12" CT white deep fissure	M	ND		117	SF	F	N	0								
2	Room 222A	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	117	SF	N	N	1							7%	
2	Room 222B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 222B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 222B	41	9"x9" FT brown	M		Pos	38	SF	N	N	1							5%	
2	Room 222B	41.5	floor tile adhesive (sample 41)	M	ND		38	SF	N	N	0								
2	Room 222B	42	9"x9" FT red	M		Pos	38	SF	N	N	1							5%	
2	Room 222B	42.5	floor tile adhesive (sample 42)	M	ND		38	SF	N	N	0								
2	Room 222B	90	black border tile	M		Pos	42	SF	N	N	1							10%	
2	Room 222B	90.5	floor tile adhesive (sample 90)	M		Pos	42	SF	N	N	1							5%	
2	Room 222B	101	12"x12" CT white deep fissure	M	ND		117	SF	F	N	0								
2	Room 222B	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	117	SF	N	N	1							7%	

2	Room 222B	140	cork wallboard w/tar (Assumed)	M		Pos	100	SF	N	N	1								
2	Room 223	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 223	25	black foam PI	T	ND			LF	F	N	0								
2	Room 223	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 223	35	wall plaster	S	ND			SF	F	N	0								
2	Room 223	41	9"x9" FT brown	M		Pos	90	SF	N	N	1								5%
2	Room 223	41.5	floor tile adhesive (sample 41)	M	ND		90	SF	N	N	0								
2	Room 223	42	9"x9" FT red	M		Pos	90	SF	N	N	1								5%
2	Room 223	42.5	floor tile adhesive (sample 42)	M	ND		90	SF	N	N	0								
2	Room 223	90	black border tile	M		Pos	56	SF	N	N	1								10%
2	Room 223	90.5	floor tile adhesive (sample 90)	M		Pos	56	SF	N	N	1								5%
2	Room 223	101	12"x12" CT white deep fissure	M	ND		180	SF	F	N	0								
2	Room 223	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	180	SF	N	N	1								7%
2	Room 223	140	cork wallboard w/tar (Assumed)	M		Pos	90	SF	N	N	1								
2	Room 223A	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 223A	25	black foam PI	T	ND			LF	F	N	0								
2	Room 223A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 223A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 223A	101	12"x12" CT white deep fissure	M	ND		104	SF	F	N	0								
2	Room 223A	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	104	SF	N	N	1								7%
2	Room 223A	202	FT under carpet (Assumed)	M		Pos	104	SF	N	N	1								
2	Room 223A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	104	SF	N	N	1								
2	Room 223A	203	carpet adhesive	M		Pos	104	SF	N	N	1								5%
2	Room 223B	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 223B	10	<4" fibrous PFI on FG	T		Pos	4	EA	F	N	2								10%
2	Room 223B	25	black foam PI	T	ND			LF	F	N	0								
2	Room 223B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 223B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 223B	41	9"x9" FT brown	M		Pos	60	SF	N	N	1								5%
2	Room 223B	41.5	floor tile adhesive (sample 41)	M	ND		60	SF	N	N	0								
2	Room 223B	42	9"x9" FT red	M		Pos	60	SF	N	N	1								5%
2	Room 223B	42.5	floor tile adhesive (sample 42)	M	ND		60	SF	N	N	0								
2	Room 223B	90	black border tile	M		Pos	48	SF	N	N	1								10%
2	Room 223B	90.5	floor tile adhesive (sample 90)	M		Pos	48	SF	N	N	1								5%

2	Room 223B	101	12"x12" CT white deep fissure	M	ND		130	SF	F	N	0								
2	Room 223B	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	130	SF	N	N	1					7%			
2	Room 224	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 224	25	black foam PI	T	ND			LF	F	N	0								
2	Room 224	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 224	35	wall plaster	S	ND			SF	F	N	0								
2	Room 224	101	12"x12" CT white deep fissure	M	ND		255	SF	F	N	0								
2	Room 224	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	255	SF	N	N	1					7%			
2	Room 224	202	FT under carpet (Assumed)	M		Pos	255	SF	N	N	1								
2	Room 224	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	255	SF	N	N	1								
2	Room 224A	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 224A	25	black foam PI	T	ND			LF	F	N	0								
2	Room 224A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 224A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 224A	101	12"x12" CT white deep fissure	M	ND		255	SF	F	N	0								
2	Room 224A	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	255	SF	N	N	1					7%			
2	Room 224A	202	FT under carpet (Assumed)	M		Pos	255	SF	N	N	1								
2	Room 224A	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	255	SF	N	N	1								
2	Room 224B	199	Inaccessable																
2	Room 224B	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 224B	25	black foam PI	T	ND			LF	F	N	0								
2	Room 224B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 224B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 224B	101	12"x12" CT white deep fissure	M	ND		255	SF	F	N	0								
2	Room 224B	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	255	SF	N	N	1					7%			
2	Room 224B	202	FT under carpet (Assumed)	M		Pos	255	SF	N	N	1								
2	Room 224B	202.5	floor tile adhesive (sample 202)(Assu	M		Pos	255	SF	N	N	1								
2	Room 225	9	<4" FG PI	T	ND			LF	F	N	0								
2	Room 225	37	clay tile mortar	M	ND			SF	F	N	0								
2	Room 225	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 225	35	wall plaster	S	ND			SF	F	N	0								

2	Room 226 V	36	red brick mortar	M	ND			SF	F	N	0								
2	Room 226 V	37	clay tile mortar	M	ND			SF	F	N	0								
2	Room 226	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 226	35	wall plaster	S	ND			SF	F	N	0								
2	Room 226	110	2'x2' CT white pinhole fissure	M	ND		318	SF	F	N	0								
2	Room 226	202	FT under carpet (Assumed)	M		Pos	318	SF	N	N	1								
2	Room 226	202.5	floor tile adhesive (sample 202)(Asst	M		Pos	318	SF	N	N	1								
2	Room 227	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 227	35	wall plaster	S	ND			SF	F	N	0								
2	Room 227	41	9"x9" FT brown	M		Pos	40	SF	N	N	1							5%	
2	Room 227	41.5	floor tile adhesive (sample 41)	M	ND		40	SF	N	N	0								
2	Room 227	42	9"x9" FT red	M		Pos	40	SF	N	N	1							5%	
2	Room 227	42.5	floor tile adhesive (sample 42)	M	ND		40	SF	N	N	0								
2	Room 227	90	black border tile	M		Pos	40	SF	N	N	1							10%	
2	Room 227	90.5	floor tile adhesive (sample 90)	M		Pos	40	SF	N	N	1							5%	
3	Room 301 V	3	<4" aircell PI (Assumed)	T		Pos	20	LF	F	N	2								
3	Room 301 V	13	4"-8" aircell PI (Assumed)	T		Pos	20	LF	F	N	2							15%	
3	Room 301 V	36	red brick mortar	M	ND			SF	F	N	0								
3	Room 301 V	37	clay tile mortar	M	ND			SF	F	N	0								
3	Room 301	3	<4" aircell PI (Assumed)	T		Pos	6	LF	F	N	2								
3	Room 301	19	4"-8" FG PI	T	ND			LF	F	N	0								
3	Room 301	20	4"-8" fibrous PFI on FG	T	ND		3	EA	F	N	0								
3	Room 301	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 301	35	wall plaster	S	ND			SF	F	N	0								
3	Room 302	1	<4" white fibrous PI	T		Pos	20	LF	F	N	2							10%	
3	Room 302	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2							15%	
3	Room 302	9	<4" FG PI	T	ND			LF	F	N	0								
3	Room 302	10	<4" fibrous PFI on FG	T		Pos	105	EA	F	H	4							10%	
3	Room 302	11	4"-8" white fibrous PI	T		Pos	100	LF	F	N	2							20%	
3	Room 302	12	4"-8" PFI on white fibrous	T		Pos	12	EA	F	N	2							15%	
3	Room 302	19	4"-8" FG PI	T	ND			LF	F	N	0								
3	Room 302	20	4"-8" fibrous PFI on FG	T	ND		29	EA	F	N	0								

3	Room 302	36	red brick mortar	M	ND			SF	F	N	0								
3	Room 302A	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2		10%						
3	Room 302A	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2			15%					
3	Room 302A	19	4"-8" FG PI	T	ND			LF	F	N	0								
3	Room 302A	20	4"-8" fibrous PFI on FG	T	ND		9	EA	F	N	0								
3	Room 302A	36	red brick mortar	M	ND			SF	F	N	0								
3	Room 302A	37	clay tile mortar	M	ND			SF	F	N	0								
3	Room 304	9	<4" FG PI	T	ND			LF	F	N	0								
3	Room 304	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 304	35	wall plaster	S	ND			SF	F	N	0								
3	Room 304	203	carpet adhesive	M		Pos	400	SF	N	N	1			5%					
3	Room 304A/	5	<4" felt with tar PI	T		Pos	30	LF	F	N	2			19%					
3	Room 304A/	6	<4" fibrous PFI on felt	T		Pos	14	EA	F	N	2			18%					
3	Room 304A/	19	4"-8" FG PI	T	ND			LF	F	N	0								
3	Room 304A/	20	4"-8" fibrous PFI on FG	T	ND		2	EA	F	N	0								
3	Room 304A/	25	black foam PI	T	ND			LF	F	N	0								
3	Room 304A/	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 304A/	35	wall plaster	S	ND			SF	F	N	0								
3	Room 304A/	37	clay tile mortar	M	ND			SF	F	N	0								
3	Room 305	36	red brick mortar	M	ND			SF	F	N	0								
3	Room 305	37	clay tile mortar	M	ND			SF	F	N	0								
3	Room 305	38	concrete block mortar	M	ND			SF	F	N	0								
3	Room 305	39	sheetrock & taping compound	M	ND			SF	F	N	0								
3	Room 305	40	baseboard adhesive	M	ND			LF	N	N	0								
3	Room 306	9	<4" FG PI	T	ND			LF	F	N	0								
3	Room 306	10	<4" fibrous PFI on FG	T		Pos	1	EA	F	N	2			10%					
3	Room 306	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 306	35	wall plaster	S	ND			SF	F	N	0								
3	Room 306	110	2'x2' CT white pinhole fissure	M	ND		330	SF	F	N	0								
3	Room 306A	5	<4" felt with tar PI	T		Pos	10	LF	F	M	3			19%					
3	Room 306A	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	M	3			18%					

4	Room 400	9	<4" FG PI	T	ND			LF	F	N	0								
4	Room 400	10	<4" fibrous PFI on FG	T		Pos	3	EA	F	N	2				10%				
4	Room 400	35	wall plaster	S	ND			SF	F	N	0								
4	Room 400	37	clay tile mortar	M	ND			SF	F	N	0								
4	Room 400	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 400	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 400	45	9"x9" FT off white w/ grey specks	M		Pos	762	SF	N	N	1				5%				
4	Room 400	45.5	floor tile adhesive (sample 45)	M		Pos	762	SF	N	N	1				5%				
4	Room 400	120	2'x4' CT pinhole wormhole	M		Pos	762	SF	F	N	1			15%					
4	Room 400A	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 400A	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 400A	45	9"x9" FT off white w/ grey specks	M		Pos	30	SF	N	N	1				5%				
4	Room 400A	45.5	floor tile adhesive (sample 45)	M		Pos	30	SF	N	N	1				5%				
4	Room 410	9	<4" FG PI	T	ND			LF	F	N	0								
4	Room 410	36	red brick mortar	M	ND			SF	F	N	0								
4	Room 410	37	clay tile mortar	M	ND			SF	F	N	0								
4	Room 410	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 410	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 410	45	9"x9" FT off white w/ grey specks	M		Pos	280	SF	N	H	4				5%				
4	Room 410	45.5	floor tile adhesive (sample 45)	M		Pos	280	SF	N	N	1				5%				
4	Room 410	120	2'x4' CT pinhole wormhole	M		Pos	280	SF	F	N	1			15%					
4	Room 410A	36	red brick mortar	M	ND			SF	F	N	0								
4	Room 410A	37	clay tile mortar	M	ND			SF	F	N	0								
4	Room 410A	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 410A	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 410A	45	9"x9" FT off white w/ grey specks	M		Pos	90	SF	N	N	1				5%				
4	Room 410A	45.5	floor tile adhesive (sample 45)	M		Pos	90	SF	N	N	1				5%				
4	Room 410A	120	2'x4' CT pinhole wormhole	M		Pos	90	SF	F	N	1			15%					
4	Room 410B	37	clay tile mortar	M	ND			SF	F	N	0								
4	Room 410B	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 410B	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 410B	45	9"x9" FT off white w/ grey specks	M		Pos	96	SF	N	N	1				5%				
4	Room 410B	45.5	floor tile adhesive (sample 45)	M		Pos	96	SF	N	N	1				5%				

4	Room 410B	120	2'x4' CT pinhole wormhole	M		Pos	96	SF	F	N	1			15%					
4	Room 410C	39	sheetrock & taping compound	M	ND			SF	F	N	0								
4	Room 410C	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 410C	45	9"x9" FT off white w/ grey specks	M		Pos	96	SF	N	N	1			5%					
4	Room 410C	45.5	floor tile adhesive (sample 45)	M		Pos	96	SF	N	N	1			5%					
4	Room 410C	120	2'x4' CT pinhole wormhole	M		Pos	96	SF	F	N	1			15%					
4	Room 420	34	ceiling plaster	S	ND			SF	F	N	0								
4	Room 420	35	wall plaster	S	ND			SF	F	N	0								
4	Room 420	36	red brick mortar	M	ND			SF	F	N	0								
4	Room 420	40	baseboard adhesive	M	ND			LF	N	N	0								
4	Room 420	45	9"x9" FT off white w/ grey specks	M		Pos	450	SF	N	N	1			5%					
4	Room 420	45.5	floor tile adhesive (sample 45)	M		Pos	450	SF	N	N	1			5%					
4	Room 420	101	12"x12" CT white deep fissure	M	ND		450	SF	F	N	0								
4	Room 420	101.5	ceiling tile adhesive (sample 101)(10	M		Pos	450	SF	N	N	1			7%					
4	Room 420W	199	Inaccessible																
4	Room 425		See Room 325																