

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
B	Garage	1	<4" white fibrous PI	T		Pos	4192	LF	F	L	3	4/23/00	JFA/GAA	10%	15%					057-96-039
B	Garage	2	<4" PFI on white fibrous	T		Pos	255	EA	F	N	2				10%					
B	Garage	3	<4" aircell PI(assumed)	T		Pos	60	LF	F	N	2									
B	Garage	4	<4" fibrous PFI on aircell(assumed)	T		Pos	13	EA	F	N	2									
B	Garage	5	<4" felt with tar PI	T		Pos	1326	LF	F	N	2				5%					
B	Garage	6	<4" fibrous PFI on felt	T		Pos	112	EA	F	N	2				10%			3%		
B	Garage	9	<4" fiberglass PI	T	ND			LF	F	N	0									
B	Garage	10	<4" fibrous PFI on FG	T	ND		2	EA	F	L	0									
B	Garage	11	4"-8" white fibrous PI	T		Pos	1680	LF	F	N	2					30%				
B	Garage	12	4"-8" PFI on white fibrous	T		Pos	89	EA	F	N	2			10%	20%					
B	Garage	17	4"-8" fiberglass w/tar PI	T	ND		165	LF	F	N	0									
B	Garage	18	4"-8" fibrous PFI on FG w/tar	T		Pos	7	EA	F	N	2				15%					
B	Garage	19	4"-8" fiberglass PI	T	ND			LF	F	N	0									
B	Garage	20	4"-8" fibrous PFI on FG	T	ND		2	EA	F	N	0									
B	Garage	25	4"-8" cork w/tar PI	T	ND		124	LF	N	N	0									
B	Garage	26	4"-8" fibrous PFI on cork w/tar	T	ND		13	EA	F	N	0									
B	Garage	37	clay tile mortar	M	ND			SF	F	N	0									
B	Garage	38	concrete block mortar	M	ND			SF	F	N	0									
B	Garage	95	canvass vibration joint	M	ND		3	EA	N	N	0									
B	Lobby(hatch	1	<4" white fibrous PI	T		Pos	46	LF	F	L	3			10%	15%					
B	Lobby(hatch	2	<4" PFI on white fibrous	T		Pos	6	EA	F	L	3				10%					
B	Lobby(hatch	3	<4" aircell PI(assumed)	T		Pos	90	LF	F	L	3									
B	Lobby(hatch	4	<4" fibrous PFI on aircell(assumed)	T		Pos	10	EA	F	L	3									
B	Lobby(hatch	37	clay tile mortar	M	ND			SF	F	N	0									
B	Lobby(hatch)		debris	M		Pos	30	SF	F	H	4									
B	Lobby	1	<4" white fibrous PI	T		Pos	8	LF	F	N	2			10%	15%					
B	Lobby	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2				10%					
B	Lobby	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2				5%					
B	Lobby	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	N	2				10%			3%		
B	Lobby	11	4"-8" white fibrous PI	T		Pos	6	LF	F	N	2				30%					
B	Lobby	34	ceiling plaster	S	ND			SF	F	N	0									
B	Lobby	35	wall plaster	S	ND			SF	F	N	0									
B	Room 3	34	ceiling plaster	S	ND			SF	F	N	0									

B	Room 3	35	wall plaster	S	ND			SF	F	N	0								
B	Room 5	9	<4" fiberglass PI	T	ND			LF	F	N	0								
B	Room 5	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 5	35	wall plaster	S	ND			SF	F	N	0								
B	Room 5(hatches)		inaccessible																
B	Room 5A	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 5A	35	wall plaster	S	ND			SF	F	N	0								
B	Room 5B	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 5B	35	wall plaster	S	ND			SF	F	N	0								
B	Room 5C	9	<4" fiberglass PI	T	ND			LF	F	N	0								
B	Room 5C	31	fiberglass duct insulation	T	ND			SF	F	N	0								
B	Room 5C	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 5C	35	wall plaster	S	ND			SF	F	N	0								
B	Room 5C	84	2'x2' pinhole crater CT	M	ND		30	SF	F	N	0								
B	Room 6	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 6	35	wall plaster	S	ND			SF	F	N	0								
B	Room 6(hatch)	37	clay tile mortar	M	ND			SF	F	N	0								
B	Room 7	1	<4" white fibrous PI	T		Pos	2	LF	F	L	3		10%	15%					
B	Room 7	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%					
B	Room 7	5	<4" felt with tar PI	T		Pos	2	LF	F	N	2			5%					
B	Room 7	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	N	2			10%			3%		
B	Room 7	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 7	35	wall plaster	S	ND			SF	F	N	0								
B	Room 8	5	<4" felt with tar PI	T		Pos	16	LF	F	N	2			5%					
B	Room 8	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	L	3			10%			3%		
B	Room 8	9	<4" fiberglass PI	T	ND			LF	F	N	0								
B	Room 8	34	ceiling plaster	S	ND			SF	F	N	0								
B	Room 8	35	wall plaster	S	ND			SF	F	N	0								

B	Room 9		inaccessible																
B	Room 10	1	<4" white fibrous PI	T	Pos	282	LF	F	N	2		10%	15%						
B	Room 10	2	<4" PFI on white fibrous	T	Pos	83	EA	F	N	2			10%						
B	Room 10	5	<4" felt with tar PI	T	Pos	64	LF	F	N	2			5%						
B	Room 10	6	<4" fibrous PFI on felt	T	Pos	22	EA	F	N	2			10%			3%			
B	Room 10	9	<4" fiberglass PI	T	ND		LF	F	N	0									
B	Room 10	11	4"-8" white fibrous PI	T	Pos	126	LF	F	N	2			30%						
B	Room 10	12	4"-8" PFI on white fibrous	T	Pos	43	EA	F	N	2		10%	20%						
B	Room 10	19	4"-8" fiberglass PI	T	ND		LF	F	N	0									
B	Room 10	20	4"-8" fibrous PFI on FG	T	ND	35	EA	F	N	0									
B	Room 10	31	fiberglass duct insulation	T	ND		SF	F	N	0									
B	Room 10	32	white fibrous tank	T	Pos	80	SF	F	N	2		10%	20%						
B	Room 10	37	clay tile mortar	M	ND		SF	F	N	0									
B	Room 11	11	4"-8" white fibrous PI	T	Pos	4	LF	F	N	2			30%						
B	Room 11	12	4"-8" PFI on white fibrous	T	Pos	1	EA	F	N	2		10%	20%						
B	Room 11	34	ceiling plaster	S	ND		SF	F	N	0									
B	Room 11	35	wall plaster	S	ND		SF	F	N	0									
B	Room 12		inaccessible																
B	Room 13	1	<4" white fibrous PI	T	Pos	97	LF	F	N	2		10%	15%						
B	Room 13	2	<4" PFI on white fibrous	T	Pos	13	EA	F	N	2			10%						
B	Room 13	5	<4" felt with tar PI	T	Pos	50	LF	F	N	2			5%						
B	Room 13	6	<4" fibrous PFI on felt	T	Pos	2	EA	F	N	2			10%			3%			
B	Room 13	11	4"-8" white fibrous PI	T	Pos	25	LF	F	N	2			30%						
B	Room 13	12	4"-8" PFI on white fibrous	T	Pos	3	EA	F	N	2		10%	20%						
B	Room 13	37	clay tile mortar	M	ND		SF	F	N	0									
B	Room 13	95	canvass vibration joint	M	ND	1	EA	N	N	0									
B	Room 14	1	<4" white fibrous PI	T	Pos	14	LF	F	N	2		10%	15%						
B	Room 14	2	<4" PFI on white fibrous	T	Pos	1	EA	F	N	2			10%						
B	Room 14	3	<4" aircell PI(assumed)	T	Pos	47	LF	F	N	2									
B	Room 14	4	<4" fibrous PFI on aircell(assumed)	T	Pos	20	EA	F	N	2									
B	Room 14	11	4"-8" white fibrous PI	T	Pos	22	LF	F	N	2			30%						

B	Room 14	12	4"-8" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%	20%						
B	Room 14	34	ceiling plaster	S	ND			SF	F	N	0										
B	Room 14	35	wall plaster	S	ND			SF	F	N	0										
B	Room 15		inaccessible																		
B	Room 16	9	<4" fiberglass PI	T	ND			LF	F	N	0										
B	Room 16	38	concrete block mortar	M	ND			SF	F	N	0										
B	Room 17	1	<4" white fibrous PI	T		Pos	98	LF	F	N	2			10%	15%						
B	Room 17	2	<4" PFI on white fibrous	T		Pos	16	EA	F	N	2				10%						
B	Room 17	3	<4" aircell PI(assumed)	T		Pos	8	LF	F	N	2										
B	Room 17	4	<4" fibrous PFI on aircell(assumed)	T		Pos	3	EA	F	N	2										
B	Room 17	5	<4" felt with tar PI	T		Pos	110	LF	F	N	2					5%					
B	Room 17	6	<4" fibrous PFI on felt	T		Pos	26	EA	F	N	2				10%			3%			
B	Room 17	13	4"-8" aircell PI(assumed)	T		Pos	51	LF	F	N	2										
B	Room 17	14	4"-8" fibrous PFI on aircell(assumed)	T		Pos	3	EA	F	N	2										
B	Room 20	1	<4" white fibrous PI	T		Pos	3	LF	F	N	2			10%	15%						
B	Room 20	9	<4" fiberglass PI	T	ND			LF	F	N	0										
B	Room 20	10	<4" fibrous PFI on FG	T	ND		4	EA	F	N	0										
B	Room 20	34	ceiling plaster	S	ND			SF	F	N	0										
B	Room 20	35	wall plaster	S	ND			SF	F	N	0										
B	Room 20	80	12"x12" smooth white CT	M	ND		1240	SF	F	N	0										
B	Room 20	80.5	ceiling tile adhesive (sample 80)	M		Pos	1240	SF	N	N	1					5%					
	Stairs Cente	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2			10%	15%						
	Stairs Cente	34	ceiling plaster	S	ND			SF	F	N	0										
	Stairs Cente	35	wall plaster	S	ND			SF	F	N	0										
	Stairs Cente	80	12"x12" smooth white CT	M	ND		176	SF	F	N	0										
	Stairs Cente	80.5	ceiling tile adhesive (sample 80)	M		Pos	176	SF	N	N	1					5%					
	Stairs East	1	<4" white fibrous PI	T		Pos	30	LF	F	L	3			10%	15%						
	Stairs East	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2				10%						
	Stairs East	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2					5%					
	Stairs East	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2				10%			3%			
	Stairs East	11	4"-8" white fibrous PI	T		Pos	12	LF	F	L	3				30%						

	Stairs East	34	ceiling plaster	S	ND			SF	F	N	0								
	Stairs East	35	wall plaster	S	ND			SF	F	N	0								
	Stairs East	80	12"x12" smooth white CT	M	ND		160	SF	F	N	0								
	Stairs East	80.5	ceiling tile adhesive (sample 80)	M		Pos	160	SF	N	N	1								5%
	Stairs East	90	2'x4' pinhole/nailhole CT	M	ND		96	SF	F	N	0								
	Stairs West	9	<4" fiberglass PI	T	ND			LF	F	N	0								
	Stairs West	34	ceiling plaster	S	ND			SF	F	N	0								
	Stairs West	35	wall plaster	S	ND			SF	F	N	0								
	Stairs West	80	12"x12" smooth white CT	M	ND		112	SF	F	N	0								
	Stairs West	80.5	ceiling tile adhesive (sample 80)	M		Pos	112	SF	N	N	1								5%
1	Corridor East	34	ceiling plaster	S	ND			SF	F	N	0								
1	Corridor East	35	wall plaster	S	ND			SF	F	N	0								
1	Corridor East	41	9"x9" black & red FT	M		Pos	305	SF	N	N	1								5%
1	Corridor East	41.5	floor tile adhesive (sample 41)	M		Pos	305	SF	N	N	1								
1	Corridor East	80	12"x12" smooth white CT	M	ND		305	SF	F	N	0								
1	Corridor East	80.5	ceiling tile adhesive (sample 80)	M		Pos	305	SF	N	N	1								5%
1	Corridor West	34	ceiling plaster	S	ND			SF	F	N	0								
1	Corridor West	35	wall plaster	S	ND			SF	F	N	0								
1	Corridor West	41	9"x9" black & red FT	M		Pos	150	SF	N	N	1								5%
1	Corridor West	41.5	floor tile adhesive (sample 41)	M		Pos	150	SF	N	N	1								
1	Corridor West	80	12"x12" smooth white CT	M	ND		150	SF	F	N	0								
1	Corridor West	80.5	ceiling tile adhesive (sample 80)	M		Pos	150	SF	N	N	1								5%
1	Lobby Central	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Lobby Central	10	<4" fibrous PFI on FG	T	ND		6	EA	F	N	0								
1	Lobby Central	34	ceiling plaster	S	ND			SF	F	N	0								
1	Lobby Central	35	wall plaster	S	ND			SF	F	N	0								
1	Lobby Central	60	12"x12" cream w/beige FT	M	ND		446	SF	N	N	0								
1	Lobby Central	60.5	floor tile adhesive (sample 60)	M		Pos	446	SF	N	N	1								3%
1	Lobby Central	80	12"x12" smooth white CT	M	ND		446	SF	F	N	0								
1	Lobby Central	80.5	ceiling tile adhesive (sample 80)	M		Pos	446	SF	N	N	1								5%
1	Lobby East	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Lobby East	10	<4" fibrous PFI on FG	T	ND		2	EA	F	N	0								

1	Lobby East	34	ceiling plaster	S	ND			SF	F	N	0								
1	Lobby East	35	wall plaster	S	ND			SF	F	N	0								
1	Lobby East	41	9"x9" black & red FT	M		Pos	275	SF	N	N	1							5%	
1	Lobby East	41.5	floor tile adhesive (sample 41)	M		Pos	275	SF	N	N	1								
1	Lobby East	80	12"x12" smooth white CT	M	ND		275	SF	F	N	0								
1	Lobby East	80.5	ceiling tile adhesive (sample 80)	M		Pos	275	SF	N	N	1							5%	
1	Room 100	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 100	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 100	35	wall plaster	S	ND			SF	F	N	0								
1	Room 100A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 100A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 100A	41	9"x9" black & red FT	M		Pos	12	SF	N	N	1							5%	
1	Room 100A	41.5	floor tile adhesive (sample 41)	M		Pos	12	SF	N	N	1								
1	Room 100C	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 100C	35	wall plaster	S	ND			SF	F	N	0								
1	Room 100C(hatch)		see Room 102C(hatch)																
1	Room 101	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 101	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101	35	wall plaster	S	ND			SF	F	N	0								
1	Room 101A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 101B	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101B	35	wall plaster	S	ND			SF	F	N	0								
1	Room 101C	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 101C	35	wall plaster	S	ND			SF	F	N	0								
1	Room 102	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 102	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 102	35	wall plaster	S	ND			SF	F	N	0								

1	Room 102B	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 102B	35	wall plaster	S	ND			SF	F	N	0								
1	Room 102C	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 102C	35	wall plaster	S	ND			SF	F	N	0								
1	Room 102C	5	<4" felt with tar PI	T		Pos	25	LF	F	N	2							5%	
1	Room 102C	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	N	2							10%	3%
1	Room 102C	35	wall plaster	S	ND			SF	F	N	0								
1	Room 102C(hatch)		aircell debris	M		Pos	4	SF	F	H	4								
1	Room 103	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 103	35	wall plaster	S	ND			SF	F	N	0								
1	Room 103(h	3	<4" aircell PI(assumed)	T		Pos	10	LF	F	L	3								
1	Room 103(h	4	<4" fibrous PFI on aircell(assumed)	T		Pos	2	EA	F	L	3								
1	Room 103(h	5	<4" felt with tar PI	T		Pos	35	LF	F	L	3							5%	
1	Room 103(h	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	L	3							10%	3%
1	Room 103(h	35	wall plaster	S	ND			SF	F	N	0								
1	Room 103A	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 103A	35	wall plaster	S	ND			SF	F	N	0								
1	Room 103B	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 103B	35	wall plaster	S	ND			SF	F	N	0								
1	Room 113	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 113	35	wall plaster	S	ND			SF	F	N	0								
1	Room 113	61	12"x12" grey w/black & cream FT	M	ND		90	SF	N	N	0								
1	Room 113	61.5	floor tile adhesive (sample 61)	M	ND		90	SF	N	N	0								
1	Room 113	82	12"x12" pegboard CT	M	ND		90	SF	F	N	0								
1	Room 113	82.5	ceiling tile adhesive (sample 82)	M		Pos	90	SF	N	N	1							3%	
1	Room 114	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 114	35	wall plaster	S	ND			SF	F	N	0								
1	Room 114	61	12"x12" grey w/black & cream FT	M	ND		175	SF	N	N	0								

1	Room 114	61.5	floor tile adhesive (sample 61)	M	ND		175	SF	N	N	0								
1	Room 115	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2		10%	15%					
1	Room 115	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 115	35	wall plaster	S	ND			SF	F	N	0								
1	Room 115	61	12"x12" grey w/black & cream FT	M	ND		70	SF	N	N	0								
1	Room 115	61.5	floor tile adhesive (sample 61)	M	ND		70	SF	N	N	0								
1	Room 115	82	12"x12" pegboard CT	M	ND		130	SF	F	N	0								
1	Room 115	82.5	ceiling tile adhesive (sample 82)	M		Pos	130	SF	N	N	1			3%					
1	Room 116	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 116	35	wall plaster	S	ND			SF	F	N	0								
1	Room 116	60	12"x12" cream w/beige FT	M	ND		6	SF	N	N	0								
1	Room 116	60.5	floor tile adhesive (sample 60)	M		Pos	6	SF	N	N	1			3%					
1	Room 117	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 117	35	wall plaster	S	ND			SF	F	N	0								
1	Room 117	61	12"x12" grey w/black & cream FT	M	ND		6	SF	N	N	0								
1	Room 117	61.5	floor tile adhesive (sample 61)	M	ND		6	SF	N	N	0								
1	Room 118	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 118	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 118	35	wall plaster	S	ND			SF	F	N	0								
1	Room 120	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 120	10	<4" fibrous PFI on FG	T	ND		6	EA	F	N	0								
1	Room 120	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 120	35	wall plaster	S	ND			SF	F	N	0								
1	Room 120	81	12"x12" pinhole fissure CT	M	ND		1500	SF	F	N	0								
1	Room 120	81.5	ceiling tile adhesive (sample 81)	M		Pos	1500	SF	N	N	1			3%					
1	Room 125	9	<4" fiberglass PI	T	ND			LF	F	N	0								
1	Room 125	10	<4" fibrous PFI on FG	T	ND		2	EA	F	N	0								
1	Room 125	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 125	35	wall plaster	S	ND			SF	F	N	0								
1	Room 125	41	9"x9" black & red FT	M		Pos	750	SF	N	N	1			5%					
1	Room 125	41.5	floor tile adhesive (sample 41)	M		Pos	750	SF	N	N	1								

1	Room 125	80	12"x12" smooth white CT	M	ND		750	SF	F	N	0									
1	Room 125	80.5	ceiling tile adhesive (sample 80)	M		Pos	750	SF	N	N	1									5%
1	Room 131	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2									10% 15%
1	Room 131	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 131	35	wall plaster	S	ND			SF	F	N	0									
1	Room 131	41	9"x9" black & red FT	M		Pos	190	SF	N	N	1									5%
1	Room 131	41.5	floor tile adhesive (sample 41)	M		Pos	190	SF	N	N	1									
1	Room 131	80	12"x12" smooth white CT	M	ND		190	SF	F	N	0									
1	Room 131	80.5	ceiling tile adhesive (sample 80)	M		Pos	190	SF	N	N	1									5%
1	Room 131A	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 131A	35	wall plaster	S	ND			SF	F	N	0									
1	Room 131A	41	9"x9" black & red FT	M		Pos	180	SF	N	N	1									5%
1	Room 131A	41.5	floor tile adhesive (sample 41)	M		Pos	180	SF	N	N	1									
1	Room 131A	80	12"x12" smooth white CT	M	ND		180	SF	F	N	0									
1	Room 131A	80.5	ceiling tile adhesive (sample 80)	M		Pos	180	SF	N	N	1									5%
1	Room 131B	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 131B	35	wall plaster	S	ND			SF	F	N	0									
1	Room 131B	41	9"x9" black & red FT	M		Pos	6	SF	N	N	1									5%
1	Room 131B	41.5	floor tile adhesive (sample 41)	M		Pos	6	SF	N	N	1									
1	Room 131C	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 131C	35	wall plaster	S	ND			SF	F	N	0									
1	Room 131C	41	9"x9" black & red FT	M		Pos	60	SF	N	N	1									5%
1	Room 131C	41.5	floor tile adhesive (sample 41)	M		Pos	60	SF	N	N	1									
1	Room 131C	80	12"x12" smooth white CT	M	ND		60	SF	F	N	0									
1	Room 131C	80.5	ceiling tile adhesive (sample 80)	M		Pos	60	SF	N	N	1									5%
1	Room 132	34	ceiling plaster	S	ND			SF	F	N	0									
1	Room 132	35	wall plaster	S	ND			SF	F	N	0									
1	Room 132(hatch)		inaccessible																	
1	Room 134	35	wall plaster	S	ND			SF	F	N	0									
1	Room 134	39	sheetrock & taping compound	M	ND			SF	F	N	0									

1	Room 134(hatch)		inaccessible																
1	Room 134A	39	sheetrock & taping compound	M	ND			SF	F	N	0								
1	Room 136	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 136	35	wall plaster	S	ND			SF	F	N	0								
1	Room 136	41	9"x9" black & red FT	M		Pos	128	SF	N	N	1							5%	
1	Room 136	41.5	floor tile adhesive (sample 41)	M		Pos	128	SF	N	N	1								
1	Room 137	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2							10%	15%
1	Room 137	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2							10%	
1	Room 137	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 137	35	wall plaster	S	ND			SF	F	N	0								
1	Room 137	41	9"x9" black & red FT	M		Pos	128	SF	N	N	1							5%	
1	Room 137	41.5	floor tile adhesive (sample 41)	M		Pos	128	SF	N	N	1								
1	Room 138	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 138	35	wall plaster	S	ND			SF	F	N	0								
1	Room 138	95	canvass vibration joint	M	ND		1	EA	N	N	0								
1	Room 139	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 139	35	wall plaster	S	ND			SF	F	N	0								
1	Room 139	41	9"x9" black & red FT	M		Pos	45	SF	N	N	1							5%	
1	Room 139	41.5	floor tile adhesive (sample 41)	M		Pos	45	SF	N	N	1								
1	Room 140	34	ceiling plaster	S	ND			SF	F	N	0								
1	Room 140	35	wall plaster	S	ND			SF	F	N	0								
1	Room 140	41	9"x9" black & red FT	M		Pos	1000	SF	N	N	1							5%	
1	Room 140	41.5	floor tile adhesive (sample 41)	M		Pos	1000	SF	N	N	1								
1	Room 140(h	35	wall plaster	S	ND			SF	F	N	0								
1	Room 140(h	37	clay tile mortar	M	ND			SF	F	N	0								
2	Corridor Eas	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2							10%	15%
2	Corridor Eas	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2							10%	
2	Corridor Eas	34	ceiling plaster	S	ND			SF	F	N	0								

2	Corridor Eas	35	wall plaster	S	ND			SF	F	N	0								
2	Corridor Eas	41	9"x9" black & red FT	M		Pos	780	SF	N	N	1								5%
2	Corridor Eas	41.5	floor tile adhesive (sample 41)	M		Pos	780	SF	N	N	1								
2	Corridor Eas	80	12"x12" smooth white CT	M	ND		780	SF	F	N	0								
2	Corridor Eas	80.5	ceiling tile adhesive (sample 80)	M		Pos	780	SF	N	N	1								5%
2	Corridor We	9	<4" fiberglass PI	T	ND			LF	F	N	0								
2	Corridor We	34	ceiling plaster	S	ND			SF	F	N	0								
2	Corridor We	35	wall plaster	S	ND			SF	F	N	0								
2	Corridor We	41	9"x9" black & red FT	M		Pos	480	SF	N	N	1								5%
2	Corridor We	41.5	floor tile adhesive (sample 41)	M		Pos	480	SF	N	N	1								
2	Corridor We	80	12"x12" smooth white CT	M	ND		480	SF	F	N	0								
2	Corridor We	80.5	ceiling tile adhesive (sample 80)	M		Pos	480	SF	N	N	1								5%
2	Room 200	9	<4" fiberglass PI	T	ND			LF	F	N	0								
2	Room 200	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 200	35	wall plaster	S	ND			SF	F	N	0								
2	Room 200A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 200A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 200B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 200B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 200C	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 200C	35	wall plaster	S	ND			SF	F	N	0								
2	Room 200C(hatch)		see Room 202C(hatch)																
2	Room 201	9	<4" fiberglass PI	T	ND			LF	F	N	0								
2	Room 201	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 201	35	wall plaster	S	ND			SF	F	N	0								
2	Room 201A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 201A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 201C	34	ceiling plaster	S	ND			SF	F	N	0								

2	Room 201C	35	wall plaster	S	ND			SF	F	N	0										
2	Room 202	9	<4" fiberglass PI	T	ND			LF	F	N	0										
2	Room 202	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 202	35	wall plaster	S	ND			SF	F	N	0										
2	Room 202B	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 202B	35	wall plaster	S	ND			SF	F	N	0										
2	Room 202C	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 202C	35	wall plaster	S	ND			SF	F	N	0										
2	Room 202C	3	<4" aircell PI(assumed)	T		Pos	15	LF	F	N	2										
2	Room 202C	4	<4" fibrous PFI on aircell(assumed)	T		Pos	4	EA	F	N	2										
2	Room 202C	5	<4" felt with tar PI	T		Pos	8	LF	F	N	2									5%	
2	Room 202C	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	N	2									10%	3%
2	Room 202C	35	wall plaster	S	ND			SF	F	N	0										
2	Room 202C(hatch)		felt debris	M		Pos	2	SF	F	H	4										
2	Room 203	9	<4" fiberglass PI	T	ND			LF	F	N	0										
2	Room 203	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 203	35	wall plaster	S	ND			SF	F	N	0										
2	Room 203B	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 203B	35	wall plaster	S	ND			SF	F	N	0										
2	Room 204	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2									10%	15%
2	Room 204	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2									10%	
2	Room 204	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 204	35	wall plaster	S	ND			SF	F	N	0										
2	Room 204A	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 204A	35	wall plaster	S	ND			SF	F	N	0										
2	Room 205	34	ceiling plaster	S	ND			SF	F	N	0										
2	Room 205	35	wall plaster	S	ND			SF	F	N	0										

2	Room 205A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 205A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 206	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2		10%	15%					
2	Room 206	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%					
2	Room 206	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 206	35	wall plaster	S	ND			SF	F	N	0								
2	Room 206A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 206A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 207	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2		10%	15%					
2	Room 207	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%					
2	Room 207	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 207	35	wall plaster	S	ND			SF	F	N	0								
2	Room 207A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 207A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 208 -	5	<4" felt with tar PI	T		Pos	10	LF	F	N	2			5%					
2	Room 208 -	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2			10%		3%			
2	Room 208	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 208	35	wall plaster	S	ND			SF	F	N	0								
2	Room 208A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 208A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 208A	41	9"x9" black & red FT	M		Pos	8	SF	N	N	1			5%					
2	Room 208A	41.5	floor tile adhesive (sample 41)	M		Pos	8	SF	N	N	1								
2	Room 208B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 208B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 209	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 209	35	wall plaster	S	ND			SF	F	N	0								
2	Room 209A	34	ceiling plaster	S	ND			SF	F	N	0								

2	Room 209A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 210	1	<4" white fibrous PI	T		Pos	20	LF	F	N	2		10%	15%					
2	Room 210	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2			10%					
2	Room 210	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 210	35	wall plaster	S	ND			SF	F	N	0								
2	Room 210A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 210A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 211	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2		10%	15%					
2	Room 211	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%					
2	Room 211	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 211	35	wall plaster	S	ND			SF	F	N	0								
2	Room 211A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 211A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 212	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 212	35	wall plaster	S	ND			SF	F	N	0								
2	Room 212A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 212A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 213	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2		10%	15%					
2	Room 213	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2			10%					
2	Room 213	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 213	35	wall plaster	S	ND			SF	F	N	0								
2	Room 213A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 213A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 214	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 214	35	wall plaster	S	ND			SF	F	N	0								
2	Room 214	41	9"x9" black & red FT	M		Pos	225	SF	N	N	1			5%					
2	Room 214	41.5	floor tile adhesive (sample 41)	M		Pos	225	SF	N	N	1								
2	Room 214	80	12"x12" smooth white CT	M	ND		225	SF	F	N	0								

2	Room 214	80.5	ceiling tile adhesive (sample 80)	M		Pos	225	SF	N	N	1				5%				
2	Room 215	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			10%	15%				
2	Room 215	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 215	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 215	35	wall plaster	S	ND			SF	F	N	0								
2	Room 215A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 215A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 215B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 215B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 216	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			10%	15%				
2	Room 216	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 216	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 216	35	wall plaster	S	ND			SF	F	N	0								
2	Room 216A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 216A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 217	1	<4" white fibrous PI	T		Pos	10	LF	F	L	3			10%	15%				
2	Room 217	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 217	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 217	35	wall plaster	S	ND			SF	F	N	0								
2	Room 217A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 217A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 218	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			10%	15%				
2	Room 218	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 218	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 218	35	wall plaster	S	ND			SF	F	N	0								
2	Room 218A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 218A	35	wall plaster	S	ND			SF	F	N	0								

2	Room 218B	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 218B	35	wall plaster	S	ND			SF	F	N	0								
2	Room 219	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 219	35	wall plaster	S	ND			SF	F	N	0								
2	Room 219A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 219A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220	40	baseboard adhesive	M	ND			LF	N	N	0								
2	Room 220	62	12"x12" tan w/brown & cream FT	M	ND		120	SF	N	N	0								> 1%
2	Room 220	62.5	floor tile adhesive (sample 62)	M	ND		120	SF	N	N	0								
2	Room 220A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 220A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 220A	41	9"x9" black & red FT	M		Pos	8	SF	N	N	1								5%
2	Room 220A	41.5	floor tile adhesive (sample 41)	M		Pos	8	SF	N	N	1								
2	Room 221	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2								10%
2	Room 221	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2								15%
2	Room 221	34	ceiling plaster	S	ND			SF	F	N	0								10%
2	Room 221	35	wall plaster	S	ND			SF	F	N	0								
2	Room 221A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 221A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 222	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2								10%
2	Room 222	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2								15%
2	Room 222	34	ceiling plaster	S	ND			SF	F	N	0								10%
2	Room 222	35	wall plaster	S	ND			SF	F	N	0								
2	Room 222A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 222A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 223	34	ceiling plaster	S	ND			SF	F	N	0								

2	Room 223	35	wall plaster	S	ND			SF	F	N	0								
2	Room 223A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 223A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 225	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			10%	15%				
2	Room 225	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 225	35	wall plaster	S	ND			SF	F	N	0								
2	Room 225A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 225A	35	wall plaster	S	ND			SF	F	N	0								
2	Room 226	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 226	35	wall plaster	S	ND			SF	F	N	0								
2	Room 227	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 227	35	wall plaster	S	ND			SF	F	N	0								
2	Room 229	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2			10%	15%				
2	Room 229	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 229	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 229	35	wall plaster	S	ND			SF	F	N	0								
2	Room 229	41	9"x9" black & red FT	M		Pos	600	SF	N	N	1				5%				
2	Room 229	41.5	floor tile adhesive (sample 41)	M		Pos	600	SF	N	N	1								
2	Room 229	80	12"x12" smooth white CT	M	ND		600	SF	F	N	0								
2	Room 229	80.5	ceiling tile adhesive (sample 80)	M		Pos	600	SF	N	N	1				5%				
2	Room 233	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2			10%	15%				
2	Room 233	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 233	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 233	35	wall plaster	S	ND			SF	F	N	0								
2	Room 233	80	12"x12" smooth white CT	M	ND		320	SF	F	N	0								
2	Room 233	80.5	ceiling tile adhesive (sample 80)	M		Pos	320	SF	N	N	1				5%				
2	Room 235	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 235	35	wall plaster	S	ND			SF	F	N	0								
2	Room 235	80	12"x12" smooth white CT	M	ND		480	SF	F	N	0								

2	Room 235	80.5	ceiling tile adhesive (sample 80)	M		Pos	480	SF	N	N	1				5%				
2	Room 236	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 236	35	wall plaster	S	ND			SF	F	N	0								
2	Room 237	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2			10%	15%				
2	Room 237	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2				10%				
2	Room 237	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 237	35	wall plaster	S	ND			SF	F	N	0								
2	Room 237	80	12"x12" smooth white CT	M	ND		210	SF	F	N	0								
2	Room 237	80.5	ceiling tile adhesive (sample 80)	M		Pos	210	SF	N	N	1				5%				
2	Room 238	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 238	35	wall plaster	S	ND			SF	F	N	0								
2	Room 238A	34	ceiling plaster	S	ND			SF	F	N	0								
2	Room 238A	35	wall plaster	S	ND			SF	F	N	0								
3	Corridor Eas	35	wall plaster	S	ND			SF	F	N	0								
3	Corridor Eas	34	ceiling plaster	S	ND			SF	F	N	0								
3	Corridor Eas	35	wall plaster	S	ND			SF	F	N	0								
3	Corridor Eas	41	9"x9" black & red FT	M		Pos	850	SF	N	N	1				5%				
3	Corridor Eas	41.5	floor tile adhesive (sample 41)	M		Pos	850	SF	N	N	1								
3	Corridor Eas	80	12"x12" smooth white CT	M	ND		850	SF	F	N	0								
3	Corridor Eas	80.5	ceiling tile adhesive (sample 80)	M		Pos	850	SF	N	N	1				5%				
3	Corridor We	9	<4" fiberglass PI	T	ND			LF	F	N	0								
3	Corridor We	34	ceiling plaster	S	ND			SF	F	N	0								
3	Corridor We	35	wall plaster	S	ND			SF	F	N	0								
3	Corridor We	41	9"x9" black & red FT	M		Pos	510	SF	N	N	1				5%				
3	Corridor We	41.5	floor tile adhesive (sample 41)	M		Pos	510	SF	N	N	1								
3	Corridor We	80	12"x12" smooth white CT	M	ND		510	SF	F	N	0								
3	Corridor We	80.5	ceiling tile adhesive (sample 80)	M		Pos	510	SF	N	N	1				5%				
3	Room 300	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 300	35	wall plaster	S	ND			SF	F	N	0								

3	Room 300A	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 300A	35	wall plaster	S	ND			SF	F	N	0									
3	Room 300B	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 300B	35	wall plaster	S	ND			SF	F	N	0									
3	Room 300C	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 300C	35	wall plaster	S	ND			SF	F	N	0									
3	Room 300C(hatch)		see Room 302C(hatch)																	
3	Room 301	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 301	35	wall plaster	S	ND			SF	F	N	0									
3	Room 301A	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 301A	35	wall plaster	S	ND			SF	F	N	0									
3	Room 301A	95	canvass vibration joint	M	ND			EA	N	N	0									
3	Room 301C	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 301C	35	wall plaster	S	ND			SF	F	N	0									
3	Room 302	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 302	35	wall plaster	S	ND			SF	F	N	0									
3	Room 302B	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 302B	35	wall plaster	S	ND			SF	F	N	0									
3	Room 302C	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 302C	35	wall plaster	S	ND			SF	F	N	0									
3	Room 302C	5	<4" felt with tar PI	T		Pos	14	LF	F	N	2									5%
3	Room 302C	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	L	3									10%
3	Room 302C	35	wall plaster	S	ND			SF	F	N	0									
3	Room 302C(hatch)		felt debris	M		Pos	2	SF	F	H	4									
3	Room 303	34	ceiling plaster	S	ND			SF	F	N	0									

3	Room 303	35	wall plaster	S	ND			SF	F	N	0								
3	Room 303(hatch)		inaccessible																
3	Room 303B	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 303B	35	wall plaster	S	ND			SF	F	N	0								
3	Room 304	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 304	35	wall plaster	S	ND			SF	F	N	0								
3	Room 304A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 304A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 305	35	wall plaster	S	ND			SF	F	N	0								
3	Room 305	35	wall plaster	S	ND			SF	F	N	0								
3	Room 305A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 305A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 306	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 306	35	wall plaster	S	ND			SF	F	N	0								
3	Room 306A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 306A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 307	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 307	35	wall plaster	S	ND			SF	F	N	0								
3	Room 307A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 307A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 308	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 308	35	wall plaster	S	ND			SF	F	N	0								
3	Room 308A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 308A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 308A	41	9"x9" black & red FT	M		Pos	6	SF	N	N	1							5%	

3	Room 314	35	wall plaster	S	ND			SF	F	N	0								
3	Room 314	41	9"x9" black & red FT	M		Pos	264	SF	N	N	1							5%	
3	Room 314	41.5	floor tile adhesive (sample 41)	M		Pos	264	SF	N	N	1								
3	Room 314	80	12"x12" smooth white CT	M	ND		264	SF	F	N	0								
3	Room 314	80.5	ceiling tile adhesive (sample 80)	M		Pos	264	SF	N	N	1							5%	
3	Room 315	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 315	35	wall plaster	S	ND			SF	F	N	0								
3	Room 315A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 315A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 315B	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 315B	35	wall plaster	S	ND			SF	F	N	0								
3	Room 316	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 316	35	wall plaster	S	ND			SF	F	N	0								
3	Room 316A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 316A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 317	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 317	35	wall plaster	S	ND			SF	F	N	0								
3	Room 317A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 317A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 318	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 318	35	wall plaster	S	ND			SF	F	N	0								
3	Room 318A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 318A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 318B	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 318B	35	wall plaster	S	ND			SF	F	N	0								
3	Room 318B	95	canvass vibration joint	M	ND			EA	N	N	0								

3	Room 319	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 319	35	wall plaster	S	ND			SF	F	N	0								
3	Room 319A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 319A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 320	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 320	35	wall plaster	S	ND			SF	F	N	0								
3	Room 320A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 320A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 320A	41	9"x9" black & red FT	M		Pos	6	SF	N	N	1							5%	
3	Room 320A	41.5	floor tile adhesive (sample 41)	M		Pos	6	SF	N	N	1								
3	Room 321	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 321	35	wall plaster	S	ND			SF	F	N	0								
3	Room 321A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 321A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 322	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 322	35	wall plaster	S	ND			SF	F	N	0								
3	Room 322A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 322A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 323	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 323	35	wall plaster	S	ND			SF	F	N	0								
3	Room 323A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 323A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 325	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 325	35	wall plaster	S	ND			SF	F	N	0								
3	Room 325A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 325A	35	wall plaster	S	ND			SF	F	N	0								

3	Room 327		inaccessible																	
3	Room 331	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331	40	baseboard adhesive	M	ND		LF	N	N	0										
3	Room 331A	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331A	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331B	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331B	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331C	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331C	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331D	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331D	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331E	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331E	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331E	40	baseboard adhesive	M	ND		LF	N	N	0										
3	Room 331F	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331F	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331F	40	baseboard adhesive	M	ND		LF	N	N	0										
3	Room 331G	9	<4" fiberglass PI	T	ND		LF	F	N	0										
3	Room 331G	34	ceiling plaster	S	ND		SF	F	N	0										
3	Room 331G	35	wall plaster	S	ND		SF	F	N	0										
3	Room 331G	5	<4" felt with tar PI	T		Pos	16	LF	F	N	2									5%
3	Room 331G	6	<4" fibrous PFI on felt	T		Pos	8	EA	F	N	2									10%
3	Room 331G	35	wall plaster	S	ND			SF	F	N	0									
3	Room 331H	34	ceiling plaster	S	ND			SF	F	N	0									
3	Room 331H	35	wall plaster	S	ND			SF	F	N	0									

3	Room 334	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 334	35	wall plaster	S	ND			SF	F	N	0								
3	Room 334	95	canvass vibration joint	M	ND			EA	N	N	0								
3	Room 335	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 335	35	wall plaster	S	ND			SF	F	N	0								
3	Room 335A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 335A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 335B	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 335B	35	wall plaster	S	ND			SF	F	N	0								
3	Room 335C	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 335C	35	wall plaster	S	ND			SF	F	N	0								
3	Room 336	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 336	35	wall plaster	S	ND			SF	F	N	0								
3	Room 337	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 337	35	wall plaster	S	ND			SF	F	N	0								
3	Room 337	81	12"x12" pinhole fissure CT	M	ND		120	SF	F	N	0								
3	Room 337	81.5	ceiling tile adhesive (sample 81)	M		Pos	120	SF	N	N	1							3%	
3	Room 337A	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 337A	35	wall plaster	S	ND			SF	F	N	0								
3	Room 337A	81	12"x12" pinhole fissure CT	M	ND		132	SF	F	N	0								
3	Room 337A	81.5	ceiling tile adhesive (sample 81)	M		Pos	132	SF	N	N	1							3%	
3	Room 337B	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 337B	35	wall plaster	S	ND			SF	F	N	0								
3	Room 337B	81	12"x12" pinhole fissure CT	M	ND		132	SF	F	N	0								
3	Room 337B	81.5	ceiling tile adhesive (sample 81)	M		Pos	132	SF	N	N	1							3%	
3	Room 337C	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 337C	35	wall plaster	S	ND			SF	F	N	0								

3	Room 337D	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 337D	35	wall plaster	S	ND		SF	F	N	0									
3	Room 337E	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 337E	35	wall plaster	S	ND		SF	F	N	0									
3	Room 337F	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 337F	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338	83	12"x12" computer board CT	M	ND	336	SF	F	N	0									
3	Room 338	83.5	ceiling tile adhesive (sample 83)	M	ND	336	SF	N	N	0									
3	Room 338A	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338A	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338B	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338B	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338C	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338C	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338D	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338D	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338D	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338D	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338E	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338E	35	wall plaster	S	ND		SF	F	N	0									
3	Room 338E	95	canvass vibration joint	M	ND		EA	N	N	0									
3	Room 338E(hatch)		inaccessible																
3	Room 338F	34	ceiling plaster	S	ND		SF	F	N	0									
3	Room 338F	35	wall plaster	S	ND		SF	F	N	0									

3	Room 338G	34	ceiling plaster	S	ND			SF	F	N	0								
3	Room 338G	35	wall plaster	S	ND			SF	F	N	0								