

Fir	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
B	Elevator Lob	24	ceiling plaster	S	ND			SF	F	N	0	6/28/98	BLA/DCK							061-94-072
B	Elevator Lob	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2	78	brown pipe putty	M	ND		4	SF	N	N	0	6/27/94	BLA/DCK							
B	Room 2A	1	<4" white fibrous PI (8/16/90)	T		Pos	93	LF	F	N	2	6/28/98	BLA/DCK	25%						061-94-072
B	Room 2A	2	<4" PFI on white fibrous (8/16/90)	T		Pos	82	EA	F	N	2	6/27/94	BLA/DCK	10%	20%					
B	Room 2A	9	<4" fibrous PFI on FG	T	ND		10	EA	F	N	0	6/27/94	BLA/DCK							
B	Room 2A	10	4"-8" white fibrous PI	T		Pos	76	LF	F	N	2	6/27/94	BLA/DCK	45%	5%					
B	Room 2A	11	4"-8" PFI on white fibrous	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK		55%					
B	Room 2A	12	4"-8" aircell PI	T		Pos	115	LF	F	N	2	6/27/94	BLA/DCK							
B	Room 2A	13	4"-8" fibrous PFI on aircell	T		Pos	20	EA	F	N	2	6/27/94	BLA/DCK							
B	Room 2A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2A	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2A	65	canvas vibration joint	M	ND		3	EA	N	N	0	6/27/94	BLA/DCK							
B	Room 2B	1	<4" white fibrous PI (8/16/90)	T		Pos	70	LF	F	N	2	6/27/94	BLA/DCK	25%						
B	Room 2B	2	<4" PFI on white fibrous (8/16/90)	T		Pos	36	EA	F	N	2	6/27/94	BLA/DCK	10%	20%					
B	Room 2B	3	<4" aircell PI (8/16/90)	T		Pos	95	LF	F	N	2	6/27/94	BLA/DCK		70%					
B	Room 2B	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	26	EA	F	N	2	6/27/94	BLA/DCK		75%					
B	Room 2B	7	<4" fiberglass w/tar PI	T	ND		8	LF	F	N	0	6/27/94	BLA/DCK							
B	Room 2B	8	<4" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK	15%	10%					
B	Room 2B	10	4"-8" white fibrous PI	T		Pos	7	LF	F	N	2	6/27/94	BLA/DCK	45%	5%					
B	Room 2B	11	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		55%					
B	Room 2B	12	4"-8" aircell PI	T		Pos	33	LF	F	N	2	6/27/94	BLA/DCK							
B	Room 2B	13	4"-8" fibrous PFI on aircell	T		Pos	19	EA	F	N	2	6/27/94	BLA/DCK							
B	Room 2B	19	9"-14" white fibrous PI	T		Pos	15	LF	F	N	2	6/27/94	BLA/DCK	10%	5%					
B	Room 2B	20	9"-14" PFI on white fibrous	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK	20%	10%					
B	Room 2B	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK							
B	Room 2B	74	4"-8" pink fibrous PI	T		Pos	20	LF	F	N	2	6/27/94	BLA/DCK	10%	10%					
B	Room 2B	75	4"-8" PFI on pink fibrous	T		Pos	8	LF	F	N	2	6/27/94	BLA/DCK		10%					
B	Room 2B	76	<4" blue fibrous PI	T		Pos	3	LF	F	N	2	6/27/94	BLA/DCK	20%	5%					
B	Room 2B	77	<4" PFI on blue fibrous PI	T	ND		6	EA	F	N	0	6/27/94	BLA/DCK							

B	Room S3	64	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
B	Room S4	1	<4" white fibrous PI (8/16/90)	T		Pos	20	LF	F	N	2	6/27/94	BLA/DCK	25%					
B	Room S4	2	<4" PFI on white fibrous (8/16/90)	T		Pos	20	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
B	Room S4	3	<4" aircell PI (8/16/90)	T		Pos	20	LF	F	N	2	6/27/94	BLA/DCK		70%				
B	Room S4	5	<4" felt with tar PI	T		Pos	25	LF	F	N	2	6/27/94	BLA/DCK		5%				
B	Room S4	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK		10%				
B	Room S4	7	<4" fiberglass w/tar PI	T	ND		42	LF	F	N	0	6/27/94	BLA/DCK						
B	Room S4	8	<4" fibrous PFI on FG w/tar	T		Pos	12	EA	F	N	2	6/27/94	BLA/DCK	15%	10%				
B	Room S4	9	<4" fibrous PFI on FG	T	ND		7	EA	F	N	0	6/27/94	BLA/DCK						
B	Room S4	10	4"-8" white fibrous PI	T		Pos	90	LF	F	N	2	6/27/94	BLA/DCK	45%	5%				
B	Room S4	11	4"-8" PFI on white fibrous	T		Pos	17	EA	F	N	2	6/27/94	BLA/DCK		55%				
B	Room S4	12	4"-8" aircell PI	T		Pos	258	LF	F	N	2	6/27/94	BLA/DCK						
B	Room S4	13	4"-8" fibrous PFI on aircell	T		Pos	60	EA	F	N	2	6/27/94	BLA/DCK						
B	Room S4	16	4"-8" fiberglass w/tar PI	T	ND		55	LF	F	N	0	6/27/94	BLA/DCK						
B	Room S4	17	4"-8" fibrous PFI on FG w/tar	T	ND		10	EA	F	N	0	6/27/94	BLA/DCK						
B	Room S4	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
B	Room S5		No Suspect Material Found																
B	Room S6	1	<4" white fibrous PI (8/16/90)	T		Pos	3	LF	F	N	2	6/27/94	BLA/DCK	25%					
B	Room S6	2	<4" PFI on white fibrous (8/16/90)	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
B	Room S6	3	<4" aircell PI (8/16/90)	T		Pos	62	LF	F	N	2	6/27/94	BLA/DCK		70%				
B	Room S6	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	23	EA	F	N	2	6/27/94	BLA/DCK		75%				
B	Room S6	7	<4" fiberglass w/tar PI	T	ND		60	LF	F	N	0	6/27/94	BLA/DCK						
B	Room S6	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
B	Room S6	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
B	Room S6	34	9"x9" gray w/white streaks floor tile	M		Pos	560	SF	N	N	1	6/27/94	BLA/DCK		10%				
B	Room S6	66	black lab top	M		Pos	20	SF	N	N	1	6/27/94	BLA/DCK		20%				
B	Room S6A	3	<4" aircell PI (8/16/90)	T		Pos	24	LF	F	N	2	6/27/94	BLA/DCK		70%				
B	Room S6A	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK		75%				
B	Room S6A	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
B	Room S6A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
B	Room S6A	34	9"x9" gray w/white streaks floor tile	M		Pos	130	SF	N	N	1	6/27/94	BLA/DCK		10%				
B	Room S6B	7	<4" fiberglass w/tar PI	T	ND		12	LF	F	N	0	6/27/94	BLA/DCK						

B	Stair Lobby/f	7	<4" fiberglass w/tar PI	T	ND		55	LF	F	N	0	6/27/94	BLA/DCK						
B	Stair Lobby/f	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
B	Stair Lobby/f	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
	Elevator Sh	3	<4" aircell PI (8/16/90)	T		Pos	100	LF	F	N	2	6/27/94	BLA/DCK		70%				
	Elevator Sh	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK		75%				
	Elevator Sh	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
	Elevator Sh	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
	Elevator	36	4"x4" blue floor tile	M	ND		27	SF	N	N	0	6/27/94	BLA/DCK						
	Elevator	36.5	floor tile adhesive (sample 36)	M	ND		27	SF	N	N	0	6/27/94	BLA/DCK						
	Elevator	37	4"x4" grey floor tile	M	ND		8	SF	N	N	0	6/27/94	BLA/DCK						
	Elevator	37.5	floor tile adhesive (sample 37)	M	ND		8	SF	N	N	0	6/27/94	BLA/DCK						
	North Stairs	2	<4" PFI on white fibrous (8/16/90)	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
	North Stairs	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
	North Stairs	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
	North Stairs	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
	North Stairs		note recessed heater		ND			EA				6/27/94	BLA/DCK						
	North Stairs	70	black linoleum	M	ND		330	SF	N	N	0	6/27/94	BLA/DCK						
	South Stairs	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
	South Stairs	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
	South Stairs	32	9"x9" brown floor tile	M		Pos	100	SF	N	N	1	6/27/94	BLA/DCK		10%				
	South Stairs	32.5	floor tile adhesive (sample 32)	M	ND		100	SF	N	N	0	6/27/94	BLA/DCK						
	South Stairs	35	12"x36" black stair tile	M		Pos	145	SF	N	N	1	6/27/94	BLA/DCK		3%				
	South Stairs	35.5	floor tile adhesive (sample 35)	M		Pos	145	SF	N	N	1	6/27/94	BLA/DCK		3%				
	South Stairs	40	12"x12" rust w/brn&wht mottling FT	M		Pos	35	SF	N	N	1	6/27/94	BLA/DCK		2%				
	South Stairs	40.5	floor tile adhesive (sample 40)	M		Pos	35	SF	N	N	1	6/27/94	BLA/DCK		2%				
1	Elevator Lob	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Elevator Lob	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						

1	Foyer&Vesti	1	<4" white fibrous PI (8/16/90)	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK	25%					
1	Foyer&Vesti	2	<4" PFI on white fibrous (8/16/90)	T		Pos	5	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
1	Foyer&Vesti	3	<4" aircell PI (8/16/90)	T		Pos	25	LF	F	N	2	6/27/94	BLA/DCK		70%				
1	Foyer&Vesti	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	1	EA	F	N	2	6/27/94	BLA/DCK		75%				
1	Foyer&Vesti	9	<4" fibrous PFI on FG	T	ND		6	EA	F	N	0	6/27/94	BLA/DCK						
1	Foyer&Vesti	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Foyer&Vesti	73	tar on fiberboard	M		Pos	200	SF	N	N	1	6/27/94	BLA/DCK						
1	Foyer&Vesti	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Foyer&Vesti	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Foyer&Vestibule		note recessed heater		ND		1	EA				6/27/94	BLA/DCK						
1	Lobby	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Lobby	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	North Catwa	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	North Catwa	61	ceramic tile mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
1	Room 100(A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100(A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100(A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
1	Room 100(A	51	12"x12" peghole ceiling tile	M	ND		1500	SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100(A	51.5	ceiling tile adhesive (sample 51)	M	ND		1500	SF	N	N	0	6/27/94	BLA/DCK						
1	Room 100(A	67	stage curtain (black)	M	ND		1	EA	N	N	0	6/27/94	BLA/DCK						
1	Room 100(A	68	stage curtain (peach)	M	ND		1	EA	N	N	0	6/27/94	BLA/DCK						
1	Room 100(A	69	brown linoleum	M	ND		375	SF	N	N	0	6/27/94	BLA/DCK						
1	Room 100B	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100B	64	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
1	Room 100B	72	tarpaper duct insulation	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK		20%				
1	Room 100B	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100B	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100C	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100C	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						

1	Room 100E	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100E	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100E	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 100E	72	tarpaper duct insulation	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK		20%				
1	Room 101 (E)	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 101 (E)	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 101 (E)	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
1	Room 101 (E)	52	12"x12" white rough ceiling tile	M	ND		300	SF	F	N	0	6/27/94	BLA/DCK						
1	Room 101 (E)	52.5	ceiling tile adhesive (sample 52)	M	ND		300	SF	N	N	0	6/27/94	BLA/DCK						
1	Room 101 (Bookshop)		note recessed heater		ND		1	EA				6/27/94	BLA/DCK						
1	Room 101	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 101	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 102	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 102	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 103	2	<4" PFI on white fibrous (8/16/90)	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
1	Room 103	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 103	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 103		note recessed heater		ND		1	EA				6/27/94	BLA/DCK						
1	Room 104	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 104	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 104	42	12"x12" white w/tan strks floor tile	M		Pos	50	SF	N	N	1	6/27/94	BLA/DCK		15%				
1	Room 104	42.5	floor tile adhesive (sample 42)	M		Pos	50	SF	N	N	1	6/27/94	BLA/DCK		25%				
1	Room 108	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 108	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 108	35	12"x36" black stair tile	M		Pos	25	SF	N	N	1	6/27/94	BLA/DCK		3%				
1	Room 108	35.5	floor tile adhesive (sample 35)	M		Pos	25	SF	N	N	1	6/27/94	BLA/DCK		3%				

1	Room 110	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 110	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 125 (N	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 125 (N	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Room 125 (N	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
1	Room 125 (N	69	brown linoleum	M	ND		5000	SF	N	N	0	6/27/94	BLA/DCK						
1	South Catwa	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	South Catwa	61	ceramic tile mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
1	Stair Lobby&	2	<4" PFI on white fibrous (8/16/90)	T		Pos	1	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
1	Stair Lobby&	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
1	Stair Lobby&	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	North Catwa	14	4"-8" felt with tar PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK		5%				
2	North Catwa	15	4"-8" fibrous PFI on felt	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		40%				
2	North Catwa	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	North Catwa	61	ceramic tile mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
2	Room 204	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 204	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 206	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 206	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 210 (N	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 210 (N	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 210 (N	70	black linoleum	M	ND		875	SF	N	N	0	6/27/94	BLA/DCK						
2	Room 210A	1	<4" white fibrous PI (8/16/90)	T		Pos	10	LF	F	N	2	6/27/94	BLA/DCK	25%					
2	Room 210A	2	<4" PFI on white fibrous (8/16/90)	T		Pos	5	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				
2	Room 210A	3	<4" aircell PI (8/16/90)	T		Pos	50	LF	F	N	2	6/27/94	BLA/DCK		70%				
2	Room 210A	4	<4" fibrous PFI on aircell (8/16/90)	T		Pos	5	EA	F	N	2	6/27/94	BLA/DCK		75%				
2	Room 210A	9	<4" fibrous PFI on FG	T	ND		20	EA	F	N	0	6/27/94	BLA/DCK						
2	Room 210A	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						

2	Room 210A	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 225(M	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 225(M	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	Room 225(M	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
2	Room 225(M	69	brown linoleum	M	ND		5000	SF	N	N	0	6/27/94	BLA/DCK						
2	South Catwa	14	4"-8" felt with tar PI	T		Pos	10	LF	F	N	2	6/27/94	BLA/DCK						5%
2	South Catwa	15	4"-8" fibrous PFI on felt	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK						40%
2	South Catwa	27	clay tile mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
2	South Catwa	61	ceramic tile mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	40	12"x12" rust w/brn&wht mottling FT	M		Pos	1275	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Hallway R-30	40.5	floor tile adhesive (sample 40)	M		Pos	1275	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Hallway R-30	51	12"x12" peghole ceiling tile	M	ND		1115	SF	F	N	0	6/27/94	BLA/DCK						
3	Hallway R-30	51.5	ceiling tile adhesive (sample 51)	M	ND		1115	SF	N	N	0	6/27/94	BLA/DCK						
3	Room 300	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 300	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 300	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 300	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
3	Room 300	40	12"x12" rust w/brn&wht mottling FT	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Room 300	40.5	floor tile adhesive (sample 40)	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Room 300	41	12"x12" brown w/drk brown strks FT	M	ND		30	SF	N	N	0	6/27/94	BLA/DCK						
3	Room 300	41.5	floor tile adhesive (sample 41)	M	ND		30	SF	N	N	0	6/27/94	BLA/DCK						
3	Room 300		note recessed heater		ND		1	EA				6/27/94	BLA/DCK						
3	Room 301	2	<4" PFI on white fibrous (8/16/90)	T		Pos	1	EA	F	N	2	6/27/94	BLA/DCK		10%				20%
3	Room 301	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 301	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 301	40	12"x12" rust w/brn&wht mottling FT	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Room 301	40.5	floor tile adhesive (sample 40)	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK						2%
3	Room 301		note recessed heater		ND		1	EA				6/27/94	BLA/DCK						

3	Room 302A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302A	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302A	40	12"x12" rust w/brn&wht mottling FT	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK						2%		
3	Room 302A	40.5	floor tile adhesive (sample 40)	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK							2%	
3	Room 302B	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302B	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302B	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 302B	40	12"x12" rust w/brn&wht mottling FT	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK							2%	
3	Room 302B	40.5	floor tile adhesive (sample 40)	M		Pos	120	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 303	2	<4" PFI on white fibrous (8/16/90)	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK	10%						20%	
3	Room 303	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 303	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 303	40	12"x12" rust w/brn&wht mottling FT	M		Pos	600	SF	N	N	1	6/27/94	BLA/DCK							2%	
3	Room 303	40.5	floor tile adhesive (sample 40)	M		Pos	600	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 303		note recessed heater		ND		2	EA				6/27/94	BLA/DCK								
3	Room 304	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 304	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 304	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 304	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK								
3	Room 304	40	12"x12" rust w/brn&wht mottling FT	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 304	40.5	floor tile adhesive (sample 40)	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 304	66	black lab top	M		Pos	50	SF	N	N	1	6/27/94	BLA/DCK								20%
3	Room 305	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 305	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 305	40	12"x12" rust w/brn&wht mottling FT	M		Pos	200	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 305	40.5	floor tile adhesive (sample 40)	M		Pos	200	SF	N	N	1	6/27/94	BLA/DCK								2%
3	Room 306	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 306	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK								
3	Room 306	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK								
3	Room 306	40	12"x12" rust w/brn&wht mottling FT	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK								2%

3	Room 306	40.5	floor tile adhesive (sample 40)	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 306A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306A	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306A	40	12"x12" rust w/brn&wht mottling FT	M		Pos	110	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 306A	40.5	floor tile adhesive (sample 40)	M		Pos	110	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 306B	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306B	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306B	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 306B	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						
3	Room 306B	40	12"x12" rust w/brn&wht mottling FT	M		Pos	200	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 306B	40.5	floor tile adhesive (sample 40)	M		Pos	200	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 307	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307	40	12"x12" rust w/brn&wht mottling FT	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 307	40.5	floor tile adhesive (sample 40)	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 307	51	12"x12" peghole ceiling tile	M	ND		400	SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307	51.5	ceiling tile adhesive (sample 51)	M	ND		400	SF	N	N	0	6/27/94	BLA/DCK						
3	Room 307A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307A	40	12"x12" rust w/brn&wht mottling FT	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 307A	40.5	floor tile adhesive (sample 40)	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 307A	51	12"x12" peghole ceiling tile	M	ND		180	SF	F	N	0	6/27/94	BLA/DCK						
3	Room 307A	51.5	ceiling tile adhesive (sample 51)	M	ND		180	SF	N	N	0	6/27/94	BLA/DCK						
3	Room 308	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 308	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 308	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 308	40	12"x12" rust w/brn&wht mottling FT	M		Pos	100	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 308	40.5	floor tile adhesive (sample 40)	M		Pos	100	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 310	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 310	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						

3	Room 310	40	12"x12" rust w/brn&wht mottling FT	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 310	40.5	floor tile adhesive (sample 40)	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 311	7	<4" fiberglass w/tar PI	T	ND		10	LF	F	N	0	6/27/94	BLA/DCK						
3	Room 311	8	<4" fibrous PFI on FG w/tar	T		Pos	14	EA	F	N	2	6/27/94	BLA/DCK	15%	10%				
3	Room 311	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 311	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 311	40	12"x12" rust w/brn&wht mottling FT	M		Pos	880	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 311	40.5	floor tile adhesive (sample 40)	M		Pos	880	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 320	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 320	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 324	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 324	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 328	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 328	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 328	40	12"x12" rust w/brn&wht mottling FT	M		Pos	70	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 328	40.5	floor tile adhesive (sample 40)	M		Pos	70	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 332	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 332	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 336	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 336	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						
3	Room 336	40	12"x12" rust w/brn&wht mottling FT	M		Pos	55	SF	N	N	1	6/27/94	BLA/DCK		2%				
3	Room 336	40.5	floor tile adhesive (sample 40)	M		Pos	55	SF	N	N	1	6/27/94	BLA/DCK		2%				
4	Penthouse	1	<4" white fibrous PI (8/16/90)	T		Pos	15	LF	F	L	3	6/27/94	BLA/DCK	25%					
4	Penthouse	2	<4" PFI on white fibrous (8/16/90)	T		Pos	4	EA	F	L	3	6/27/94	BLA/DCK	10%	20%				
4	Penthouse	26	red brick mortar	M	ND			SF	F	N	0	6/27/94	BLA/DCK						
4	Penthouse	64	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						
4	Penthouse	65	canvas vibration joint	M	ND		4	EA	N	N	0	6/27/94	BLA/DCK						