

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
B	Room 50	1	<4" white fibrous PI	T		Pos	220	LF	F	N	2	6/28/98	BLA/DCK	50%						061-94-074
B	Room 50	2	<4" PFI on white fibrous	T		Pos	45	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 50	7	<4" fiberglass w/tar PI	T	ND		150	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 50	8	<4" fibrous PFI on FG w/tar	T		Pos	26	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
B	Room 50	10	4"-8" white fibrous PI	T		Pos	100	LF	F	N	2	6/27/94	BLA/DCK	20%	15%					061-94-074
B	Room 50	11	4"-8" PFI on white fibrous	T	ND		50	EA	F	N	0	6/27/94	BLA/DCK				<1%			061-94-074
B	Room 50	11	4"-8" PFI on white fibrous	T	ND		1	EA	F	N	0	6/27/94	BLA/DCK				<1%			061-94-074
B	Room 50	19	9"-14" white fibrous PI	T		Pos	5	LF	F	N	2	6/27/94	BLA/DCK	25%	2%					061-94-074
B	Room 50	20	9"-14" PFI on white fibrous	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK	25%	2%					061-94-074
B	Room 50	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 50	72	galbestos	M		Pos	14	SF	N	N	1	6/27/94	BLA/DCK		40%					061-94-074
B	Room 60	1	<4" white fibrous PI	T		Pos	74	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 60	2	<4" PFI on white fibrous	T		Pos	48	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 60	9	<4" fibrous PFI on FG	T		Pos	21	EA	F	N	2	6/27/94	BLA/DCK	10%	20%					061-94-074
B	Room 60	10	4"-8" white fibrous PI	T		Pos	36	LF	F	N	2	6/27/94	BLA/DCK	20%	15%					061-94-074
B	Room 60	11	4"-8" PFI on white fibrous	T	ND		13	EA	F	N	0	6/27/94	BLA/DCK				<1%			061-94-074
B	Room 60	16	4"-8" fiberglass w/tar PI	T	ND		18	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 60	17	4"-8" fibrous PFI on FG w/tar	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
B	Room 60	19	9"-14" white fibrous PI	T		Pos	6	LF	F	N	2	6/27/94	BLA/DCK	25%	2%					061-94-074
B	Room 60	20	9"-14" PFI on white fibrous	T		Pos	5	EA	F	N	2	6/27/94	BLA/DCK	25%	2%					061-94-074
B	Room 60	21	9"-14" fibrous PFI on FG	T	ND		4	EA	F	N	0	6/27/94	BLA/DCK				<1%			061-94-074
B	Room 60	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 60	63	tar/canvas wall covering	M	ND		320	SF	N	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 60	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 75	1	<4" white fibrous PI	T		Pos	197	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 75	2	<4" PFI on white fibrous	T		Pos	21	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 75	7	<4" fiberglass w/tar PI	T	ND		225	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 75	8	<4" fibrous PFI on FG w/tar	T		Pos	40	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
B	Room 75	10	4"-8" white fibrous PI	T		Pos	6	LF	F	N	2	6/27/94	BLA/DCK	20%	15%					061-94-074
B	Room 75	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 75	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 75	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 75	72	galbestos	M		Pos	225	SF	N	N	1	6/27/94	BLA/DCK		40%					061-94-074

B	Room 76	1	<4" white fibrous PI	T		Pos	210	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 76	2	<4" PFI on white fibrous	T		Pos	65	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 76	7	<4" fiberglass w/tar PI	T	ND		60	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 76	8	<4" fibrous PFI on FG w/tar	T		Pos	15	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
B	Room 76	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
B	Room 76	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 76	64	black sink undercoat	M		Pos	12	SF	N	N	1	6/27/94	BLA/DCK		20%				061-94-074
B	Room 76	66	black lab top	M	ND		15	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 76	71	transite	M		Pos	40	SF	F	N	2	6/27/94	BLA/DCK		45%				061-94-074
B	Room 76	72	galbestos	M		Pos	400	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074
B	Room 77	1	<4" white fibrous PI	T		Pos	23	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 77	2	<4" PFI on white fibrous	T		Pos	10	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 77	7	<4" fiberglass w/tar PI	T	ND		105	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 77	8	<4" fibrous PFI on FG w/tar	T		Pos	48	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
B	Room 77	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
B	Room 77	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 77	66	black lab top	M	ND		36	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 77	71	transite	M		Pos	45	SF	F	N	2	6/27/94	BLA/DCK		45%				061-94-074
B	Room 78	1	<4" white fibrous PI	T		Pos	95	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 78	2	<4" PFI on white fibrous	T		Pos	36	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 78	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
B	Room 78	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 80	7	<4" fiberglass w/tar PI	T	ND		55	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 80	8	<4" fibrous PFI on FG w/tar	T		Pos	22	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
B	Room 80	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
B	Room 80	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 80	72	galbestos	M		Pos	25	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074
B	Room 80A	1	<4" white fibrous PI	T		Pos	16	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 80A	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
B	Room 80A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
B	Room 80A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
B	Room 80A	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074

B	Room 80C	1	<4" white fibrous PI	T		Pos	38	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80C	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80C	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80C	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80D	1	<4" white fibrous PI	T		Pos	155	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80D	2	<4" PFI on white fibrous	T		Pos	36	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80D	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 80D	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80D	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	1	<4" white fibrous PI	T		Pos	15	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80E	1	<4" white fibrous PI	T		Pos	46	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80E	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80E	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80E	9	<4" fibrous PFI on FG	T		Pos	24	EA	F	N	2	6/27/94	BLA/DCK	10%	20%					061-94-074
B	Room 80E	16	4"-8" fiberglass w/tar PI	T	ND		12	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	17	4"-8" fibrous PFI on FG w/tar	T		Pos	1	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
B	Room 80E	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 80E	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	76	9"-14" fiberglass w/tar PI	T	ND		10	LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E	77	9"-14" fibrous PFI on FG w/tar	T	ND		4	EA	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80E		vertical pipe chase above		ND															
B	Room 80F	1	<4" white fibrous PI	T		Pos	85	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80F	2	<4" PFI on white fibrous	T		Pos	23	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80F	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 80F	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80G	1	<4" white fibrous PI	T		Pos	56	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80G	2	<4" PFI on white fibrous	T		Pos	21	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80G	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
B	Room 80G	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074

B	Room 80H	1	<4" white fibrous PI	T		Pos	55	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80H	2	<4" PFI on white fibrous	T		Pos	20	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
B	Room 80H	7	<4" fiberglass w/tar PI	T	ND		36	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80H	8	<4" fibrous PFI on FG w/tar	T		Pos	16	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
B	Room 80H	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80H	66	black lab top	M	ND		15	SF	N	N	0	6/27/94	BLA/DCK							061-94-074
B	Room 80H	71	transite	M		Pos	40	SF	F	N	2	6/27/94	BLA/DCK		45%					061-94-074
B	Room 89	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
	Elevator Sha	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
	West Stairwa	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
	West Stairwa	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway E.	1	<4" white fibrous PI	T		Pos	6	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
1	Hallway E.	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
1	Hallway E.	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	Hallway E.	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	Hallway E.	62	2'X2' cratered CT	M	ND		60	SF	F	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway E.	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway W.	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	Hallway W.	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	Hallway W.	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway W.	51	12"x12" gray acoustical CT	M	ND		15	SF	F	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway W.	51.5	ceiling tile adhesive (sample 51)	M	ND		15	SF	N	N	0	6/27/94	BLA/DCK							061-94-074
1	Hallway W.	62	2'X2' cratered CT	M	ND		200	SF	F	N	0	6/27/94	BLA/DCK							061-94-074
1	Room 150 (A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	Room 150 (A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
1	Room 150 (A	31	9"x9" beige w/ pink & blue& white FT	M		Pos	300	SF	N	N	1	6/27/94	BLA/DCK		10%					061-94-074
1	Room 150 (A	31.5	floor tile adhesive (sample 31)	M		Pos	300	SF	N	N	1	6/27/94	BLA/DCK		10%					061-94-074
1	Room 150 (A	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074

1	Room 175	1	<4" white fibrous PI	T		Pos	106	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 175	2	<4" PFI on white fibrous	T		Pos	16	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 175	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 175	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 175	51	12"x12" gray acoustical CT	M	ND		200	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175	51.5	ceiling tile adhesive (sample 51)	M	ND		200	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175	62	2'X2' cratered CT	M	ND		660	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175A	1	<4" white fibrous PI	T		Pos	40	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 175A	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 175A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 175A	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 175A	51	12"x12" gray acoustical CT	M	ND		25	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175A	51.5	ceiling tile adhesive (sample 51)	M	ND		25	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175A	62	2'X2' cratered CT	M	ND		120	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175A	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 175A	75	brown floor mastic	M	ND		25	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 180	1	<4" white fibrous PI	T		Pos	45	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 180	2	<4" PFI on white fibrous	T		Pos	10	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	Room 180	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 180	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
1	Room 180	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 180	51	12"x12" gray acoustical CT	M	ND		45	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 180	51.5	ceiling tile adhesive (sample 51)	M	ND		45	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 180	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	Room 180	75	brown floor mastic	M	ND		75	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
1	West Gallery	1	<4" white fibrous PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	West Gallery	16	4"-8" fiberglass w/tar PI	T	ND		15	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
1	West Gallery	17	4"-8" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
1	West Gallery	64	black sink undercoat	M		Pos	12	SF	N	N	1	6/27/94	BLA/DCK		20%				061-94-074
1	West Gallery	1	<4" white fibrous PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
1	West Gallery	7	<4" fiberglass w/tar PI	T	ND		20	LF	F	N	0	6/27/94	BLA/DCK						061-94-074

1	West Gallery	8	<4" fibrous PFI on FG w/tar	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
1	West Gallery	10	4"-8" white fibrous PI	T		Pos	18	LF	F	N	2	6/27/94	BLA/DCK	20%	15%					061-94-074
1	West Gallery	11	4"-8" PFI on white fibrous	T	ND		1	EA	F	N	0	6/27/94	BLA/DCK					<1%		061-94-074
1	West Gallery	16	4"-8" fiberglass w/tar PI	T	ND		15	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
1	West Gallery	17	4"-8" fibrous PFI on FG w/tar	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
1	West Gallery	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	West Gallery	64	black sink undercoat	M		Pos	12	SF	N	N	1	6/27/94	BLA/DCK		20%					061-94-074
1	West Gallery	1	<4" white fibrous PI	T		Pos	160	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
1	West Gallery	2	<4" PFI on white fibrous	T		Pos	34	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
1	West Gallery	9	<4" fibrous PFI on FG	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK	10%	20%					061-94-074
1	West Gallery	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	West Gallery	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
1	West Gallery	51	12"x12" gray acoustical CT	M	ND		540	SF	F	N	0	6/27/94	BLA/DCK							061-94-074
1	West Gallery	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 275 N	1	<4" white fibrous PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 275 N	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 275 N	16	4"-8" fiberglass w/tar PI	T	ND		15	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 275 N	17	4"-8" fibrous PFI on FG w/tar	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
2	Room 275 N	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 275 S	1	<4" white fibrous PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 275 S	10	4"-8" white fibrous PI	T		Pos	15	LF	F	N	2	6/27/94	BLA/DCK	20%	15%					061-94-074
2	Room 275 S	16	4"-8" fiberglass w/tar PI	T	ND		15	LF	F	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 275 S	17	4"-8" fibrous PFI on FG w/tar	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK		20%					061-94-074
2	Room 275	1	<4" white fibrous PI	T		Pos	210	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 275	2	<4" PFI on white fibrous	T		Pos	28	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 275	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%					061-94-074
2	Room 275	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 275	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK							061-94-074
2	Room 280	1	<4" white fibrous PI	T		Pos	16	LF	F	N	2	6/27/94	BLA/DCK	50%						061-94-074
2	Room 280	2	<4" PFI on white fibrous	T		Pos	10	EA	F	N	2	6/27/94	BLA/DCK	50%						061-94-074

2	Room 280	7	<4" fiberglass w/tar PI	T	ND		28	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 280	8	<4" fibrous PFI on FG w/tar	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
2	Room 280	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 280	58	2'x4' fissured pinhole CT	M	ND		512	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 280	64	black sink undercoat	M		Pos	12	SF	N	N	1	6/27/94	BLA/DCK		20%				061-94-074
2	Room 280	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288	1	<4" white fibrous PI	T		Pos	38	LF	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 288	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 288	7	<4" fiberglass w/tar PI	T	ND		60	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288	8	<4" fibrous PFI on FG w/tar	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
2	Room 288	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 288	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 288	54	2'x2' fissured pinhole CT	M	ND		280	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288	70	yellow textured flooring	M	ND		280	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288A	1	<4" white fibrous PI	T		Pos	30	LF	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 288A	2	<4" PFI on white fibrous	T		Pos	12	EA	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 288A	7	<4" fiberglass w/tar PI	T	ND		22	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288A	8	<4" fibrous PFI on FG w/tar	T		Pos	7	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
2	Room 288A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 288A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288A	54	2'x2' fissured pinhole CT	M	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288A	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 288A	74	black/white/gray/flooring	M	ND		144	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 290	1	<4" white fibrous PI	T		Pos	16	LF	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 290	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
2	Room 290	7	<4" fiberglass w/tar PI	T	ND		24	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 290	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 290	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 290	57	2'x2' crater fissure pinhole CT	M		Pos	96	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
2	Room 292	7	<4" fiberglass w/tar PI	T	ND		18	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 292	8	<4" fibrous PFI on FG w/tar	T		Pos	2	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
2	Room 292	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074

2	Room 292	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 292	57	2'x2' crater fissure pinhole CT	M		Pos	25	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
2	Room 292	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 292	70	yellow textured flooring	M	ND		25	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 294	1	<4" white fibrous PI	T		Pos	4	LF	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
2	Room 294	2	<4" PFI on white fibrous	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK	50%					061-94-074
2	Room 294	7	<4" fiberglass w/tar PI	T	ND		55	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 294	16	4"-8" fiberglass w/tar PI	T	ND		15	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 294	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 294	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 294	57	2'x2' crater fissure pinhole CT	M		Pos	90	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
2	Room 294	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
2	Room 294	72	galbestos	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074
2	Room 294B	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
2	Room 294B	70	yellow textured flooring	M	ND		65	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Hall 339-375	16	4"-8" fiberglass w/tar PI	T	ND		10	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Hall 339-375	17	4"-8" fibrous PFI on FG w/tar	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Hall 339-375	23	spray-on fireproofing	S	ND		272	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Hall 339-375	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Hall 339-375	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Hall 339-375	31	9"x9" beige w/ pink & blue& white FT	M		Pos	272	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Hall 339-375	31.5	floor tile adhesive (sample 31)	M		Pos	272	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Hall 339-375	54	2'x2' fissured pinhole CT	M	ND		272	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339	9	<4" fibrous PFI on FG	T		Pos	10	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				061-94-074
3	Room 339	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 339	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339	32	9"x9" grey marble FT	M		Pos	242	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 339	32.5	floor tile adhesive (sample 32)	M		Pos	242	SF	N	N	1	6/27/94	BLA/DCK		15%				061-94-074
3	Room 339	56	2'x2' crater pinhole CT	M	ND		242	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339	67	white sink undercoat	M		Pos	4	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 339	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074

3	Room 339A	16	4"-8" fiberglass w/tar PI	T	ND		10	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339A	17	4"-8" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 339A	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 339A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339A	32	9"x9" grey marble FT	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 339A	32.5	floor tile adhesive (sample 32)	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		15%				061-94-074
3	Room 339A	56	2'x2' crater pinhole CT	M	ND		180	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 339A	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 340	9	<4" fibrous PFI on FG	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				061-94-074
3	Room 340	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 340	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 340	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 340	33	9"x9" white w/black swirls FT	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		5%				061-94-074
3	Room 340	33.5	floor tile adhesive (sample 33)	M		Pos	180	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 340	55	2'x2' random pinhole CT	M		Pos	180	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
3	Room 340	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 342	9	<4" fibrous PFI on FG	T		Pos	4	EA	F	N	2	6/27/94	BLA/DCK	10%	20%				061-94-074
3	Room 342	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 342	29	sheetrock & taping comp.	M	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 342	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 342	33	9"x9" white w/black swirls FT	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK		5%				061-94-074
3	Room 342	33.5	floor tile adhesive (sample 33)	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 342	55	2'x2' random pinhole CT	M		Pos	240	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
3	Room 342	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 344	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 344	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 344	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 344	33	9"x9" white w/black swirls FT	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK		5%				061-94-074
3	Room 344	33.5	floor tile adhesive (sample 33)	M		Pos	240	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 344	55	2'x2' random pinhole CT	M		Pos	240	SF	F	N	2	6/27/94	BLA/DCK		5%				061-94-074
3	Room 344	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 349	16	4"-8" fiberglass w/tar PI	T	ND		10	LF	F	N	0	6/27/94	BLA/DCK						061-94-074

3	Room 349	17	4"-8" fibrous PFI on FG w/tar	T		Pos	6	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 349	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 349	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 349	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 349	32	9"x9" grey marble FT	M		Pos	175	SF	N	N	1	6/27/94	BLA/DCK		10%				061-94-074
3	Room 349	32.5	floor tile adhesive (sample 32)	M		Pos	175	SF	N	N	1	6/27/94	BLA/DCK		15%				061-94-074
3	Room 349	56	2'x2' crater pinhole CT	M	ND		175	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 349	68	trowled-on plaster	S	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 349	69	concrete block mortar	M	ND			SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 375	7	<4" fiberglass w/tar PI	T	ND		390	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 375	8	<4" fibrous PFI on FG w/tar	T		Pos	36	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 375	10	4"-8" white fibrous PI	T		Pos	40	LF	F	N	2	6/27/94	BLA/DCK	20%	15%				061-94-074
3	Room 375	11	4"-8" PFI on white fibrous	T	ND		9	EA	F	N	0	6/27/94	BLA/DCK				<1%		061-94-074
3	Room 375	16	4"-8" fiberglass w/tar PI	T	ND		8	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 375	17	4"-8" fibrous PFI on FG w/tar	T		Pos	31	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 375	23	spray-on fireproofing	S	ND		4068	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 375	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 375	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 375	54	2'x2' fissured pinhole CT	M	ND		4068	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 382	23	spray-on fireproofing	S	ND		150	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 382	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 382	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 382	54	2'x2' fissured pinhole CT	M	ND		150	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	7	<4" fiberglass w/tar PI	T	ND		39	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	8	<4" fibrous PFI on FG w/tar	T		Pos	8	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 384	23	spray-on fireproofing	S	ND		288	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 384	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	54	2'x2' fissured pinhole CT	M	ND		288	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	66	black lab top	M	ND		16	SF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 384	71	transite	M		Pos	25	SF	F	N	2	6/27/94	BLA/DCK		45%				061-94-074
3	Room 388	23	spray-on fireproofing	S	ND			SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 388	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						061-94-074

3	Room 388	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 388	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 388	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 388A	23	spray-on fireproofing	S	ND			SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 388A	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 388A	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 390	23	spray-on fireproofing	S	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 390	24	ceiling plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 390	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 390	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 390	54	2'x2' fissured pinhole CT	M	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 392	7	<4" fiberglass w/tar PI	T	ND		40	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 392	8	<4" fibrous PFI on FG w/tar	T		Pos	3	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
3	Room 392	23	spray-on fireproofing	S	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 392	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 392	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 392	54	2'x2' fissured pinhole CT	M	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 394	23	spray-on fireproofing	S	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 394	25	wall plaster	S	ND			SF	F	N	0	6/27/94	BLA/DCK		<1%				061-94-074
3	Room 394	30	baseboard adhesive	M	ND			LF	N	N	0	6/27/94	BLA/DCK						061-94-074
3	Room 394	54	2'x2' fissured pinhole CT	M	ND		144	SF	F	N	0	6/27/94	BLA/DCK						061-94-074
4	Room 475	1	<4" white fibrous PI	T		Pos	75	LF	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
4	Room 475	2	<4" PFI on white fibrous	T		Pos	45	EA	F	N	2	6/27/94	BLA/DCK		50%				061-94-074
4	Room 475	10	4"-8" white fibrous PI	T		Pos	40	LF	F	N	2	6/27/94	BLA/DCK		20%	15%			061-94-074
4	Room 475	11	4"-8" PFI on white fibrous	T	ND		11	EA	F	N	0	6/27/94	BLA/DCK				<1%		061-94-074
4	Room 475	16	4"-8" fiberglass w/tar PI	T	ND		35	LF	F	N	0	6/27/94	BLA/DCK						061-94-074
4	Room 475	17	4"-8" fibrous PFI on FG w/tar	T		Pos	23	EA	F	N	2	6/27/94	BLA/DCK		20%				061-94-074
4	Room 475	65	canvas vibration joint	M	ND		11	EA	N	N	0	6/27/94	BLA/DCK						061-94-074
4	Room 475	72	galbestos	M		Pos	344	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074
4	Room 475	73	tar on metal siding	M		Pos	1350	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074

	Roof	73	tar on metal siding	M		Pos	1440	SF	N	N	1	6/27/94	BLA/DCK		40%				061-94-074
--	------	----	---------------------	---	--	-----	------	----	---	---	---	---------	---------	--	-----	--	--	--	------------