

Fir	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
13	elevator lobby	116	2'x2' single-sized pinhole CT	M	ND		8	SF	F	N	0	7/15/94	DAH/TJS							
13	elevator lobby	119	2'x2' swirled pinhole CT	M		Pos	316	SF	F	N	2	8/5/94	DAH/TJS		3%					
13	elevator lobby	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	elevator lobby	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
13	elevator lobby	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS							
13	elevator lobby	156	grey duct adhesive	M		Pos	32	LF	N	N	1	7/15/94	DAH/TJS		10%					
13	elevator lobby	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS							
13	elevator lobby	213	12"x12" white, cream & tan	M	ND		390	SF	N	N	0	7/15/94	DAH/TJS							
13	elevator lobby	213.5	floor tile adhesive(sample)	M		Pos	390	SF	N	N	1	9/8/94	DAH/TJS		5%					
13	hall(hatch)	47	fluffy spray-on fireproofing	S	ND		2	SF	F	N	0	7/15/94	DAH/TJS							
13	hall	116	2'x2' single-sized pinhole CT	M	ND		114	SF	F	N	0	7/15/94	DAH/TJS							
13	hall	119	2'x2' swirled pinhole CT	M		Pos	850	SF	F	N	2	8/5/94	DAH/TJS		3%					
13	hall	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	hall	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
13	hall	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS							
13	hall	154	putty sealant around pipe	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS							
13	hall	156	grey duct adhesive	M		Pos	30	LF	N	N	1	7/15/94	DAH/TJS		10%					
13	hall	196	bright green duct adhesive	M	ND		61	LF	N	N	0	9/8/94	DAH/TJS							
13	hall	213	12"x12" white, cream & tan	M	ND		1000	SF	N	N	0	7/15/94	DAH/TJS							
13	hall	213.5	floor tile adhesive(sample)	M		Pos	1000	SF	N	N	1	9/8/94	DAH/TJS		5%					
13	room 1301	46	patching plaster	S	ND		2	SF	F	N	0	7/15/94	DAH/TJS							
13	room 1301	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1301	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
13	room 1301	154	putty sealant around pipe	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS							
13	room 1301	162	red pipe sealant	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS							
13	room 1301(hatch)	47	fluffy spray-on fireproofing	S	ND		50	SF	F	N	0	7/15/94	DAH/TJS							
13	room 1301(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1307	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
13	room 1307	125	2'x4' swirled pinhole CT	M		Pos	98	SF	F	N	2	8/5/94	DAH/TJS		3%					
13	room 1307	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							

13	room 1307	156	grey duct adhesive	M		Pos	6	LF	N	N	1	7/15/94	DAH/TJS		10%						
13	room 1307	162	red pipe sealant	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1307(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1315	47	fluffy spray-on fireproofing	S	ND		100	SF	F	N	0	7/15/94	DAH/TJS								
13	room 1315	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1315	154	putty sealant around pipe	M	ND		3	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1315	156	grey duct adhesive	M		Pos	20	LF	N	N	1	7/15/94	DAH/TJS		10%						
13	room 1315	162	red pipe sealant	M	ND		7	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1315	182	tan w/white specks linoleum	M	ND		600	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1315	182.5	linoleum adhesive(sample)	M	ND		600	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1315	192	shiny black lab top	M	ND		186	SF	N	N	0	9/8/94	DAH/TJS								
13	room 1315	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1315	269	2'x4' plastic coated CT	M	ND		620	SF	F	N	0	9/8/94	DAH/TJS								
13	room 1316	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1316	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
13	room 1317	16	4"-8" white fibrous PI	T		Pos	9	LF	F	H	4	7/15/94	DAH/TJS	7%	7%						
13	room 1317	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1317	196	bright green duct adhesive	M	ND		76	LF	N	N	0	9/8/94	DAH/TJS								
13	room 1319	47	fluffy spray-on fireproofing	S	ND		50	SF	F	N	0	7/15/94	DAH/TJS								
13	room 1319	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1319	156	grey duct adhesive	M	ND		6	LF	N	N	0	7/15/94	DAH/TJS								
13	room 1319	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1319	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1319	182	tan w/white specks linoleum	M	ND		140	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1319	182.5	linoleum adhesive(sample)	M	ND		140	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1319	192	shiny black lab top	M	ND		24	SF	N	N	0	9/8/94	DAH/TJS								
13	room 1319	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1319	196	bright green duct adhesive	M	ND		25	LF	N	N	0	9/8/94	DAH/TJS								
13	room 1319	269	2'x4' plastic coated CT	M	ND		130	SF	F	N	0	9/8/94	DAH/TJS								
13	room 1325	47	fluffy spray-on fireproofing	S	ND		100	SF	F	N	0	7/15/94	DAH/TJS								
13	room 1325	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								

13	room 1325	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1325	156	grey duct adhesive	M		Pos	15	LF	N	N	1	7/15/94	DAH/TJS		10%						
13	room 1325	169	black tar on insulation	M	ND		200	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1325	182	tan w/white specks linoleu	M	ND		800	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1325	182.5	linoleum adhesive(sample	M	ND		800	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1325	192	shiny black lab top	M	ND		186	SF	N	N	0	9/8/94	DAH/TJS								
13	room 1325	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1325	213	12"x12" white, cream & ta	M	ND		4	SF	N	N	0	7/15/94	DAH/TJS								
13	room 1325	269	2'x4' plastic coated CT	M	ND		860	SF	F	N	0	9/8/94	DAH/TJS								
13	room 1325-1	125	2'x4' swirled pinhole CT	M		Pos	86	SF	F	N	2	8/5/94	DAH/TJS		3%						
13	room 1325-1	131	2'x4' high-density pinhole	M	ND		20	SF	F	N	0	9/8/94	DAH/TJS								
13	room 1325-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1325-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
13	room 1325-1	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1325-1	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1325-1	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1325-1	169	black tar on insulation	M	ND		60	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1331	99	9"x9" grey w/ white & black streaks	FT		Pos	6	SF	N	N	1	7/15/94	DAH/TJS		7%						
13	room 1331	182	tan w/white specks linoleu	M	ND		122	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1331	182.5	linoleum adhesive(sample	M	ND		122	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1331	1001	unable to view above ceiling																		
13	room 1333	182	tan w/white specks linoleu	M	ND		122	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1333	182.5	linoleum adhesive(sample	M	ND		122	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1333	1001	unable to view above ceiling																		
13	room 1340	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
13	room 1340	154	putty sealant around pipe	M	ND		10	LF	N	N	0	8/5/94	DAH/TJS								
13	room 1340	156	grey duct adhesive	M		Pos	150	LF	N	N	1	7/15/94	DAH/TJS		10%						
13	room 1340	182	tan w/white specks linoleu	M	ND		840	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1340	182.5	linoleum adhesive(sample	M	ND		840	SF	N	N	0	8/5/94	DAH/TJS								
13	room 1340	192	shiny black lab top	M	ND		186	SF	N	N	0	9/8/94	DAH/TJS								
13	room 1340	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
13	room 1340	269	2'x4' plastic coated CT	M	ND		880	SF	F	N	0	9/8/94	DAH/TJS								

13	room 1342	46	patching plaster	S	ND		3	SF	F	N	0	7/15/94	DAH/TJS						
13	room 1342	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1342	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
13	room 1342	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
13	room 1342	156	grey duct adhesive	M		Pos	30	LF	N	N	1	7/15/94	DAH/TJS		10%				
13	room 1342	269	2'x4' plastic coated CT	M	ND		144	SF	F	N	0	9/8/94	DAH/TJS						
13	room 1344	125	2'x4' swirled pinhole CT	M		Pos	144	SF	F	N	2	8/5/94	DAH/TJS		3%				
13	room 1344	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1344	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
13	room 1344	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
13	room 1344	154	putty sealant around pipe	M	ND		3	LF	N	N	0	8/5/94	DAH/TJS						
13	room 1344	156	grey duct adhesive	M		Pos	20	LF	N	N	1	7/15/94	DAH/TJS		10%				
13	room 1346	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1346	1001	unable to view above ceiling																
13	room 1348	46	patching plaster	S	ND		100	SF	F	N	0	7/15/94	DAH/TJS						
13	room 1348	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348	156	grey duct adhesive	M		Pos	70	LF	N	N	1	7/15/94	DAH/TJS		10%				
13	room 1348	167	black sink coating	M		Pos	2	EA	N	N	1	7/15/94	DAH/TJS		10%				
13	room 1348	169	black tar on insulation	M	ND		60	SF	N	N	0	8/5/94	DAH/TJS						
13	room 1348	269	2'x4' plastic coated CT	M	ND		190	SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-1	47	fluffy spray-on fireproofing	S	ND		30	SF	F	N	0	7/15/94	DAH/TJS						
13	room 1348-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-1	196	bright green duct adhesive	M	ND		70	LF	N	N	0	9/8/94	DAH/TJS						
13	room 1348-1	269	2'x4' plastic coated CT	M	ND		162	SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-1a	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-1a	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
13	room 1348-1a	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS						
13	room 1348-1a	163	tan duct adhesive	M	ND		15	LF	N	N	0	8/5/94	DAH/TJS						
13	room 1348-2	43	spray-on fireproofing	S	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-2	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1348-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						

13	room 1354	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1354(hatch)	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS							
13	room 1354(hatch)	156	grey duct adhesive	M		Pos	28	LF	N	N	1	7/15/94	DAH/TJS		10%					
13	room 1354(hatch)	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS							
13	room 1356	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1356	163	tan duct adhesive	M	ND		24	LF	N	N	0	8/5/94	DAH/TJS							
13	room 1356	182	tan w/white specks linoleu	M	ND		340	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1356	182.5	linoleum adhesive(sample	M	ND		340	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1356	192	shiny black lab top	M	ND		18	SF	N	N	0	9/8/94	DAH/TJS							
13	room 1356	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS							
13	room 1356	269	2'x4' plastic coated CT	M	ND		300	SF	F	N	0	9/8/94	DAH/TJS							
13	room 1360	47	fluffy spray-on fireproofing	S	ND		50	SF	F	N	0	7/15/94	DAH/TJS							
13	room 1360	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1360	156	grey duct adhesive	M		Pos	15	LF	N	N	1	7/15/94	DAH/TJS		10%					
13	room 1360	156	grey duct adhesive	M		Pos	30	LF	N	N	1	7/15/94	DAH/TJS		10%					
13	room 1360	169	black tar on insulation	M	ND		250	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1360	182	tan w/white specks linoleu	M	ND		800	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1360	182.5	linoleum adhesive(sample	M	ND		800	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1360	192	shiny black lab top	M	ND		186	SF	N	N	0	9/8/94	DAH/TJS							
13	room 1360	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS							
13	room 1360	269	2'x4' plastic coated CT	M	ND		860	SF	F	N	0	9/8/94	DAH/TJS							
13	room 1360-1	125	2'x4' swirled pinhole CT	M		Pos	112	SF	F	N	2	8/5/94	DAH/TJS		3%					
13	room 1360-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
13	room 1360-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
13	room 1360-1	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS							
13	room 1360-1	169	black tar on insulation	M	ND		50	SF	N	N	0	8/5/94	DAH/TJS							
13	room 1369	5	<4" felt with tar PI	T		Pos	18	LF	F	N	2	7/15/94	DAH/TJS		60%					
13	room 1369	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
13	room 1369	20	4"-8" felt w/ tar PI	T		Pos	7	LF	F	N	2	7/15/94	DAH/TJS		60%					
13	room 1369	21	4"-8" PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
13	room 1369	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							

13	room 1369	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1369	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
13	room 1369	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
13	room 1369	156	grey duct adhesive	M		Pos	22	LF	N	N	1	7/15/94	DAH/TJS		10%				
13	room 1369	269	2'x4' plastic coated CT	M	ND		76	SF	F	N	0	9/8/94	DAH/TJS						
13	room 1371	5	<4" felt with tar PI	T		Pos	38	LF	F	N	2	7/15/94	DAH/TJS		60%				
13	room 1371	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
13	room 1371	16	4"-8" white fibrous PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
13	room 1371	17	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
13	room 1371	20	4"-8" felt w/ tar PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS		60%				
13	room 1371	21	4"-8" PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
13	room 1371	24	4"-8" cork w/ tar PI	T	ND		24	LF	N	N	0	7/15/94	DAH/TJS						
13	room 1371	25	4"-8" PFI on cork	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	15%	35%				
13	room 1371	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
13	room 1371	186	white paper	M		Pos	28	SF	F	N	2	8/5/94	DAH/TJS		85%				
13	room 1373	127	2'x4' single-size pinhole C	M	ND		72	SF	F	N	0	7/15/94	DAH/TJS						
13	room 1373	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
13	room 1373	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	elevator lobby	116	2'x2' single-sized pinhole C	M	ND		300	SF	F	N	0	7/15/94	DAH/TJS						
14	elevator lobby	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	elevator lobby	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	elevator lobby	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS						
14	elevator lobby	163	tan duct adhesive	M	ND		4	LF	N	N	0	8/5/94	DAH/TJS						
14	elevator lobby	169	black tar on insulation	M	ND		18	SF	N	N	0	8/5/94	DAH/TJS						
14	elevator lobby	213	12"x12" white, cream & ta	M	ND		369	SF	N	N	0	7/15/94	DAH/TJS						
14	elevator lobby	213.5	floor tile adhesive(sample	M		Pos	369	SF	N	N	1	9/8/94	DAH/TJS		5%				
14	elevator lobby	233	12"x12" greenish & tan m	M		Pos	11	SF	N	N	1	NS			assume				
14	elevator lobby	233.5	floor tile adhesive (sample	M		Pos	11	SF	N	N	1	NS			assume				
14	hall 1420-1460	116	2'x2' single-sized pinhole C	M	ND		908	SF	F	N	0	7/15/94	DAH/TJS						
14	hall 1420-1460	119	2'x2' swirled pinhole CT	M		Pos	40	SF	F	N	2	8/5/94	DAH/TJS		3%				
14	hall 1420-1460	131	2'x4' high-density pinhole	M	ND		8	SF	F	N	0	9/8/94	DAH/TJS						
14	hall 1420-1460	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	hall 1420-1460	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						

14	hall 1420-1460	154	putty sealant around pipe	M	ND		11	LF	N	N	0	8/5/94	DAH/TJS						
14	hall 1420-1460	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS						
14	hall 1420-1460	163	tan duct adhesive	M	ND		170	LF	N	N	0	8/5/94	DAH/TJS						
14	hall 1420-1460	196	bright green duct adhesive	M	ND		58	LF	N	N	0	9/8/94	DAH/TJS						
14	hall 1420-1460	213	12"x12" white, cream & ta	M	ND		1000	SF	N	N	0	7/15/94	DAH/TJS						
14	hall 1420-1460	213.5	floor tile adhesive(sample	M		Pos	1000	SF	N	N	1	9/8/94	DAH/TJS		5%				
14	hall 1448-1450	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	hall 1448-1450	125	2'x4' swirled pinhole CT	M		Pos	36	SF	F	N	2	8/5/94	DAH/TJS		3%				
14	hall 1448-1450	127	2'x4' single-size pinhole C	M	ND		74	SF	F	N	0	7/15/94	DAH/TJS						
14	hall 1448-1450	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	hall 1448-1450	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	hall 1448-1450	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	hall 1448-1450	213	12"x12" white, cream & ta	M	ND		110	SF	N	N	0	7/15/94	DAH/TJS						
14	hall 1448-1450	213.5	floor tile adhesive(sample	M		Pos	110	SF	N	N	1	9/8/94	DAH/TJS		5%				
14	room 1401	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1401	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1401	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	room 1401	154	putty sealant around pipe	M	ND		16	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1401	163	tan duct adhesive	M	ND		120	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1404	127	2'x4' single-size pinhole C	M	ND		128	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1404	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1404	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1404	169	black tar on insulation	M	ND		41	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1404(hatch)	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	room 1404(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1405	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1405	163	tan duct adhesive	M	ND		30	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1405	169	black tar on insulation	M	ND		270	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1405	182	tan w/white specks linoleu	M	ND		688	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1405	182.5	linoleum adhesive(sample	M	ND		560	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1405	192	shiny black lab top	M	ND		186	SF	N	N	0	9/8/94	DAH/TJS						
14	room 1405	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS						



14	room 1415-1	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1415-1	169	black tar on insulation	M	ND		210	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1415-1	182	tan w/white specks linoleu	M	ND		116	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1415-1	182.5	linoleum adhesive(sample	M	ND		116	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1415-1	269	2'x4' plastic coated CT	M	ND		66	SF	F	N	0	9/8/94	DAH/TJS						
14	room 1420	182	tan w/white specks linoleu	M	ND		90	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1420	182.5	linoleum adhesive(sample	M	ND		90	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1420	1001	unable to view above ceiling																
14	room 1425	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1425	148	lab top	M		Pos	4	SF	N	N	1	7/15/94	DAH/TJS		30%				
14	room 1425	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1425	163	tan duct adhesive	M	ND		80	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1425	169	black tar on insulation	M	ND		220	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1425	182	tan w/white specks linoleu	M	ND		7220	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1425	182.5	linoleum adhesive(sample	M	ND		720	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1425	192	shiny black lab top	M	ND		384	SF	N	N	0	9/8/94	DAH/TJS						
14	room 1425	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1425	269	2'x4' plastic coated CT	M	ND		800	SF	F	N	0	9/8/94	DAH/TJS						
14	room 1435	127	2'x4' single-size pinhole C	M	ND		144	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1435	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1435	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1435	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1435	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1435	169	black tar on insulation	M	ND		25	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1436	47	fluffy spray-on fireproofing	S	ND		80	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1436	127	2'x4' single-size pinhole C	M	ND		144	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1436	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1436	163	tan duct adhesive	M	ND		20	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1436	169	black tar on insulation	M	ND		60	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1436	182	tan w/white specks linoleu	M	ND		1	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1436	182.5	linoleum adhesive(sample	M	ND		166	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1436	192	shiny black lab top	M	ND		38	SF	N	N	0	9/8/94	DAH/TJS						

14	room 1437	127	2'x4' single-size pinhole C	M	ND		144	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1437	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1437	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1437	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1437	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1437	169	black tar on insulation	M	ND		60	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1438	127	2'x4' single-size pinhole C	M	ND		112	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1438	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1438	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1438	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1438	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1438	163	tan duct adhesive	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1438	169	black tar on insulation	M	ND		20	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1440	127	2'x4' single-size pinhole C	M	ND		310	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1440	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1440	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
14	room 1440	154	putty sealant around pipe	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1440	163	tan duct adhesive	M	ND		40	LF	N	N	0	8/5/94	DAH/TJS						
14	room 1440	167	black sink coating	M		Pos	1	EA	N	N	1	7/15/94	DAH/TJS		10%				
14	room 1440	169	black tar on insulation	M	ND		82	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1440	182	tan w/white specks linoleu	M	ND		368	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1440	182.5	linoleum adhesive(sample	M	ND		368	SF	N	N	0	8/5/94	DAH/TJS						
14	room 1440(hatch)	47	fluffy spray-on fireproofing	S	ND		30	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1440(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1446	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1446	1001	unable to view above ceiling																
14	room 1448	47	fluffy spray-on fireproofing	S	ND		30	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1448	127	2'x4' single-size pinhole C	M	ND		50	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1448	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1448	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1448	148	lab top	M		Pos	25	SF	N	N	1	7/15/94	DAH/TJS		30%				
14	room 1448	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS						

14	room 1448	163	tan duct adhesive	M	ND		36	LF	N	N	0	8/5/94	DAH/TJS								
14	room 1448	164	white sink coating	M		Pos	1	EA	N	N	1	9/8/94	DAH/TJS		15%						
14	room 1448	213	12"x12" white, cream & ta	M	ND		40	SF	N	N	0	7/15/94	DAH/TJS								
14	room 1448	213.5	floor tile adhesive(sample	M		Pos	40	SF	N	N	1	9/8/94	DAH/TJS		5%						
14	room 1449	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1449	163	tan duct adhesive	M	ND		24	LF	N	N	0	8/5/94	DAH/TJS								
14	room 1449	169	black tar on insulation	M	ND		14	SF	N	N	0	8/5/94	DAH/TJS								
14	room 1449-1		unable to access																		
14	room 1450	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450	125	2'x4' swirled pinhole CT	M		Pos	40	SF	F	N	2	8/5/94	DAH/TJS		3%						
14	room 1450	127	2'x4' single-size pinhole C	M	ND		216	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450	131	2'x4' high-density pinhole	M	ND		48	SF	F	N	0	9/8/94	DAH/TJS								
14	room 1450	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1450	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1450	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450	150	chalkboard	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
14	room 1450	169	black tar on insulation	M	ND		136	SF	N	N	0	8/5/94	DAH/TJS								
14	room 1450-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1450-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1450-1	1001	unable to view above ceiling																		
14	room 1450-2	1	<4" white fibrous PI	T		Pos	22	LF	F	N	2	7/15/94	DAH/TJS	7%	5%						
14	room 1450-2	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS		35%						
14	room 1450-2	47	fluffy spray-on fireproofing	S	ND		20	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450-2	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1450-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1450-2	157	brown duct adhesive	M	ND		88	LF	N	N	0	8/5/94	DAH/TJS								
14	room 1450-2	163	tan duct adhesive	M	ND		64	LF	N	N	0	8/5/94	DAH/TJS								
14	room 1450-2	178	tar paper duct wrap	M	ND		22	SF	F	N	0	8/5/94	DAH/TJS								
14	room 1453	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								

14	room 1453	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1453	1001	unable to view above ceiling																		
14	room 1460	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460	46	patching plaster	S	ND		116	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460	47	fluffy spray-on fireproofing	S	ND		50	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460	125	2'x4' swirled pinhole CT	M		Pos	80	SF	F	N	2	8/5/94	DAH/TJS		3%						
14	room 1460	127	2'x4' single-size pinhole C	M	ND		158	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460	154	putty sealant around pipe	M	ND		5	LF	N	N	0	8/5/94	DAH/TJS								
14	room 1460-01	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-01	46	patching plaster	S	ND		48	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-01	127	2'x4' single-size pinhole C	M	ND		102	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-01	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-01	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-01	169	black tar on insulation	M	ND		70	SF	N	N	0	8/5/94	DAH/TJS								
14	room 1460-02	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-02	46	patching plaster	S	ND		48	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-02	127	2'x4' single-size pinhole C	M	ND		56	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-02	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-02	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-02	169	black tar on insulation	M	ND		56	SF	N	N	0	8/5/94	DAH/TJS								
14	room 1460-03	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-03	46	patching plaster	S	ND		40	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-03	127	2'x4' single-size pinhole C	M	ND		56	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-03	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-03	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-03	169	black tar on insulation	M	ND		36	SF	N	N	0	8/5/94	DAH/TJS								
14	room 1460-04	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-04	46	patching plaster	S	ND		52	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-04	127	2'x4' single-size pinhole C	M	ND		90	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-04	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								



14	room 1460-08(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-09	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-09	125	2'x4' swirled pinhole CT	M		Pos	8	SF	F	N	2	8/5/94	DAH/TJS		3%						
14	room 1460-09	127	2'x4' single-size pinhole C	M	ND		24	SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-09	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-09	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-10	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
14	room 1460-10	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-10	1001	unable to view above ceiling																		
14	room 1460-11	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-11	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-11	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-11	1001	unable to view above ceiling																		
14	room 1460-12	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-12	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-12	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-12	1001	unable to view above ceiling																		
14	room 1460-13	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-13	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-13	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-13	1001	unable to view above ceiling																		
14	room 1460-14	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-14	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-14	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
14	room 1460-14	1001	unable to view above ceiling																		
14	room 1460-15	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-15	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
14	room 1460-15	1001	unable to view above ceiling																		
14	room 1463	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								

14	room 1463	46	patching plaster	S	ND		10	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1463	127	2'x4' single-size pinhole C	M	ND		74	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1463	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1463	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1463	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	room 1466	5	<4" felt with tar PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS						60%
14	room 1466	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%					3%
14	room 1466	16	4"-8" white fibrous PI	T		Pos	32	LF	F	N	2	7/15/94	DAH/TJS	7%					7%
14	room 1466	17	4"-8" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	3%					7%
14	room 1466	20	4"-8" felt w/ tar PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS						60%
14	room 1466	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%					15%
14	room 1466	24	4"-8" cork w/ tar PI	T	ND		24	LF	N	N	0	7/15/94	DAH/TJS						
14	room 1466	25	4"-8" PFI on cork	T		Pos	2	EA	F	H	4	7/15/94	DAH/TJS	15%					35%
14	room 1466	40	white fibrous tank insulatic	T		Pos	12	SF	F	N	2	7/15/94	DAH/TJS	5%					5%
14	room 1466	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1466	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	room 1466	186	white paper	M		Pos	28	SF	F	N	2	8/5/94	DAH/TJS						85%
14	room 1468	127	2'x4' single-size pinhole C	M	ND		90	SF	F	N	0	7/15/94	DAH/TJS						
14	room 1468	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	room 1468	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	room 1468	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	room 1468	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS						
14	stair to 15th fl.	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
14	stair to 15th fl.	58	9"x9" black w/ white smea	M		Pos	48	SF	N	N	1	8/5/94	DAH/TJS						23%
14	stair to 15th fl.	58.5	floor tile adhesive (sample	M		Pos	48	SF	N	N	1	9/8/94	DAH/TJS						10%
14	stair to 15th fl.	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
14	stair to 15th fl.	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
14	stair to 15th fl.	213	12"x12" white, cream & ta	M	ND		14	SF	N	N	0	7/15/94	DAH/TJS						
14	stair to 15th fl.	213.5	floor tile adhesive(sample	M		Pos	14	SF	N	N	1	9/8/94	DAH/TJS						5%
15	hall	1	<4" white fibrous PI	T		Pos	68	LF	F	N	2	7/15/94	DAH/TJS	7%					5%
15	hall	2	<4" PFI on white fibrous	T		Pos	15	EA	F	N	2	7/15/94	DAH/TJS						35%
15	hall	5	<4" felt with tar PI	T		Pos	4	LF	F	N	2	7/15/94	DAH/TJS						60%
15	hall	9	<4" cork w/ tar PI	T	ND		9	LF	N	N	0	7/15/94	DAH/TJS						

15	hall	10	<4" PFI on cork	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	15%	15%					
15	hall	16	4"-8" white fibrous PI	T		Pos	18	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	hall	17	4"-8" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	hall	20	4"-8" felt w/ tar PI	T		Pos	4	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	hall	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	hall	99	9"x9" grey w/ white & black streaks FT			Pos	30	SF	N	N	1	7/15/94	DAH/TJS		7%					
15	hall	99.5	floor tile adhesive (sample	M		Pos	30	SF	N	N	1	7/15/94	DAH/TJS		10%					
15	hall	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
15	hall	201	9"x9" charcoal w/ white sn	M		Pos	340	SF	N	N	1	7/15/94	DAH/TJS		3%					
15	hall	201.5	floor tile adhesive (sample	M		Pos	340	SF	N	N	1	7/15/94	DAH/TJS		5%					
15	room 1500	1	<4" white fibrous PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
15	room 1500	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS		35%					
15	room 1500	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1500	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
15	room 1500	16	4"-8" white fibrous PI	T		Pos	56	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	room 1500	17	4"-8" PFI on white fibrous	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1500	20	4"-8" felt w/ tar PI	T		Pos	4	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1500	21	4"-8" PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1500	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
15	room 1500	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1500	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS							
15	room 1510	1	<4" white fibrous PI	T		Pos	33	LF	F	L	3	7/15/94	DAH/TJS	7%	5%					
15	room 1510	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS		35%					
15	room 1510	5	<4" felt with tar PI	T		Pos	200	LF	F	M	3	7/15/94	DAH/TJS		60%					
15	room 1510	6	<4" fibrous PFI on felt	T		Pos	36	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
15	room 1510	16	4"-8" white fibrous PI	T		Pos	123	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	room 1510	17	4"-8" PFI on white fibrous	T		Pos	25	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1510	20	4"-8" felt w/ tar PI	T		Pos	65	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1510	21	4"-8" PFI on felt	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1510	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
15	room 1510	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1510	147	cloth vibration joint	M	ND		3	EA	N	N	0	8/5/94	DAH/TJS							
15	room 1513	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1513	147	cloth vibration joint	M	ND		1	EA	N	N		8/5/94	DAH/TJS							



15	room 1521	11	<4" fiberglass w/ tar PI	T	ND		7	LF	F	N	0	7/15/94	DAH/TJS						
15	room 1521	12	<4" PFI on fiberglass w/ ta	T		Pos	2	EA	F	N	2	9/8/94	DAH/TJS	15%	15%				
15	room 1521	13	<4" PFI on fiberglass	T	ND		2	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1521	26	4"-8" fiberglass w/ tar PI	T	ND		3	LF	F	N	0	7/15/94	DAH/TJS						
15	room 1521	27	4"-8" PFI on fiberglass w/	T		Pos	3	EA	F	N	2	9/8/94	DAH/TJS	15%	15%				
15	room 1521	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1521	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1521	148	lab top	M		Pos	60	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1521	1003	unable to fully view space																
15	room 1522	5	<4" felt with tar PI	T		Pos	11	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1522	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	M	4	7/15/94	DAH/TJS	12%	3%				
15	room 1522	13	<4" PFI on fiberglass	T	ND		10	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1522	20	4"-8" felt w/ tar PI	T		Pos	11	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1522	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
15	room 1522	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1522	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1522	148	lab top	M		Pos	18	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1522	195	black transite	M		Pos	55	SF	N	N	1	9/8/94	DAH/TJS		25%				
15	room 1522	198	cream w/ black streaks lin	M	ND		187	LF	N	N	0	9/8/94	DAH/TJS						
15	room 1522	198.5	linoleum adhesive (sample	M	ND		187	SF	N	N	0	9/8/94	DAH/TJS						
15	room 1524	5	<4" felt with tar PI	T		Pos	16	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1524	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1524	16	4"-8" white fibrous PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
15	room 1524	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1524	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1524	148	lab top	M		Pos	100	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1525	5	<4" felt with tar PI	T		Pos	13	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1525	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1525	11	<4" fiberglass w/ tar PI	T	ND		38	LF	F	N	0	7/15/94	DAH/TJS						
15	room 1525	12	<4" PFI on fiberglass w/ ta	T		Pos	10	EA	F	N	2	9/8/94	DAH/TJS	15%	15%				
15	room 1525	13	<4" PFI on fiberglass	T	ND		8	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1525	16	4"-8" white fibrous PI	T		Pos	50	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
15	room 1525	17	4"-8" PFI on white fibrous	T		Pos	12	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
15	room 1525	17	4"-8" PFI on white fibrous	T		Pos	1	EA	F	H	4	7/15/94	DAH/TJS	3%	7%				

15	room 1525	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1525	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1525	148	lab top	M		Pos	96	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1525	149	lab sink	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS						
15	room 1526	1	<4" white fibrous PI	T		Pos	26	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
15	room 1526	2	<4" PFI on white fibrous	T		Pos	14	EA	F	N	2	7/15/94	DAH/TJS		35%				
15	room 1526	5	<4" felt with tar PI	T		Pos	30	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1526	6	<4" fibrous PFI on felt	T		Pos	13	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1526	13	<4" PFI on fiberglass	T	ND		5	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1526	16	4"-8" white fibrous PI	T		Pos	26	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
15	room 1526	17	4"-8" PFI on white fibrous	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
15	room 1526	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1526	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1526	148	lab top	M		Pos	58	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1526	167	black sink coating	M		Pos	1	EA	N	N	1	7/15/94	DAH/TJS		10%				
15	room 1528	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1528	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1528	9	<4" cork w/ tar PI	T	ND		10	LF	N	N	0	7/15/94	DAH/TJS						
15	room 1528	11	<4" fiberglass w/ tar PI	T	ND		29	LF	F	N	0	7/15/94	DAH/TJS						
15	room 1528	12	<4" PFI on fiberglass w/ ta	T		Pos	8	EA	F	N	2	9/8/94	DAH/TJS	15%	15%				
15	room 1528	13	<4" PFI on fiberglass	T	ND		15	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1528	20	4"-8" felt w/ tar PI	T		Pos	1	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1528	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
15	room 1528	26	4"-8" fiberglass w/ tar PI	T	ND		3	LF	F	N	0	7/15/94	DAH/TJS						
15	room 1528	27	4"-8" PFI on fiberglass w/	T		Pos	1	EA	F	N	2	9/8/94	DAH/TJS	15%	15%				
15	room 1528	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1528	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
15	room 1528	148	lab top	M		Pos	87	SF	N	N	1	7/15/94	DAH/TJS		30%				
15	room 1528	149	lab sink	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS						
15	room 1529	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1529	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1529	9	<4" cork w/ tar PI	T	ND		10	LF	N	N	0	7/15/94	DAH/TJS						
15	room 1529	13	<4" PFI on fiberglass	T	ND		4	EA	F	N	0	9/8/94	DAH/TJS						
15	room 1529	16	4"-8" white fibrous PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				

15	room 1529	17	4"-8" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1529	20	4"-8" felt w/ tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1529	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1529	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1529	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
15	room 1529	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1529	148	lab top	M		Pos	110	SF	N	N	1	7/15/94	DAH/TJS		30%					
15	room 1529	149	lab sink	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS							
15	room 1529	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS							
15	room 1529	1003	unable to fully view space																	
15	room 1530	5	<4" felt with tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1530	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
15	room 1530	9	<4" cork w/ tar PI	T	ND		10	LF	N	N	0	7/15/94	DAH/TJS							
15	room 1530	13	<4" PFI on fiberglass	T	ND		5	EA	F	N	0	9/8/94	DAH/TJS							
15	room 1530	16	4"-8" white fibrous PI	T		Pos	28	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	room 1530	17	4"-8" PFI on white fibrous	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1530	20	4"-8" felt w/ tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1530	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1530	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1530	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
15	room 1530	199	black pipe putty	M		Pos	8	LF	N	N	1	9/8/94	DAH/TJS		12%					
15	room 1535	1	<4" white fibrous PI	T		Pos	75	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
15	room 1535	2	<4" PFI on white fibrous	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS		35%					
15	room 1535	5	<4" felt with tar PI	T		Pos	38	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1535	6	<4" fibrous PFI on felt	T		Pos	14	EA	F	M	3	7/15/94	DAH/TJS	12%	3%					
15	room 1535	9	<4" cork w/ tar PI	T	ND		44	LF	N	N	0	7/15/94	DAH/TJS							
15	room 1535	10	<4" PFI on cork	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	15%	15%					
15	room 1535	13	<4" PFI on fiberglass	T	ND		31	EA	F	M	0	9/8/94	DAH/TJS							
15	room 1535	16	4"-8" white fibrous PI	T		Pos	13	LF	F	M	4	7/15/94	DAH/TJS	7%	7%					
15	room 1535	17	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1535	20	4"-8" felt w/ tar PI	T		Pos	31	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1535	21	4"-8" PFI on felt	T		Pos	11	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1535	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1535	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
15	room 1535	148	lab top	M		Pos	129	SF	N	N	1	7/15/94	DAH/TJS		30%					

15	room 1535	149	lab sink	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS								
15	room 1536	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1536	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
15	room 1540	5	<4" felt with tar PI	T		Pos	98	LF	F	N	2	7/15/94	DAH/TJS								60%
15	room 1540	6	<4" fibrous PFI on felt	T		Pos	27	EA	F	N	2	7/15/94	DAH/TJS	12%							3%
15	room 1540	16	4"-8" white fibrous PI	T		Pos	226	LF	F	N	2	7/15/94	DAH/TJS	7%							7%
15	room 1540	17	4"-8" PFI on white fibrous	T		Pos	31	EA	F	N	2	7/15/94	DAH/TJS	3%							7%
15	room 1540	20	4"-8" felt w/ tar PI	T		Pos	154	LF	F	N	2	7/15/94	DAH/TJS								60%
15	room 1540	21	4"-8" PFI on felt	T		Pos	22	EA	F	N	2	7/15/94	DAH/TJS	10%							15%
15	room 1540	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
15	room 1540	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1540	154	putty sealant around pipe	M	ND		3	LF	N	N	0	8/5/94	DAH/TJS								
15	room 1540(hatch)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1540(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1540(hatch)	163	tan duct adhesive	M	ND		65	LF	N	N	0	8/5/94	DAH/TJS								
15	room 1550		unable to access																		
15	room 1555-a	16	4"-8" white fibrous PI	T		Pos	7	LF	F	N	2	7/15/94	DAH/TJS	7%							7%
15	room 1555-a	17	4"-8" PFI on white fibrous	T		Pos	33	EA	F	N	2	7/15/94	DAH/TJS	3%							7%
15	room 1555-a	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
15	room 1555-a	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1555-a	147	cloth vibration joint	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS								
15	room 1555-b	5	<4" felt with tar PI	T		Pos	42	LF	F	N	2	7/15/94	DAH/TJS								60%
15	room 1555-b	6	<4" fibrous PFI on felt	T		Pos	13	EA	F	N	2	7/15/94	DAH/TJS	12%							3%
15	room 1555-b	13	<4" PFI on fiberglass	T	ND		6	EA	F	N	0	9/8/94	DAH/TJS								
15	room 1555-b	16	4"-8" white fibrous PI	T		Pos	30	LF	F	N	2	7/15/94	DAH/TJS	7%							7%
15	room 1555-b	17	4"-8" PFI on white fibrous	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	3%							7%
15	room 1555-b	20	4"-8" felt w/ tar PI	T		Pos	46	LF	F	N	2	7/15/94	DAH/TJS								60%
15	room 1555-b	21	4"-8" PFI on felt	T		Pos	15	EA	F	N	2	7/15/94	DAH/TJS	10%							15%
15	room 1555-b	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
15	room 1555-b	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
15	room 1555-b	257	tar flooring	M	ND		300	SF	N	N	0	9/8/94	DAH/TJS								

15	room 1560	5	<4" felt with tar PI	T		Pos	96	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1560	6	<4" fibrous PFI on felt	T		Pos	20	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
15	room 1560	11	<4" fiberglass w/ tar PI	T	ND		24	LF	F	N	0	7/15/94	DAH/TJS							
15	room 1560	12	<4" PFI on fiberglass w/ ta	T		Pos	5	EA	F	N	2	9/8/94	DAH/TJS	15%	15%					
15	room 1560	13	<4" PFI on fiberglass	T	ND		21	EA	F	N	0	9/8/94	DAH/TJS							
15	room 1560	16	4"-8" white fibrous PI	T		Pos	120	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	room 1560	17	4"-8" PFI on white fibrous	T		Pos	21	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1560	20	4"-8" felt w/ tar PI	T		Pos	56	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1560	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1560	28	4"-8" PFI on fiberglass	T		Pos	18	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
15	room 1560	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1560	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS							
15	room 1565	1	<4" white fibrous PI	T		Pos	15	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
15	room 1565	2	<4" PFI on white fibrous	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS		35%					
15	room 1565	5	<4" felt with tar PI	T		Pos	34	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1565	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
15	room 1565	16	4"-8" white fibrous PI	T		Pos	60	LF	F	L	3	7/15/94	DAH/TJS	7%	7%					
15	room 1565	17	4"-8" PFI on white fibrous	T		Pos	18	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1565	20	4"-8" felt w/ tar PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS		60%					
15	room 1565	21	4"-8" PFI on felt	T		Pos	10	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
15	room 1565	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
15	room 1565	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
15	room 1565	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1565	147	cloth vibration joint	M	ND		2	EA	N	N	0	8/5/94	DAH/TJS							
15	room 1565	196	bright green duct adhesive	M	ND		35	LF	N	N	0	9/8/94	DAH/TJS							
15	room 1570	16	4"-8" white fibrous PI	T		Pos	14	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
15	room 1570	17	4"-8" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1570	47	fluffy spray-on fireproofing	S	ND		40	SF	F	N	0	7/15/94	DAH/TJS							
15	room 1570	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
15	room 1570	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
15	room 1570-1	16	4"-8" white fibrous PI	T		Pos	13	LF	F	M	4	7/15/94	DAH/TJS	7%	7%					
15	room 1570-1	17	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
15	room 1570-1	47	fluffy spray-on fireproofing	S	ND		45	SF	F	N	0	7/15/94	DAH/TJS							

15	room 1570-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
15	room 1570-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1570-1	155	black tar on duct	M		Pos	260	SF	N	N	1	33089	DAH/TJS		5%				
15	room 1570-1	156	grey duct adhesive	M		Pos	15	LF	N	N	1	7/15/94	DAH/TJS		10%				
15	room 1570-1	184	black duct adhesive	M		Pos	4	LF	N	N	1	8/5/94	DAH/TJS		5%				
15	room 1571	5	<4" felt with tar PI	T		Pos	34	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1571	6	<4" fibrous PFI on felt	T		Pos	11	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
15	room 1571	16	4"-8" white fibrous PI	T		Pos	26	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
15	room 1571	17	4"-8" PFI on white fibrous	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
15	room 1571	20	4"-8" felt w/ tar PI	T		Pos	30	LF	F	N	2	7/15/94	DAH/TJS		60%				
15	room 1571	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
15	room 1571	24	4"-8" cork w/ tar PI	T	ND		10	LF	N	N	0	7/15/94	DAH/TJS						
15	room 1571	25	4"-8" PFI on cork	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	15%	35%				
15	room 1571	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
15	room 1571	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS						
15	room 1573	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
16	room 1600	1	<4" white fibrous PI	T		Pos	204	LF	F	L	3	7/15/94	DAH/TJS	7%	5%				
16	room 1600	2	<4" PFI on white fibrous	T		Pos	96	EA	F	N	2	7/15/94	DAH/TJS		35%				
16	room 1600	16	4"-8" white fibrous PI	T		Pos	514	LF	F	L	3	7/15/94	DAH/TJS	7%	7%				
16	room 1600	17	4"-8" PFI on white fibrous	T		Pos	139	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
16	room 1600	20	4"-8" felt w/ tar PI	T		Pos	100	LF	F	N	2	7/15/94	DAH/TJS		60%				
16	room 1600	21	4"-8" PFI on felt	T		Pos	29	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
16	room 1600	28	4"-8" PFI on fiberglass	T		Pos	11	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
16	room 1600	29	4"-8" cal-sil PI	T	ND		24	LF	F	N	0	9/8/94	DAH/TJS						
16	room 1600	30	4"-8" PFI on cal-sil	T	ND		19	EA	F	N	0	9/8/94	DAH/TJS						
16	room 1600	31	9"-14" white fibrous PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS	15%					
16	room 1600	32	9"-14" PFI on white fibrous	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS		25%				
16	room 1600	40	white fibrous tank insulatic	T		Pos	532	SF	F	N	2	7/15/94	DAH/TJS	5%	5%				
16	room 1600	41	black foam w/ mud tank in	T		Pos	556	SF	F	L	3	7/15/94	DAH/TJS	< 1%	80%				
16	room 1600	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
16	room 1600	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1600	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
16	room 1600		pink fibrous debris	M		Pos	300	SF	F	H	4								

16	room 1600(hatches)		listed in rooms 1555 & 1540																
16	room 1625	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1635	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1635	163	tan duct adhesive	M	ND		114	LF	N	N	0	8/5/94	DAH/TJS						
16	room 1635	176	black tar sealant	M		Pos	3	LF	N	N	1	8/5/94	DAH/TJS		20%				
16	room 1635	196	bright green duct adhesive	M	ND		552	LF	N	N	0	9/8/94	DAH/TJS						
16	room 1655	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1655	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
16	room 1655	163	tan duct adhesive	M	ND		40	LF	N	N	0	8/5/94	DAH/TJS						
16	room 1660	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1660	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1660	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
16	room 1660	163	tan duct adhesive	M	ND		117	LF	N	N	0	8/5/94	DAH/TJS						
16	room 1660	196	bright green duct adhesive	M	ND		108	LF	N	N	0	9/8/94	DAH/TJS						
16	room 1670	16	4"-8" white fibrous PI	T		Pos	34	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
16	room 1670	17	4"-8" PFI on white fibrous	T		Pos	16	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
16	room 1670	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
16	room 1670	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
17	penthouse	151	transite	M		Pos	136	SF	N	N	1	9/8/94	DAH/TJS		40%				
17	penthouse	155	black tar on duct	M		Pos	150	SF	N	N	1	33089	DAH/TJS		5%				
17	penthouse	236	roofing	M	ND		1221	SF	N	N	0	9/8/94	DAH/TJS						