

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
7	attic off stair J	28	4"-8" PFI on fiberglass	T		Pos	2	EA	F	N		9/8/94	DAH/TJS	20%	10%					
7	attic off stair J	43	spray-on fireproofing	S	ND		40	SF	F	N		9/8/94	DAH/TJS							
7	attic off stair J	46	patching plaster	S	ND		6	SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
7	attic off stair J	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	155	black tar on duct	M		Pos	16	SF	N	N	1	8/5/94	DAH/TJS		5%					
7	attic off stair J	290	vermiculite insulation	M	ND		360	SF	F	N	0		DAH/TJS							
7	elevator 14 machine r	400	brick mortar	M	ND			SF	F	N	0	9/30/94	DAH / TJS							
7	elevator 14 machine r	401	clay tile mortar	M	ND			SF	F	N	0	9/30/94	DAH / TJS							
7	elevator lobby	13	<4" PFI on fiberglass	T	ND		4	EA	F	N	0	9/8/94	DAH/TJS							
7	elevator lobby	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	elevator lobby	73	12"x12" cream w/ tan, gre	M	ND		329	SF	N	N	0	7/15/94	DAH/TJS							
7	elevator lobby	73.5	floor tile adhesive (sample	M	ND		329	SF	N	N	0	7/15/94	DAH/TJS							
7	elevator lobby	74	12"x12" salmon w/ grey &	M	ND		51	SF	N	N	0	7/15/94	DAH/TJS							
7	elevator lobby	74.5	floor tile adhesive (sample	M	ND		51	SF	N	N	0	7/15/94	DAH/TJS							
7	elevator lobby	119	2'x2' swirled pinhole CT	M		Pos	8	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	elevator lobby	128	2'x4' cratered CT	M	ND		18	SF	F	N	0	9/8/94	DAH/TJS							
7	elevator lobby	129	2'x4' longitudinal wormhole	M	ND		330	SF	F	N	0	7/15/94	DAH/TJS							
7	elevator lobby	134	2'x4' tiny pinhole w/ fissure	M	ND		24	SF	F	N	0	9/8/94	DAH/TJS							
7	elevator lobby	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	elevator lobby	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	hall 725-760	5	<4" felt with tar PI	T		Pos	56	LF	F	N	2	7/15/94	DAH/TJS		60%					
7	hall 725-760	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	L	3	7/15/94	DAH/TJS	12%	3%					
7	hall 725-760	13	<4" PFI on fiberglass	T	ND		19	EA	F	N	0	9/8/94	DAH/TJS							
7	hall 725-760	28	4"-8" PFI on fiberglass	T		Pos	11	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
7	hall 725-760	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	hall 725-760	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	hall 725-760	73	12"x12" cream w/ tan, gre	M	ND		1330	SF	N	N	0	7/15/94	DAH/TJS							
7	hall 725-760	73.5	floor tile adhesive (sample	M	ND		1330	SF	N	N	0	7/15/94	DAH/TJS							
7	hall 725-760	74	12"x12" salmon w/ grey &	M	ND		36	SF	N	N	0	7/15/94	DAH/TJS							

7	north attic	429	grey pipe sealant	M		Pos	6	LF	N	N	1	9/30/94	DAH / TJS		3%					
7	north attic	1003	white fibrous debris	M		Pos	3	SF	F	H	4									
7	northwest attic	1	<4" white fibrous PI	T		Pos	80	LF	F	L	3	9/30/94	DAH / TJS	15%	5%					
7	northwest attic	2	<4" PFI on white fibrous	T		Pos	12	EA	F	N	2	9/30/94	DAH / TJS	10%	10%					
7	northwest attic	5	<4" felt with tar PI	T	ND		70	LF	F	L	0	9/30/94	DAH / TJS							
7	northwest attic	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2	9/30/94	DAH / TJS	10%	20%					
7	northwest attic	9	<4" fibrous PFI on FG	T	ND		6	EA	F	N	0	9/30/94	DAH / TJS							
7	northwest attic	21	4"-8" white fibrous PI	T		Pos	40	LF	F	L	3	9/30/94	DAH / TJS		15%					
7	northwest attic	22	4"-8" PFI on white fibrous	T		Pos	10	EA	F	N	2	9/30/94	DAH / TJS		60%					
7	northwest attic	74	cementitious spray-on	S	ND		54	SF	F	N	0	9/30/94	DAH / TJS							
7	northwest attic	400	brick mortar	M	ND			SF	F	N	0	9/30/94	DAH / TJS							
7	northwest attic	411	sheetrock and mud	M	ND			SF	F	N	0	9/30/94	DAH / TJS							
7	northwest attic	442	painted-on tar	M		Pos	6	LF	N	N	1	9/30/94	DAH / TJS		10%					
7	northwest attic	461	roofing tar	M	ND		2	SF	N	N	0	9/30/94	DAH / TJS							
7	room 2A	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 2C	1	<4" white fibrous PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
7	room 2C	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%					
7	room 2C	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
7	room 2C	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 2C	55	9"x9" grey w/ white smear	M		Pos	5	SF	N	N	1	7/15/94	DAH/TJS		20%					
7	room 2C	55.5	floor tile adhesive (sample	M	ND		5	SF	N	N	0	7/15/94	DAH/TJS							
7	room 2C	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
7	room 2C	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 701	5	<4" felt with tar PI	T		Pos	3	LF	F	N	2	7/15/94	DAH/TJS		60%					
7	room 701	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
7	room 701	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 701	73	12"x12" cream w/ tan, gre	M	ND		58	SF	N	N	0	7/15/94	DAH/TJS							
7	room 701	73.5	floor tile adhesive (sample	M	ND		58	SF	N	N	0	7/15/94	DAH/TJS							
7	room 701	125	2'x4' swirled pinhole CT	M		Pos	46	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 701	134	2'x4' tiny pinhole w/ fissure	M	ND		12	SF	F	N	0	9/8/94	DAH/TJS							
7	room 701	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 701	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 701	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							

7	room 702	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 702	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 702	73	12"x12" cream w/ tan, gre	M	ND		72	SF	N	N	0	7/15/94	DAH/TJS							
7	room 702	73.5	floor tile adhesive (sample	M	ND		72	SF	N	N	0	7/15/94	DAH/TJS							
7	room 702	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 702(hatch)	5	<4" felt with tar PI	T		Pos	44	LF	F	N	2	7/15/94	DAH/TJS							60%
7	room 702(hatch)	6	<4" fibrous PFI on felt	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	12%						3%
7	room 702(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 705	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 705	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 705	73	12"x12" cream w/ tan, gre	M	ND		76	SF	N	N	0	7/15/94	DAH/TJS							
7	room 705	73.5	floor tile adhesive (sample	M	ND		76	SF	N	N	0	7/15/94	DAH/TJS							
7	room 705	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 705(hatch)	5	<4" felt with tar PI	T		Pos	13	LF	F	N	2	7/15/94	DAH/TJS							60%
7	room 705(hatch)	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS	12%						3%
7	room 705(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 706	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 706	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 706	73	12"x12" cream w/ tan, gre	M	ND		76	SF	N	N	0	7/15/94	DAH/TJS							
7	room 706	73.5	floor tile adhesive (sample	M	ND		76	SF	N	N	0	7/15/94	DAH/TJS							
7	room 706	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 706(hatch)	5	<4" felt with tar PI	T		Pos	9	LF	F	N	2	7/15/94	DAH/TJS							60%
7	room 706(hatch)	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	12%						3%
7	room 706(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 709	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 709	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 709	73	12"x12" cream w/ tan, gre	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS							
7	room 709	73.5	floor tile adhesive (sample	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS							
7	room 709	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 709	1001	unable to view above ceiling																	

7	room 710	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 710	73	12"x12" cream w/ tan, gre	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 710	73.5	floor tile adhesive (sample	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 710	125	2'x4' swirled pinhole CT	M		Pos	80	SF	F	N	2	8/5/94	DAH/TJS		3%				
7	room 710	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 710	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 711	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 711	73	12"x12" cream w/ tan, gre	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
7	room 711	73.5	floor tile adhesive (sample	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
7	room 711	125	2'x4' swirled pinhole CT	M		Pos	90	SF	F	N	2	8/5/94	DAH/TJS		3%				
7	room 711	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 711	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 711	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 712	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 712	73	12"x12" cream w/ tan, gre	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 712	73.5	floor tile adhesive (sample	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 712	125	2'x4' swirled pinhole CT	M		Pos	80	SF	F	N	2	8/5/94	DAH/TJS		3%				
7	room 712	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 712	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 712	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 714	5	<4" felt with tar PI	T		Pos	132	LF	F	N	2	7/15/94	DAH/TJS		60%				
7	room 714	6	<4" fibrous PFI on felt	T		Pos	38	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
7	room 714	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 714	125	2'x4' swirled pinhole CT	M		Pos	324	SF	F	N	0	8/5/94	DAH/TJS		3%				
7	room 714	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 714	148	lab top	M		Pos	14	SF	N	N	1	7/15/94	DAH/TJS		30%				
7	room 714	167	black sink coating	M		Pos	1	EA	N	N	1	7/15/94	DAH/TJS		10%				
7	room 715	5	<4" felt with tar PI	T		Pos	72	LF	F	N	2	7/15/94	DAH/TJS		60%				
7	room 715	6	<4" fibrous PFI on felt	T		Pos	19	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
7	room 715	20	4"-8" felt w/ tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%				
7	room 715	21	4"-8" PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
7	room 715	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						

7	room 729	125	2'x4' swirled pinhole CT	M		Pos	9	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 729	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 729	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 730	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 730	125	2'x4' swirled pinhole CT	M		Pos	50	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 730	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 731	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 731	73	12"x12" cream w/ tan, gre	M	ND		25	SF	N	N	0	7/15/94	DAH/TJS							
7	room 731	73.5	floor tile adhesive (sample	M	ND		25	SF	N	N	0	7/15/94	DAH/TJS							
7	room 731	125	2'x4' swirled pinhole CT	M		Pos	25	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 731	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 731	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 732	5	<4" felt with tar PI	T		Pos	100	LF	F	N	2	7/15/94	DAH/TJS		60%					
7	room 732	6	<4" fibrous PFI on felt	T		Pos	11	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
7	room 732	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 732	47	fluffy spray-on fireproofing	S	ND		2	SF	F	N	0	7/15/94	DAH/TJS							
7	room 732	73	12"x12" cream w/ tan, gre	M	ND		10	SF	N	N	0	7/15/94	DAH/TJS							
7	room 732	73.5	floor tile adhesive (sample	M	ND		10	SF	N	N	0	7/15/94	DAH/TJS							
7	room 732	125	2'x4' swirled pinhole CT	M		Pos	135	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 732	129	2'x4' longitudinal wormhol	M	ND		10	SF	F	N	0	7/15/94	DAH/TJS							
7	room 732	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 732	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 733	5	<4" felt with tar PI	T		Pos	86	LF	F	N	2	7/15/94	DAH/TJS		60%					
7	room 733	6	<4" fibrous PFI on felt	T		Pos	22	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
7	room 733	6	<4" fibrous PFI on felt	T		Pos	1	EA	F	H	4	7/15/94	DAH/TJS	12%	3%					
7	room 733	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 733	47	fluffy spray-on fireproofing	S	ND		1	SF	F	N	0	7/15/94	DAH/TJS							
7	room 733	73	12"x12" cream w/ tan, gre	M	ND		118	SF	N	N	0	7/15/94	DAH/TJS							
7	room 733	73.5	floor tile adhesive (sample	M	ND		118	SF	N	N	0	7/15/94	DAH/TJS							
7	room 733	125	2'x4' swirled pinhole CT	M		Pos	124	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	room 733	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 733	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 733	167	black sink coating	M		Pos	2	EA	N	N	1	7/15/94	DAH/TJS		10%					

7	room 763	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763	73	12"x12" cream w/ tan, gre	M	ND		1200	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763	73.5	floor tile adhesive (sample	M	ND		1200	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763	102	1'x1' small pegboard CT	M		Pos	16	SF	F	N	2	8/5/94	DAH/TJS		3%				
7	room 763	102.5	ceiling tile adhesive (sampl	M	ND		16	SF	F	N	0	8/5/94	DAH/TJS						
7	room 763	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 763	250	1'x1' polka dot CT	M	ND		900	SF	F	N	0	8/5/94	DAH/TJS						
7	room 763	250.5	ceiling tile adhesive (sampl	M	ND		900	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 763	254	1'x1' swirled pinhole CT	M	ND		80	SF	F	N	0	9/8/94	DAH/TJS						
7	room 763	254.5	ceiling tile adhesive (sampl	M		Pos	80	SF	N	N	1	9/8/94	DAH/TJS		2%				
7	room 763(hatches)	1	<4" white fibrous PI	T		Pos	1	LF	F	H	4	7/15/94	DAH/TJS	7%	5%				
7	room 763(hatches)	13	<4" PFI on fiberglass	T	ND		5	EA	F	N	0	9/8/94	DAH/TJS						
7	room 763(hatches)	28	4"-8" PFI on fiberglass	T		Pos	3	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
7	room 763(hatches)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763(hatches)	1003	unable to fully view space																
7	room 763(hatches)		white fibrous PI debris	M		Pos	1	SF	F	H	4								
7	room 763-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763-1	73	12"x12" cream w/ tan, gre	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763-1	73.5	floor tile adhesive (sample	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 763-1(hatch)	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room 763-1(hatch)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 763-2	73	12"x12" cream w/ tan, gre	M	ND		401	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763-2	73.5	floor tile adhesive (sample	M	ND		401	SF	N	N	0	7/15/94	DAH/TJS						
7	room 763-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 763-2	250	1'x1' polka dot CT	M	ND		394	SF	F	N	0	8/5/94	DAH/TJS						
7	room 763-2	250.5	ceiling tile adhesive (sampl	M	ND		394	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 763-2	254	1'x1' swirled pinhole CT	M	ND		7	SF	F	N	0	9/8/94	DAH/TJS						
7	room 763-2	254.5	ceiling tile adhesive (sampl	M		Pos	7	SF	N	N	1	9/8/94	DAH/TJS		2%				
7	room 763-2	1001	unable to view above ceiling																

7	room 763-3	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-3	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-3	73	12"x12" cream w/ tan, gre	M	ND	144		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-3	73.5	floor tile adhesive (sample	M	ND	144		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-3	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 763-3	250	1'x1' polka dot CT	M	ND	117		SF	F	N	0	8/5/94	DAH/TJS							
7	room 763-3	250.5	ceiling tile adhesive (sampl	M	ND	117		SF	N	N	0	8/5/94	DAH/TJS							<1%
7	room 763-3	1001	unable to view above ceiling																	
7	room 763-4	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4	73	12"x12" cream w/ tan, gre	M	ND	66		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4	73.5	floor tile adhesive (sample	M	ND	66		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
7	room 763-4	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4	250	1'x1' polka dot CT	M	ND	66		SF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4	250.5	ceiling tile adhesive (sampl	M	ND	66		SF	N	N	0	8/5/94	DAH/TJS							<1%
7	room 763-4	1001	unable to view above ceiling																	
7	room 763-4a	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4a	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4a	73	12"x12" cream w/ tan, gre	M	ND	64		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4a	73.5	floor tile adhesive (sample	M	ND	64		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4a	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
7	room 763-4a	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4a	250	1'x1' polka dot CT	M	ND	64		SF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4a	250.5	ceiling tile adhesive (sampl	M	ND	64		SF	N	N	0	8/5/94	DAH/TJS							<1%
7	room 763-4a	1001	unable to view above ceiling																	
7	room 763-4b	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4b	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	room 763-4b	73	12"x12" cream w/ tan, gre	M	ND	134		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4b	73.5	floor tile adhesive (sample	M	ND	134		SF	N	N	0	7/15/94	DAH/TJS							
7	room 763-4b	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4b	250	1'x1' polka dot CT	M	ND	130		SF	F	N	0	8/5/94	DAH/TJS							
7	room 763-4b	250.5	ceiling tile adhesive (sampl	M	ND	130		SF	N	N	0	8/5/94	DAH/TJS							<1%

7	room 774	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 774	73	12"x12" cream w/ tan, gre	M	ND		54	SF	N	N	0	7/15/94	DAH/TJS						
7	room 774	73.5	floor tile adhesive (sample	M	ND		54	SF	N	N	0	7/15/94	DAH/TJS						
7	room 774	101	1'X1' fissured CT	M	ND		33	SF	F	N	0	7/15/94	DAH/TJS						
7	room 774	101.5	ceiling tile adhesive (samp	M	ND		33	SF	N	N	0	7/15/94	DAH/TJS						
7	room 774	129	2'x4' longitudinal wormhol	M	ND		42	SF	F	N	0	7/15/94	DAH/TJS						
7	room 774	134	2'x4' tiny pinhole w/ fissur	M	ND		6	SF	F	N	0	9/8/94	DAH/TJS						
7	room 774	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 774	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room 774	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 774		PFI on FG debris		ND		1	SF	F	H									
7	room 775	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 775	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 775	73	12"x12" cream w/ tan, gre	M	ND		66	SF	N	N	0	7/15/94	DAH/TJS						
7	room 775	73.5	floor tile adhesive (sample	M	ND		66	SF	N	N	0	7/15/94	DAH/TJS						
7	room 775	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 775	250	1'x1' polka dot CT	M	ND		52	SF	F	N	0	8/5/94	DAH/TJS						
7	room 775	250.5	ceiling tile adhesive (samp	M	ND		52	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 775(hatch)	13	<4" PFI on fiberglass	T	ND		3	EA	F	N	0	9/8/94	DAH/TJS						
7	room 775(hatch)	31	9"-14" white fibrous PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS	15%					
7	room 775(hatch)	32	9"-14" PFI on white fibrous	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS		25%				
7	room 775(hatch)	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room 775(hatch)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 775(hatch)		white fibrous PI debris	M		Pos	2	SF	F	H	4								
7	room 776	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 776	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 776	73	12"x12" cream w/ tan, gre	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 776	73.5	floor tile adhesive (sample	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room 776	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 776	250	1'x1' polka dot CT	M	ND		80	SF	F	N	0	8/5/94	DAH/TJS						
7	room 776	250.5	ceiling tile adhesive (samp	M	ND		80	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 776	1001	unable to view above ceiling																
7	room 777	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						

7	room 777	73	12"x12" cream w/ tan, gre	M	ND		98	SF	N	N	0	7/15/94	DAH/TJS						
7	room 777	73.5	floor tile adhesive (sample	M	ND		98	SF	N	N	0	7/15/94	DAH/TJS						
7	room 777	129	2'x4' longitudinal wormhol	M	ND		98	SF	F	N	0	7/15/94	DAH/TJS						
7	room 777	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 777	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 779	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 779	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 779	73	12"x12" cream w/ tan, gre	M	ND		64	SF	N	N	0	7/15/94	DAH/TJS						
7	room 779	73.5	floor tile adhesive (sample	M	ND		64	SF	N	N	0	7/15/94	DAH/TJS						
7	room 779	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 779	250	1'x1' polka dot CT	M	ND		64	SF	F	N	0	8/5/94	DAH/TJS						
7	room 779	250.5	ceiling tile adhesive (sampl	M	ND		64	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 779	1001	unable to view above ceiling																
7	room 780	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 780	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 780	73	12"x12" cream w/ tan, gre	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS						
7	room 780	73.5	floor tile adhesive (sample	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS						
7	room 780	103	1'x1' large fissure CT	M	ND		310	SF	F	N	0	9/8/94	DAH/TJS						
7	room 780	103.5	ceiling tile adhesive (sampl	M	ND		310	SF	N	N	0	9/8/94	DAH/TJS						
7	room 780	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 780	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
7	room 780	1001	unable to view above ceiling																
7	room 781	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 781	73	12"x12" cream w/ tan, gre	M	ND		104	SF	N	N	0	7/15/94	DAH/TJS						
7	room 781	73.5	floor tile adhesive (sample	M	ND		104	SF	N	N	0	7/15/94	DAH/TJS						
7	room 781	101	1'X1' fissured CT	M	ND		252	SF	F	N	0	7/15/94	DAH/TJS						
7	room 781	101.5	ceiling tile adhesive (sampl	M	ND		252	SF	N	N	0	7/15/94	DAH/TJS						
7	room 781	103	1'x1' large fissure CT	M	ND		104	SF	F	N	0	9/8/94	DAH/TJS						
7	room 781	103.5	ceiling tile adhesive (sampl	M	ND		104	SF	N	N	0	9/8/94	DAH/TJS						
7	room 781	128	2'x4' cratered CT	M	ND		104	SF	F	N	0	9/8/94	DAH/TJS						
7	room 781	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 781	1001	unable to view above ceiling																
7	room 791	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						

7	room 791	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 791	73	12"x12" cream w/ tan, gre	M	ND	120		SF	N	N	0	7/15/94	DAH/TJS						
7	room 791	73.5	floor tile adhesive (sample	M	ND	120		SF	N	N	0	7/15/94	DAH/TJS						
7	room 791	103	1'x1' large fissure CT	M	ND	280		SF	F	N	0	9/8/94	DAH/TJS						
7	room 791	103.5	ceiling tile adhesive (samp	M	ND	280		SF	N	N	0	9/8/94	DAH/TJS						
7	room 791	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 791	150	chalkboard	M	ND			EA	N	N	0	9/8/94	DAH/TJS						
7	room 791	1001	unable to view above ceiling																
7	room 793	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 793	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 793	73	12"x12" cream w/ tan, gre	M	ND	150		SF	N	N	0	7/15/94	DAH/TJS						
7	room 793	73.5	floor tile adhesive (sample	M	ND	150		SF	N	N	0	7/15/94	DAH/TJS						
7	room 793	103	1'x1' large fissure CT	M	ND	345		SF	F	N	0	9/8/94	DAH/TJS						
7	room 793	103.5	ceiling tile adhesive (samp	M	ND	345		SF	N	N	0	9/8/94	DAH/TJS						
7	room 793	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 793	1001	unable to view above ceiling																
7	room 795	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 795	73	12"x12" cream w/ tan, gre	M	ND	66		SF	N	N	0	7/15/94	DAH/TJS						
7	room 795	73.5	floor tile adhesive (sample	M	ND	66		SF	N	N	0	7/15/94	DAH/TJS						
7	room 795	129	2'x4' longitudinal wormhol	M	ND	52		SF	F	N	0	7/15/94	DAH/TJS						
7	room 795	134	2'x4' tiny pinhole w/ fissure	M	ND	14		SF	F	N	0	9/8/94	DAH/TJS						
7	room 795	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 795	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 796	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 796	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 796	73	12"x12" cream w/ tan, gre	M	ND	94		SF	N	N	0	7/15/94	DAH/TJS						
7	room 796	73.5	floor tile adhesive (sample	M	ND	94		SF	N	N	0	7/15/94	DAH/TJS						
7	room 796	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 796	250	1'x1' polka dot CT	M	ND	94		SF	F	N	0	8/5/94	DAH/TJS						
7	room 796	250.5	ceiling tile adhesive (samp	M	ND	94		SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 796	1001	unable to view above ceiling																
7	room 797	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 797	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						

7	room 797	73	12"x12" cream w/ tan, gre	M	ND		130	SF	N	N	0	7/15/94	DAH/TJS						
7	room 797	73.5	floor tile adhesive (sample	M	ND		130	SF	N	N	0	7/15/94	DAH/TJS						
7	room 797	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 797	250	1'x1' polka dot CT	M	ND		130	SF	F	N	0	8/5/94	DAH/TJS						
7	room 797	250.5	ceiling tile adhesive (sampl	M	ND		130	SF	N	N	0	8/5/94	DAH/TJS		<1%				
7	room 797	1001	unable to view above ceiling																
7	room 798	13	<4" PFI on fiberglass	T	ND		2	EA	F	N	0	9/8/94	DAH/TJS						
7	room 798	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room 798	73	12"x12" cream w/ tan, gre	M	ND		120	SF	N	N	0	7/15/94	DAH/TJS						
7	room 798	73.5	floor tile adhesive (sample	M	ND		120	SF	N	N	0	7/15/94	DAH/TJS						
7	room 798	129	2'x4' longitudinal wormhol	M	ND		120	SF	F	N	0	7/15/94	DAH/TJS						
7	room 798	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
7	room 798	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room 798	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room A740	1	<4" white fibrous PI	T		Pos	243	LF	F	L	3	9/30/94	DAH / TJS	15%	5%				
7	room A740	2	<4" PFI on white fibrous	T		Pos	116	EA	F	N	2	9/30/94	DAH / TJS	10%	10%				
7	room A740	9	<4" fibrous PFI on FG	T	ND		2	EA	F	N	2	9/30/94	DAH / TJS						
7	room A740	21	4"-8" white fibrous PI	T		Pos	168	LF	F	N	2	9/30/94	DAH / TJS		15%				
7	room A740	22	4"-8" PFI on white fibrous	T		Pos	58	EA	F	N	2	9/30/94	DAH / TJS		60%				
7	room A740	60	white fibrous tank insulatic	T		Pos	25	SF	F	N	2	9/30/94	DAH / TJS	15%	30%				
7	room A740	71	wall plaster	S	ND			SF	F	N	0	9/30/94	DAH / TJS						
7	room A740	412	cloth vibration joint	M	ND		8	EA	N	N	0	9/30/94	DAH / TJS						
7	room B700	1	<4" white fibrous PI	T		Pos	1	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
7	room B700	13	<4" PFI on fiberglass	T	ND		98	EA	F	N	0	9/8/94	DAH/TJS						
7	room B700	28	4"-8" PFI on fiberglass	T		Pos	146	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
7	room B700	37	9"-14" PFI on fiberglass	T	ND		15	EA	F	N	0	7/15/94	DAH/TJS						
7	room B700	40	white fibrous tank insulatic	T		Pos	35	SF	F	N	2	7/15/94	DAH/TJS	5%	5%				
7	room B700	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room B700	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room B700	55	9"x9" grey w/ white smear	M		Pos	80	SF	N	N	1	7/15/94	DAH/TJS		20%				
7	room B700	55.5	floor tile adhesive (sample	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS						
7	room B700	134	2'x4' tiny pinhole w/ fissure	M	ND		108	SF	F	N	0	9/8/94	DAH/TJS						
7	room B700	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room B700	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						

7	room B700	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
7	room B700	151	transite	M		Pos	168	SF	N	N	1	9/8/94	DAH/TJS		40%				
7	room B700	176	black tar sealant	M		Pos	3300	LF	N	N	1	8/5/94	DAH/TJS		20%				
7	room B700	187	roof flashing	M		Pos	350	LF	N	N	1	9/8/94	DAH/TJS		2%				
7	room B700	188	transite sealant	M	ND		56	LF	N	N	0	9/8/94	DAH/TJS						
7	room B770	13	<4" PFI on fiberglass	T	ND		6	EA	F	N	0	9/8/94	DAH/TJS						
7	room B770	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room B770	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room B770	151	transite	M		Pos	168	SF	N	N	1	9/8/94	DAH/TJS		40%				
7	room B770	188	transite sealant	M	ND		120	LF	N	N	0	9/8/94	DAH/TJS						
7	room B780	1	<4" white fibrous PI	T		Pos	58	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
7	room B780	2	<4" PFI on white fibrous	T		Pos	33	EA	F	N	2	7/15/94	DAH/TJS		35%				
7	room B780	13	<4" PFI on fiberglass	T	ND		52	EA	F	N	0	9/8/94	DAH/TJS						
7	room B780	16	4"-8" white fibrous PI	T		Pos	28	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
7	room B780	17	4"-8" PFI on white fibrous	T		Pos	14	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
7	room B780	24	4"-8" cork w/ tar PI	T	ND		53	LF	N	N	0	7/15/94	DAH/TJS						
7	room B780	25	4"-8" PFI on cork	T		Pos	25	EA	F	N	2	7/15/94	DAH/TJS	15%	35%				
7	room B780	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room B780	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room B780	147	cloth vibration joint	M	ND		2	EA	N	N	0	8/5/94	DAH/TJS						
7	room B780	155	black tar on duct	M		Pos	54	SF	N	N	1	8/5/94	DAH/TJS		5%				
7	room B780	171	white mud on FG duct insul	M		Pos	212	SF	N	N	1	9/8/94	DAH/TJS		75%				
7	room C722	1	<4" white fibrous PI	T		Pos	78	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
7	room C722	2	<4" PFI on white fibrous	T		Pos	41	EA	F	N	2	7/15/94	DAH/TJS		35%				
7	room C722	16	4"-8" white fibrous PI	T		Pos	68	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
7	room C722	17	4"-8" PFI on white fibrous	T		Pos	20	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
7	room C722	24	4"-8" cork w/ tar PI	T	ND		84	LF	N	N	0	7/15/94	DAH/TJS						
7	room C722	25	4"-8" PFI on cork	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	15%	35%				
7	room C722	28	4"-8" PFI on fiberglass	T		Pos	5	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
7	room C722	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
7	room C722	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
7	room C722	147	cloth vibration joint	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS						
7	room C722	155	black tar on duct	M		Pos	340	SF	N	N	1	8/5/94	DAH/TJS		5%				
7	room C722	171	white mud on FG duct insul	M		Pos	437	SF	N	N	1	9/8/94	DAH/TJS		75%				

7	room C722-1	155	black tar on duct	M		Pos	40	SF	N	N	1	8/5/94	DAH/TJS		5%					
7	room C722-1	156	grey duct adhesive	M	ND		86	LF	N	N	0	7/15/94	DAH/TJS							
7	room C722-1	187	roof flashing	M		Pos	32	LF	N	N	1	9/8/94	DAH/TJS		2%					
7	waiting area	28	4"-8" PFI on fiberglass	T		Pos	4	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
7	waiting area	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	waiting area	73	12"x12" cream w/ tan, gre	M	ND		620	SF	N	N	0	7/15/94	DAH/TJS							
7	waiting area	73.5	floor tile adhesive (sample	M	ND		620	SF	N	N	0	7/15/94	DAH/TJS							
7	waiting area	74	12"x12" salmon w/ grey &	M	ND		32	SF	N	N	0	7/15/94	DAH/TJS							
7	waiting area	74.5	floor tile adhesive (sample	M	ND		32	SF	N	N	0	7/15/94	DAH/TJS							
7	waiting area	125	2'x4' swirled pinhole CT	M		Pos	620	SF	F	N	2	8/5/94	DAH/TJS		3%					
7	waiting area	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
7	waiting area	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	waiting area	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	waiting area	1003	unable to fully view space																	
8	elevator lobby	119	2'x2' swirled pinhole CT	M		Pos	304	SF	F	N	2	8/5/94	DAH/TJS		3%					
8	elevator lobby	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
8	elevator lobby	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
8	elevator lobby	163	tan duct adhesive	M	ND		28	LF	N	N	0	8/5/94	DAH/TJS							
8	elevator lobby	229	12"x12" blueish-grey markt	M	ND		112	SF	N	N	0	9/8/94	DAH/TJS							
8	elevator lobby	229.5	floor tile adhesive (sample	M	ND		112	SF	N	N	0	9/8/94	DAH/TJS							
8	elevator lobby	230	12"x12" white w/ grey flecl	M	ND		256	SF	N	N	0	9/8/94	DAH/TJS							
8	elevator lobby	230.5	floor tile adhesive (sample	M	ND		256	SF	N	N	0	9/8/94	DAH/TJS							
8	hall(hatch)	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS							
8	hall	47	fluffy spray-on fireproofing	S	ND		30	SF	F	N	0	7/15/94	DAH/TJS							
8	hall	119	2'x2' swirled pinhole CT	M		Pos	956	SF	F	N	2	8/5/94	DAH/TJS		3%					
8	hall	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
8	hall	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
8	hall	154	putty sealant around pipe	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS							
8	hall	163	tan duct adhesive	M	ND		250	LF	N	N	0	8/5/94	DAH/TJS							
8	hall	229	12"x12" blueish-grey markt	M	ND		402	SF	N	N	0	9/8/94	DAH/TJS							
8	hall	229.5	floor tile adhesive (sample	M	ND		402	SF	N	N	0	9/8/94	DAH/TJS							
8	hall	230	12"x12" white w/ grey flecl	M	ND		654	SF	N	N	0	9/8/94	DAH/TJS							

8	hall	230.5	floor tile adhesive (sample	M	ND		654	SF	N	N	0	9/8/94	DAH/TJS								
8	room 801	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 801	154	putty sealant around pipe	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS								
8	room 801	162	red pipe sealant	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
8	room 801	163	tan duct adhesive	M	ND		31	LF	N	N	0	8/5/94	DAH/TJS								
8	room 804	47	fluffy spray-on fireproofing	S	ND		20	SF	F	N	0	7/15/94	DAH/TJS								
8	room 804	125	2'x4' swirled pinhole CT	M		Pos	100	SF	F	N	2	8/5/94	DAH/TJS		3%						
8	room 804	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 804	154	putty sealant around pipe	M	ND		2	LF	N	N	0	8/5/94	DAH/TJS								
8	room 804	163	tan duct adhesive	M	ND		20	LF	N	N	0	8/5/94	DAH/TJS								
8	room 804(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 806	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 806	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
8	room 806	163	tan duct adhesive	M	ND		30	LF	N	N	0	8/5/94	DAH/TJS								
8	room 806	191	grey & white pebbled linoleum	M	ND		70	SF	N	N	0	9/8/94	DAH/TJS								
8	room 806	191.5	linoleum adhesive (sample	M	ND		70	SF	N	N	0	9/8/94	DAH/TJS								
8	room 806	192	shiny black lab top	M	ND		6	SF	N	N	0	9/8/94	DAH/TJS								
8	room 806	271	2'X4' smooth white CT	M	ND		62	SF	F	N	0	9/8/94	DAH/TJS								
8	room 810	9	<4" cork w/ tar PI	T	ND		20	LF	N	N	0	7/15/94	DAH/TJS								
8	room 810	47	fluffy spray-on fireproofing	S	ND		60	SF	F	N	0	7/15/94	DAH/TJS								
8	room 810	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 810	163	tan duct adhesive	M	ND		60	LF	N	N	0	8/5/94	DAH/TJS								
8	room 810	191	grey & white pebbled linoleum	M	ND		580	SF	N	N	0	9/8/94	DAH/TJS								
8	room 810	191.5	linoleum adhesive (sample	M	ND		580	SF	N	N	0	9/8/94	DAH/TJS								
8	room 810	192	shiny black lab top	M	ND		136	SF	N	N	0	9/8/94	DAH/TJS								
8	room 810	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
8	room 810	194	hard white board	M	ND		23	SF	N	N	0	9/8/94	DAH/TJS								
8	room 810	271	2'X4' smooth white CT	M	ND		530	SF	F	N	0	9/8/94	DAH/TJS								
8	room 810-1	125	2'x4' swirled pinhole CT	M		Pos	90	SF	F	N	2	8/5/94	DAH/TJS		3%						
8	room 810-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 810-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								

8	room 820-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
8	room 820-2	163	tan duct adhesive	M	ND		10	LF	N	N	0	8/5/94	DAH/TJS								
8	room 825	191	grey & white pebbled linoleum	M	ND		50	SF	N	N	0	9/8/94	DAH/TJS								
8	room 825	191.5	linoleum adhesive (sample)	M	ND		50	SF	N	N	0	9/8/94	DAH/TJS								
8	room 825	1001	unable to view above ceiling																		
8	room 827	191	grey & white pebbled linoleum	M	ND		210	SF	N	N	0	9/8/94	DAH/TJS								
8	room 827	191.5	linoleum adhesive (sample)	M	ND		210	SF	N	N	0	9/8/94	DAH/TJS								
8	room 827	1001	unable to view above ceiling																		
8	room 827-1	191	grey & white pebbled linoleum	M	ND		50	SF	N	N	0	9/8/94	DAH/TJS								
8	room 827-1	191.5	linoleum adhesive (sample)	M	ND		50	SF	N	N	0	9/8/94	DAH/TJS								
8	room 827-1	1001	unable to view above ceiling																		
8	room 830	125	2'x4' swirled pinhole CT	M		Pos	144	SF	F	N	2	8/5/94	DAH/TJS								3%
8	room 830	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 830	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
8	room 830	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
8	room 830	162	red pipe sealant	M	ND		10	LF	N	N	0	8/5/94	DAH/TJS								
8	room 830	163	tan duct adhesive	M	ND		35	LF	N	N	0	8/5/94	DAH/TJS								
8	room 835	47	fluffy spray-on fireproofing	S	ND		160	SF	F	N	0	7/15/94	DAH/TJS								
8	room 835	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 835	154	putty sealant around pipe	M	ND		7	LF	N	N	0	8/5/94	DAH/TJS								
8	room 835	163	tan duct adhesive	M	ND		98	LF	N	N	0	8/5/94	DAH/TJS								
8	room 835	191	grey & white pebbled linoleum	M	ND		580	SF	N	N	0	9/8/94	DAH/TJS								
8	room 835	191.5	linoleum adhesive (sample)	M	ND		580	SF	N	N	0	9/8/94	DAH/TJS								
8	room 835	192	shiny black lab top	M	ND		160	SF	N	N	0	9/8/94	DAH/TJS								
8	room 835	193	shiny black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS								
8	room 835	194	hard white board	M	ND		23	SF	N	N	0	9/8/94	DAH/TJS								
8	room 835	271	2'X4' smooth white CT	M	ND		556	SF	F	N	0	9/8/94	DAH/TJS								
8	room 837	47	fluffy spray-on fireproofing	S	ND		30	SF	F	N	0	7/15/94	DAH/TJS								
8	room 837	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 837	191	grey & white pebbled linoleum	M	ND		120	SF	N	N	0	9/8/94	DAH/TJS								
8	room 837	191.5	linoleum adhesive (sample)	M	ND		120	SF	N	N	0	9/8/94	DAH/TJS								

8	room 837	192	shiny black lab top	M	ND		44	SF	N	N	0	9/8/94	DAH/TJS									
8	room 837	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS									
8	room 837	271	2'X4' smooth white CT	M	ND		148	SF	F	N	0	9/8/94	DAH/TJS									
8	room 840	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 840	191	grey & white pebbled linoleum	M	ND		628	SF	N	N	0	9/8/94	DAH/TJS									
8	room 840	191.5	linoleum adhesive (sample)	M	ND		628	SF	N	N		9/8/94	DAH/TJS									
8	room 840	192	shiny black lab top	M	ND		122	SF	N	N		9/8/94	DAH/TJS									
8	room 840	193	shiny black lab sink	M	ND		2	EA	N	N		9/8/94	DAH/TJS									
8	room 840	194	hard white board	M	ND		23	SF	N	N		9/8/94	DAH/TJS									
8	room 840	271	2'X4' smooth white CT	M	ND		628	SF	F	N		9/8/94	DAH/TJS									
8	room 844	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 844(hatch)	47	fluffy spray-on fireproofing	S	ND		40	SF	F	N	0	7/15/94	DAH/TJS									
8	room 844(hatch)	163	tan duct adhesive	M	ND		25	LF	N	N		8/5/94	DAH/TJS									
8	room 850	125	2'x4' swirled pinhole CT	M		Pos	108	SF	F	N	0	8/5/94	DAH/TJS								3%	
8	room 850	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 850	141	baseboard adhesive	M	ND			LF	F	N	0		DAH/TJS									
8	room 850	154	putty sealant around pipe	M	ND		1	LF	N	N		8/5/94	DAH/TJS									
8	room 850	163	tan duct adhesive	M	ND		15	LF	N	N		8/5/94	DAH/TJS									
8	room 850-1	125	2'x4' swirled pinhole CT	M		Pos	196	SF	F	N	0	8/5/94	DAH/TJS								3%	
8	room 850-1	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 850-1	141	baseboard adhesive	M	ND			LF	F	N	0		DAH/TJS									
8	room 850-1	163	tan duct adhesive	M	ND		24	LF	N	N		8/5/94	DAH/TJS									
8	room 850-2	125	2'x4' swirled pinhole CT	M		Pos	176	SF	F	N	0	8/5/94	DAH/TJS								3%	
8	room 850-2	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 850-2	141	baseboard adhesive	M	ND			LF	F	N	0		DAH/TJS									
8	room 850-2	163	tan duct adhesive	M	ND		24	LF	N	N		8/5/94	DAH/TJS									
8	room 854	140	sheetrock & mud	M	ND			SF	F	N	0		DAH/TJS									
8	room 854(hatch)	28	4"-8" PFI on fiberglass	T		Pos	1	EA	F	H	4	9/8/94	DAH/TJS								20%	10%
8	room 854(hatch)	47	fluffy spray-on fireproofing	S	ND		21	SF	F	N	0	7/15/94	DAH/TJS									

8	room 869	271	2'X4' smooth white CT	M	ND		66	SF	F	N	0	9/8/94	DAH/TJS								
8	room 871	9	<4" cork w/ tar PI	T	ND		24	LF	N	N	0	7/15/94	DAH/TJS								
8	room 871	47	fluffy spray-on fireproofing	S	ND		1	SF	F	N	0	7/15/94	DAH/TJS								
8	room 871	119	2'x2' swirled pinhole CT	M		Pos	10	SF	F	N	2	8/5/94	DAH/TJS		3%						
8	room 871	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 871	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
8	room 871	186	white paper	M		Pos	28	SF	F	N	2	8/5/94	DAH/TJS		85%						
8	room 871	271	2'X4' smooth white CT	M	ND		40	SF	F	N	0	9/8/94	DAH/TJS								
8	room 873	125	2'x4' swirled pinhole CT	M		Pos	72	SF	F	N	2	8/5/94	DAH/TJS		3%						
8	room 873	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 873	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
8	room 873	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
8	room 873	230	12"x12" white w/ grey fleck	M	ND		72	SF	N	N	0	9/8/94	DAH/TJS								
8	room 873	230.5	floor tile adhesive (sample)	M	ND		72	SF	N	N	0	9/8/94	DAH/TJS								
8	room 875	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room 875	151	transite	M		Pos	660	SF	N	N	1	9/8/94	DAH/TJS		40%						
8	room B877	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
8	room B877	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
8	room B877	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
8	room PC1		inaccessible																		
8	room PC2	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	elevator lobby	116	2'x2' single-sized pinhole CT	M	ND		28	SF	F	N	0	7/15/94	DAH/TJS								
9	elevator lobby	119	2'x2' swirled pinhole CT	M		Pos	276	SF	F	N	2	8/5/94	DAH/TJS		3%						
9	elevator lobby	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	elevator lobby	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
9	elevator lobby	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS								
9	elevator lobby	163	tan duct adhesive	M	ND		45	LF	N	N	0	8/5/94	DAH/TJS								
9	elevator lobby	213	12"x12" white, cream & tan	M	ND		336	SF	N	N	0	7/15/94	DAH/TJS								
9	elevator lobby	213.5	floor tile adhesive(sample)	M		Pos	336	SF	N	N	1	9/8/94	DAH/TJS		5%						

9	room 913	213.5	floor tile adhesive(sample	M		Pos	153	SF	N	N	1	9/8/94	DAH/TJS		5%						
9	room 913	269	2'x4' plastic coated CT	M	ND		126	SF	F	N	0	9/8/94	DAH/TJS								
9	room 913-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
9	room 913-1	125	2'x4' swirled pinhole CT	M		Pos	76	SF	F	N	2	8/5/94	DAH/TJS		3%						
9	room 913-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 913-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
9	room 913-1	169	black tar on insulation	M	ND		20	SF	N	N	0	8/5/94	DAH/TJS								
9	room 913-1(hatch)	169	black tar on insulation	M	ND		16	SF	N	N	0	8/5/94	DAH/TJS								
9	room 917	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
9	room 917	125	2'x4' swirled pinhole CT	M		Pos	64	SF	F	N	0	8/5/94	DAH/TJS		3%						
9	room 917	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
9	room 917	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
9	room 917	148	lab top	M		Pos	24	SF	N	N	1	7/15/94	DAH/TJS		30%						
9	room 917	163	tan duct adhesive	M	ND		4	LF	N	N	0	8/5/94	DAH/TJS								
9	room 917	213	12"x12" white, cream & ta	M	ND		64	SF	N	N	0	7/15/94	DAH/TJS								
9	room 917	213.5	floor tile adhesive(sample	M		Pos	64	SF	N	N	1	9/8/94	DAH/TJS		5%						
9	room 919	16	4"-8" white fibrous PI	T		Pos	1	LF	F	H	4	7/15/94	DAH/TJS	7%	7%						
9	room 919	47	fluffy spray-on fireproofing	S	ND		2	SF	F	N	0	7/15/94	DAH/TJS								
9	room 919	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 919	163	tan duct adhesive	M	ND		122	LF	N	N	0	8/5/94	DAH/TJS								
9	room 921	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 921	169	black tar on insulation	M	ND		30	SF	N	N	0	8/5/94	DAH/TJS								
9	room 921	182	tan w/white specks linoleu	M	ND		290	SF	N	N	0	8/5/94	DAH/TJS								
9	room 921	182.5	linoleum adhesive(sample	M	ND		290	SF	N	N	0	8/5/94	DAH/TJS								
9	room 921	192	shiny black lab top	M	ND		20	SF	N	N	0	9/8/94	DAH/TJS								
9	room 921	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS								
9	room 921	196	bright green duct adhesive	M	ND		8	LF	N	N	0	9/8/94	DAH/TJS								
9	room 921	269	2'x4' plastic coated CT	M	ND		264	SF	F	N	0	9/8/94	DAH/TJS								
9	room 925	47	fluffy spray-on fireproofing	S	ND		40	SF	F	N	0	7/15/94	DAH/TJS								
9	room 925	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 925	150	chalkboard	M	ND		1	EA	N	N	0	33123	DAH/TJS								

9	room 925	163	tan duct adhesive	M	ND		20	LF	N	N	0	8/5/94	DAH/TJS						
9	room 925	169	black tar on insulation	M	ND		40	SF	N	N	0	8/5/94	DAH/TJS						
9	room 925	182	tan w/white specks linoleu	M	ND		880	SF	N	N	0	8/5/94	DAH/TJS						
9	room 925	182.5	linoleum adhesive(sample	M	ND		940	SF	N	N	0	8/5/94	DAH/TJS						
9	room 925	192	shiney black lab top	M	ND		180	SF	N	N	0	9/8/94	DAH/TJS						
9	room 925	193	shiney black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS						
9	room 925	269	2'x4' plastic coated CT	M	ND		880	SF	F	N	0	9/8/94	DAH/TJS						
9	room 925-1	125	2'x4' swirled pinhole CT	M		Pos	80	SF	F	N	2	8/5/94	DAH/TJS		3%				
9	room 925-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 925-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 925-1	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
9	room 925-1	169	black tar on insulation	M	ND		20	SF	N	N	0	8/5/94	DAH/TJS						
9	room 925-1(hatch)	169	black tar on insulation	M	ND		16	SF	N	N	0	8/5/94	DAH/TJS						
9	room 935	43	spray-on fireproofing	S	ND		32	SF	F	N	0	9/8/94	DAH/TJS						
9	room 935	47	fluffy spray-on fireproofing	S	ND		40	SF	F	N	0	7/15/94	DAH/TJS						
9	room 935	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 935	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
9	room 935	150	chalkboard	M	ND		1	EA	N	N	0	33123	DAH/TJS						
9	room 935	163	tan duct adhesive	M	ND		85	LF	N	N	0	8/5/94	DAH/TJS						
9	room 935	182	tan w/white specks linoleu	M	ND		1140	SF	N	N	0	8/5/94	DAH/TJS						
9	room 935	182.5	linoleum adhesive(sample	M	ND		1140	SF	N	N	0	8/5/94	DAH/TJS						
9	room 935	192	shiney black lab top	M	ND		216	SF	N	N	0	9/8/94	DAH/TJS						
9	room 935	193	shiney black lab sink	M	ND		2	EA	N	N	0	9/8/94	DAH/TJS						
9	room 935	269	2'x4' plastic coated CT	M	ND		940	SF	F	N	0	9/8/94	DAH/TJS						
9	room 935-1	1	<4" white fibrous PI	T		Pos	29	LF	F	L	3	7/15/94	DAH/TJS	7%	5%				
9	room 935-1	2	<4" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS		35%				
9	room 935-1	47	fluffy spray-on fireproofing	S	ND		50	SF	F	N	0	7/15/94	DAH/TJS						
9	room 935-1	125	2'x4' swirled pinhole CT	M		Pos	76	SF	F	N	2	8/5/94	DAH/TJS		3%				
9	room 935-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 935-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 935-1	150	chalkboard	M	ND		1	EA	N	N	0	33123	DAH/TJS						
9	room 935-1	154	putty sealant around pipe	M	ND		1	LF	N	N	0	8/5/94	DAH/TJS						
9	room 935-1	163	tan duct adhesive	M	ND		12	LF	N	N	0	8/5/94	DAH/TJS						

9	room 953	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 953	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 953	169	black tar on insulation	M	ND		100	SF	N	N	0	8/5/94	DAH/TJS						
9	room 953	213	12"x12" white, cream & ta	M	ND		146	SF	N	N	0	7/15/94	DAH/TJS						
9	room 953	213.5	floor tile adhesive(sample	M		Pos	146	SF	N	N	1	9/8/94	DAH/TJS						5%
9	room 953-1	125	2'x4' swirled pinhole CT	M		Pos	120	SF	F	N	2	8/5/94	DAH/TJS						3%
9	room 953-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 953-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 953-1	163	tan duct adhesive	M	ND		8	LF	N	N	0	8/5/94	DAH/TJS						
9	room 953-1	192	shiny black lab top	M	ND		36	SF	N	N	0	9/8/94	DAH/TJS						
9	room 953-1	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
9	room 953-1	213	12"x12" white, cream & ta	M	ND		96	SF	N	N	0	7/15/94	DAH/TJS						
9	room 953-1	213.5	floor tile adhesive(sample	M		Pos	96	SF	N	N	1	9/8/94	DAH/TJS						5%
9	room 955	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 955(hatch)		NSMV																
9	room 957	125	2'x4' swirled pinhole CT	M		Pos	56	SF	F	N	2	8/5/94	DAH/TJS						3%
9	room 957	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 957	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 957	213	12"x12" white, cream & ta	M	ND		56	SF	N	N	0	7/15/94	DAH/TJS						
9	room 957	213.5	floor tile adhesive(sample	M		Pos	56	SF	N	N	1	9/8/94	DAH/TJS						5%
9	room 957(hatch)	47	fluffy spray-on fireproofing	S	ND		24	SF	F	N	0	7/15/94	DAH/TJS						
9	room 957(hatch)	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 957-1	119	2'x2' swirled pinhole CT	M		Pos	64	SF	F	N	2	8/5/94	DAH/TJS						3%
9	room 957-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
9	room 957-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
9	room 957-1	163	tan duct adhesive	M	ND		6	LF	N	N	0	8/5/94	DAH/TJS						
9	room 957-1	192	shiny black lab top	M	ND		26	SF	N	N	0	9/8/94	DAH/TJS						
9	room 957-1	193	shiny black lab sink	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS						
9	room 957-1	213	12"x12" white, cream & ta	M	ND		72	SF	N	N	0	7/15/94	DAH/TJS						
9	room 957-1	213.5	floor tile adhesive(sample	M		Pos	72	SF	N	N	1	9/8/94	DAH/TJS						5%
9	room 957-1	272	2'x4' bumpy pinhole CT	M	ND		8	SF	F	N	0	9/8/94	DAH/TJS						

9	room 969	269	2'x4' plastic coated CT	M	ND		54	SF	F	N	0	9/8/94	DAH/TJS								
9	room 971	5	<4" felt with tar PI	T		Pos	37	LF	F	N	2	7/15/94	DAH/TJS		60%						
9	room 971	6	<4" fibrous PFI on felt	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
9	room 971	9	<4" cork w/ tar PI	T	ND		23	LF	N	N	0	7/15/94	DAH/TJS								
9	room 971	13	<4" PFI on fiberglass	T	ND		5	EA	F	N	0	9/8/94	DAH/TJS								
9	room 971	16	4"-8" white fibrous PI	T		Pos	12	LF	F	L	3	7/15/94	DAH/TJS	7%	7%						
9	room 971	17	4"-8" PFI on white fibrous	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	3%	7%						
9	room 971	20	4"-8" felt w/ tar PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS		60%						
9	room 971	21	4"-8" PFI on felt	T		Pos	4	EA	F	L	3	7/15/94	DAH/TJS	10%	15%						
9	room 971	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 971	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room 971	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
9	room 971	186	white paper	M		Pos	28	SF	F	N	2	8/5/94	DAH/TJS		85%						
9	room 973	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room PC1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
9	room PC1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								