

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
5	hall B501-B508	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	hall B501-B508	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	hall B501-B508	55	9"x9" grey w/ white smears FT	M		Pos	724	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	hall B501-B508	55.5	floor tile adhesive (sample 55)	M	ND		724	SF	N	N	0	7/15/94	DAH/TJS							
5	hall B501-B508	56	9"x9" grey w/ white and grey streaks	M		Pos	1	SF	N	N	1	8/5/94	DAH/TJS		3%					
5	hall B501-B508	56.5	floor tile adhesive (sample 56)	M		Pos	1	SF	N	N	1	8/5/94	DAH/TJS		2%					
5	hall B501-B508	99	9"x9" grey w/ white & black streaks FT			Pos	2	SF	N	N	1	7/15/94	DAH/TJS		7%					
5	hall B501-B508	99.5	floor tile adhesive (sample 99)	M		Pos	2	SF	N	N	1	7/15/94	DAH/TJS		10%					
5	hall B501-B508	100	1'x1' pegboard CT	M	ND		576	SF	F	N	0	7/15/94	DAH/TJS							
5	hall B501-B508	100.5	ceiling tile adhesive (sample 100)	M		Pos	576	SF	N	N	1	9/8/94	DAH/TJS		10%					
5	hall B501-B508	102	1'x1' small pegboard CT	M		Pos	80	SF	F	N	2	8/5/94	DAH/TJS		3%					
5	hall B501-B508	102.5	ceiling tile adhesive (sample 102)	M	ND		80	SF	N	N	0	8/5/94	DAH/TJS							
5	hall B501-B508	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	hall B501-B508	201	9"x9" charcoal w/ white smears FT	M		Pos	4	SF	N	N	1	7/15/94	DAH/TJS		3%					
5	hall B501-B508	201.5	floor tile adhesive (sample 201)	M		Pos	4	SF	N	N	1	7/15/94	DAH/TJS		5%					
5	hall B501-B508	212	12"x12" grey w/ white & black streak	M		Pos	9	SF	N	N	1	7/15/94	DAH/TJS		10%					
5	hall B501-B508	212.5	floor tile adhesive (sample 212)	M	ND		9	SF	N	N	0	9/8/94	DAH/TJS							
5	hall B501-B508	255	1'x1' plain white CT	M	ND		74	SF	F	N	0	9/8/94	DAH/TJS							
5	hall B501-B508	255.5	ceiling tile adhesive (sample 255)	M	ND		74	SF	N	N	0	9/8/94	DAH/TJS							
5	hall B501-B508(h	1	<4" white fibrous PI	T		Pos	9	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	hall B501-B508(h	2	<4" PFI on white fibrous	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	hall B501-B508(h	5	<4" felt with tar PI	T		Pos	16	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	hall B501-B508(h	6	<4" fibrous PFI on felt	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
5	hall B501-B508(h	16	4"-8" white fibrous PI	T		Pos	18	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	hall B501-B508(h	20	4"-8" felt w/ tar PI	T		Pos	42	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	hall B501-B508(h	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	hall B501-B508(h	43	spray-on fireproofing	S	ND		174	SF	F	N		9/8/94	DAH/TJS							
5	hall B501-B508(h	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	hall B501-B508(h	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	hall B501-B508(h	155	black tar on duct	M		Pos	203	SF	N	N	1	8/5/94	DAH/TJS		5%					
5	hall B501-B508(h	157	brown duct adhesive	M	ND		60	LF	N	N	0	8/5/94	DAH/TJS							
5	hall B501-B508(h	176	black tar sealant	M		Pos	12	LF	N	N	1	8/5/94	DAH/TJS		20%					
5	hall B501-B508(h	178	tar paper duct wrap	M	ND		30	SF	F	N	0	8/5/94	DAH/TJS							
5	hall B501-B508(h	1003	unable to fully view space																	

5	hall B510-B520	1	<4" white fibrous PI	T		Pos	33	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	hall B510-B520	2	<4" PFI on white fibrous	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	hall B510-B520	5	<4" felt with tar PI	T		Pos	252	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	hall B510-B520	6	<4" fibrous PFI on felt	T		Pos	20	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	hall B510-B520	20	4"-8" felt w/ tar PI	T		Pos	136	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	hall B510-B520	21	4"-8" PFI on felt	T		Pos	18	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	hall B510-B520	43	spray-on fireproofing	S	ND		12	SF	F	N	0	9/8/94	DAH/TJS						
5	hall B510-B520	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B510-B520	55	9"x9" grey w/ white smears FT	M		Pos	827	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	hall B510-B520	55.5	floor tile adhesive (sample 55)	M	ND		827	SF	N	N	0	7/15/94	DAH/TJS						
5	hall B510-B520	68	9"x9" olive w/white streaks FT	M		Pos	7	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	hall B510-B520	68.5	floor tile adhesive (sample 68)	M	ND		7	SF	N	N	0	9/8/94	DAH/TJS						
5	hall B510-B520	99	9"x9" grey w/ white & black streaks FT			Pos	5	SF	N	N	1	7/15/94	DAH/TJS		7%				
5	hall B510-B520	99.5	floor tile adhesive (sample 99)	M		Pos	5	SF	N	N	1	7/15/94	DAH/TJS		10%				
5	hall B510-B520	138	2'x2' pock-marked CT	M	ND		840	SF	F	N	0	9/8/94	DAH/TJS						
5	hall B510-B520	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	hall B510-B520	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	hall B510-B520	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B510-B520	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B510-B520	203	9"x9" charcoal w/ white & grey flecks	M	ND		0.5	SF	N	N	0	9/8/94	DAH/TJS						
5	hall B510-B520	203.5	floor tile adhesive (sample 203)	M	ND		0.5	SF	N	N	0	9/8/94	DAH/TJS						
5	hall B522-B527	1	<4" white fibrous PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	hall B522-B527	5	<4" felt with tar PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	hall B522-B527	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B522-B527	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B522-B527	55	9"x9" grey w/ white smears FT	M		Pos	360	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	hall B522-B527	55.5	floor tile adhesive (sample 55)	M	ND		360	SF	N	N	0	7/15/94	DAH/TJS						
5	hall B522-B527	138	2'x2' pock-marked CT	M	ND		192	SF	F	N	0	9/8/94	DAH/TJS						
5	hall B522-B527	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	hall B522-B527	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B522-B527	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	hall B522-B527	157	brown duct adhesive	M	ND		250	LF	N	N	0	8/5/94	DAH/TJS						
5	hall B522-B527	178	tar paper duct wrap	M	ND		175	SF	F	N	0	8/5/94	DAH/TJS						
5	hall B522-B527	221	12"x12" gray w/black & white specks	M		Pos	166	SF	N	N	1	8/5/94	DAH/TJS		3%				
5	hall B522-B527	221.5	floor tile adhesive (sample 221)	M		Pos	166	SF	N	N	1	8/5/94	DAH/TJS		3%				

5	hall B522-B527	1003	unable to fully view space																		
5	hall B522-B527		unable to view above plaster ceiling																		
5	hall B551 to B57	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040	
5	hall B551 to B57	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	47	9"x9" black w/cream FT	M		Pos	160	SF	N	N	1	4/27/95	Allen/Archer	15%							074-95-040
5	hall B551 to B57	47.5	floor tile adhesive (sample 47)	M	ND		160	SF	N	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	82	12"x12" accoustic CT (7/24/92)	M	ND		1656	SF	F	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	82.5	ceiling tile adhesive (sample 82)	M	ND		1656	SF	N	N	0	4/27/95	Allen/Archer								074-95-040
5	hall B551 to B57	88	2'x2' nailhole long fissure CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer								074-95-040
5	ramp	1	<4" white fibrous PI	T		Pos	1	LF	F	N	2	7/15/94	DAH/TJS	7%	5%						
5	ramp	2	<4" PFI on white fibrous	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS		35%						
5	ramp	20	4"-8" felt w/ tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	ramp	21	4"-8" PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	10%	15%						
5	ramp	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	ramp	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
5	ramp	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
5	ramp	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS								
5	ramp	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	ramp	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	ramp	222	12"x12" brown w/ brown & white spe	M		Pos	360	SF	N	N	1	9/8/94	DAH/TJS		20%						
5	ramp	222.5	floor tile adhesive (sample 222)	M		Pos	360	SF	N	N	1	8/5/94	DAH/TJS								
5	ramp	223	12"x12" dark & light brown mottled F	M		Pos	2	SF	N	N	1	8/5/94	DAH/TJS		7%						
5	ramp	223.5	floor tile adhesive (sample 223)	M		Pos	2	SF	N	N	1	8/5/94	DAH/TJS		2%						
5	room B501	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B501	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B501	55	9"x9" grey w/ white smears FT	M		Pos	14	SF	N	N	1	7/15/94	DAH/TJS		20%						
5	room B501	55.5	floor tile adhesive (sample 55)	M	ND		14	SF	N	N	0	7/15/94	DAH/TJS								
5	room B501	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
5	room B501(above	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B502	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								

5	room B502	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B502	1001	unable to view above ceiling																	
5	room B502-1	5	<4" felt with tar PI	T		Pos	5	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B502-1	6	<4" fibrous PFI on felt	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
5	room B502-1	13	<4" PFI on fiberglass	T	ND		8	EA	F	N	0	9/8/94	DAH/TJS							
5	room B502-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B502-1	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B502-2	1	<4" white fibrous PI	T		Pos	79	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B502-2	2	<4" PFI on white fibrous	T		Pos	21	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B502-2	5	<4" felt with tar PI	T		Pos	38	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B502-2	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
5	room B502-2	13	<4" PFI on fiberglass	T	ND		4	EA	F	N	0	9/8/94	DAH/TJS							
5	room B502-2	16	4"-8" white fibrous PI	T		Pos	17	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	room B502-2	17	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
5	room B502-2	20	4"-8" felt w/ tar PI	T		Pos	19	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B502-2	21	4"-8" PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	room B502-2	24	4"-8" cork w/ tar PI	T	ND		50	LF	N	N	0	7/15/94	DAH/TJS							
5	room B502-2	25	4"-8" PFI on cork	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	15%	35%					
5	room B502-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B502-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B502-2	157	brown duct adhesive	M	ND			LF	N	N	1	8/5/94	DAH/TJS							
5	room B504	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B504	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B504	147	cloth vibration joint	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS							
5	room B504(hatch	43	spray-on fireproofing	S	ND		64	SF	F	N	0	9/8/94	DAH/TJS							
5	room B504(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B504(hatch	155	black tar on duct	M		Pos	112	SF	N	N	1	8/5/94	DAH/TJS		5%					
5	room B504-1	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B504-1	16	4"-8" white fibrous PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	room B504-1	24	4"-8" cork w/ tar PI	T	ND		12	LF	N	N	0	7/15/94	DAH/TJS							
5	room B504-1	25	4"-8" PFI on cork	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	15%	35%					
5	room B504-1	47	fluffy spray-on fireproofing	S	ND		4	SF	F	N	0	7/15/94	DAH/TJS							

5	room B511	21	4"-8" PFI on felt	T		Pos	11	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B511	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B511	55	9"x9" grey w/ white smears FT	M		Pos	110	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B511	55.5	floor tile adhesive (sample 55)	M	ND		110	SF	N	N	0	7/15/94	DAH/TJS						
5	room B511	138	2'x2' pock-marked CT	M	ND		90	SF	F	N	0	9/8/94	DAH/TJS						
5	room B511	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B511	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B511	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B511	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B511	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512	5	<4" felt with tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B512	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B512	20	4"-8" felt w/ tar PI	T		Pos	22	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B512	21	4"-8" PFI on felt	T		Pos	12	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B512	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512	138	2'x2' pock-marked CT	M	ND		52	SF	F	N	0	9/8/94	DAH/TJS						
5	room B512	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B512	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B512	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512	220	12"x12" tan w/ brown & cream streak	M	ND		60	SF	N	N	0	8/5/94	DAH/TJS						
5	room B512	220.5	floor tile adhesive (sample 220)	M		Pos	60	SF	N	N	1	8/5/94	DAH/TJS		10%				
5	room B512-1	1	<4" white fibrous PI	T		Pos	32	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B512-1	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B512-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-1	55	9"x9" grey w/ white smears FT	M		Pos	100	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B512-1	55.5	floor tile adhesive (sample 55)	M	ND		100	SF	N	N	0	7/15/94	DAH/TJS						
5	room B512-1	138	2'x2' pock-marked CT	M	ND		70	SF	F	N	0	9/8/94	DAH/TJS						
5	room B512-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B512-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B512-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-1	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-2	16	4"-8" white fibrous PI	T		Pos	27	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
5	room B512-2	17	4"-8" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				

5	room B512-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-2	55	9"x9" grey w/ white smears FT	M		Pos	90	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B512-2	55.5	floor tile adhesive (sample 55)	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
5	room B512-2	138	2'x2' pock-marked CT	M	ND		58	SF	F	N	0	9/8/94	DAH/TJS						
5	room B512-2	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B512-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B512-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B512-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B513	5	<4" felt with tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B513	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B513	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B513	55	9"x9" grey w/ white smears FT	M		Pos	90	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B513	55.5	floor tile adhesive (sample 55)	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
5	room B513	109	2'x2' tiny pinhole w/ fissures CT	M	ND		32	SF	F	N	0	7/15/94	DAH/TJS						
5	room B513	138	2'x2' pock-marked CT	M	ND		52	SF	F	N	0	9/8/94	DAH/TJS						
5	room B513	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B513	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B513	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B515	5	<4" felt with tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B515	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B515	16	4"-8" white fibrous PI	T		Pos	40	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
5	room B515	17	4"-8" PFI on white fibrous	T		Pos	20	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
5	room B515	17	4"-8" PFI on white fibrous	T		Pos	1	EA	F	M	4	7/15/94	DAH/TJS	3%	7%				
5	room B515	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B515	109	2'x2' tiny pinhole w/ fissures CT	M	ND		16	SF	F	N	0	7/15/94	DAH/TJS						
5	room B515	138	2'x2' pock-marked CT	M	ND		160	SF	F	N	0	9/8/94	DAH/TJS						
5	room B515	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B515	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B515	220	12"x12" tan w/ brown & cream streak	M	ND		216	SF	N	N	0	8/5/94	DAH/TJS						
5	room B515	220.5	floor tile adhesive (sample 220)	M		Pos	216	SF	N	N	1	8/5/94	DAH/TJS		10%				
5	room B515-1	1	<4" white fibrous PI	T		Pos	22	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B515-1	1	<4" white fibrous PI	T		Pos	24	LF	F	N	2								
5	room B515-1	2	<4" PFI on white fibrous	T		Pos	5	EA	F	N	2								

5	room B515-3	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B517	1	<4" white fibrous PI	T		Pos	41	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B517	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B517	5	<4" felt with tar PI	T		Pos	26	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B517	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	L	3	7/15/94	DAH/TJS	12%	3%					
5	room B517	16	4"-8" white fibrous PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	room B517	17	4"-8" PFI on white fibrous	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
5	room B517	20	4"-8" felt w/ tar PI	T		Pos	15	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B517	21	4"-8" PFI on felt	T		Pos	12	EA	F	L	3	7/15/94	DAH/TJS	10%	15%					
5	room B517	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B517	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B517	55	9"x9" grey w/ white smears FT	M		Pos	220	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	room B517	55.5	floor tile adhesive (sample 55)	M	ND		220	SF	N	N	0	7/15/94	DAH/TJS							
5	room B517	109	2'x2' tiny pinhole w/ fissures CT	M	ND		10	SF	F	N	0	7/15/94	DAH/TJS							
5	room B517	123	2'x2' scraggly worm CT	M	ND		12	SF	F	N	0	9/8/94	DAH/TJS							
5	room B517	138	2'x2' pock-marked CT	M	ND		158	SF	F	N	0	9/8/94	DAH/TJS							
5	room B517	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B517	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B518	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B518	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B518	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
5	room B518	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B518	222	12"x12" brown w/ brown & white spe	M		Pos	86	SF	N	N	1	9/8/94	DAH/TJS		20%					
5	room B518	222.5	floor tile adhesive (sample 222)	M		Pos	86	SF	N	N	0	8/5/94	DAH/TJS		5%					
5	room B518	223	12"x12" dark & light brown mottled F	M		Pos	1	SF	N	N	1	8/5/94	DAH/TJS		7%					
5	room B518	223.5	floor tile adhesive (sample 223)	M		Pos	1	SF	N	N	1	8/5/94	DAH/TJS		2%					
5	room B518	1001	unable to view above ceiling																	
5	room B518-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B518-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B518-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
5	room B518-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B518-1	222	12"x12" brown w/ brown & white spe	M		Pos	65	SF	N	N	1	9/8/94	DAH/TJS		20%					
5	room B518-1	222.5	floor tile adhesive (sample 222)	M		Pos	65	SF	N	N	0	8/5/94	DAH/TJS		5%					
5	room B518-1	1001	unable to view above ceiling																	

5	room B518-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B518-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B518-2	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B518-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B518-2	222	12"x12" brown w/ brown & white spe	M		Pos	60	SF	N	N	1	9/8/94	DAH/TJS		20%				
5	room B518-2	222.5	floor tile adhesive (sample 222)	M		Pos	60	SF	N	N	0	8/5/94	DAH/TJS		5%				
5	room B518-2	1001	unable to view above ceiling																
5	room B519	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B519	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B519	162	red pipe sealent	M	ND		0.5	LF	N	N	0	8/5/94	DAH/TJS						
5	room B519	220	12"x12" tan w/ brown & cream streat	M	ND		8	SF	N	N	0	8/5/94	DAH/TJS						
5	room B519	220.5	floor tile adhesive (sample 220)	M		Pos	8	SF	N	N	1	8/5/94	DAH/TJS		10%				
5	room B520	5	<4" felt with tar PI	T		Pos	17	LF	F	N	2								
5	room B520	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2								
5	room B520	20	4"-8" felt w/ tar PI	T		Pos	5	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B520	21	4"-8" PFI on felt	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B520	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B520	108	2'x2' cratered CT	M	ND		46	SF	F	N	0	7/15/94	DAH/TJS						
5	room B520	138	2'x2' pock-marked CT	M	ND		22	SF	F	N	0	9/8/94	DAH/TJS						
5	room B520	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B520	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B520	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B520	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B520	220	12"x12" tan w/ brown & cream streat	M	ND		70	SF	N	N	0	8/5/94	DAH/TJS						
5	room B520	220.5	floor tile adhesive (sample 220)	M		Pos	70	SF	N	N	1	8/5/94	DAH/TJS		10%				
5	room B520-1	5	<4" felt with tar PI	T		Pos	25	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B520-1	6	<4" fibrous PFI on felt	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B520-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B520-1	55	9"x9" grey w/ white smears FT	M		Pos	90	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B520-1	55.5	floor tile adhesive (sample 55)	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						
5	room B520-1	138	2'x2' pock-marked CT	M	ND		70	SF	F	N	0	9/8/94	DAH/TJS						
5	room B520-1	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B520-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						

5	room B524	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B524	55	9"x9" grey w/ white smears FT	M		Pos	172	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B524	55.5	floor tile adhesive (sample 55)	M	ND		172	SF	N	N	0	7/15/94	DAH/TJS						
5	room B524	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B524(above)	1	<4" white fibrous PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B524(above)	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B524(above)	5	<4" felt with tar PI	T		Pos	49	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B524(above)	6	<4" fibrous PFI on felt	T		Pos	16	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B524(above)	20	4"-8" felt w/ tar PI	T		Pos	40	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B524(above)	21	4"-8" PFI on felt	T		Pos	17	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B524(above)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B524(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525	55	9"x9" grey w/ white smears FT	M		Pos	180	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B525	55.5	floor tile adhesive (sample 55)	M	ND		180	SF	N	N	0	7/15/94	DAH/TJS						
5	room B525	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B525(above)	5	<4" felt with tar PI	T		Pos	73	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B525(above)	6	<4" fibrous PFI on felt	T		Pos	23	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B525(above)	20	4"-8" felt w/ tar PI	T		Pos	128	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B525(above)	21	4"-8" PFI on felt	T		Pos	26	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B525(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525(above)	157	brown duct adhesive	M	ND		22	LF	N	N	0	8/5/94	DAH/TJS						
5	room B525-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B525-1	55	9"x9" grey w/ white smears FT	M		Pos	10	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B525-1	55.5	floor tile adhesive (sample 55)	M	ND		100	SF	N	N	0	7/15/94	DAH/TJS						
5	room B525-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B525-1(above)	1	<4" white fibrous PI	T		Pos	57	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B525-1(above)	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B525-1(above)	5	<4" felt with tar PI	T		Pos	31	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B525-1(above)	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				

5	room B525-1(abc	20	4"-8" felt w/ tar PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B525-1(abc	21	4"-8" PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	room B525-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B525-1(abc	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B525-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B525-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B525-2	55	9"x9" grey w/ white smears FT	M		Pos	100	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	room B525-2	55.5	floor tile adhesive (sample 55)	M	ND		100	SF	N	N	0	7/15/94	DAH/TJS							
5	room B525-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B525-2(abc	1	<4" white fibrous PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B525-2(abc	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B525-2(abc	5	<4" felt with tar PI	T		Pos	7	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B525-2(abc	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
5	room B525-2(abc	20	4"-8" felt w/ tar PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B525-2(abc	21	4"-8" PFI on felt	T		Pos	13	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	room B525-2(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B525-2(abc	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B527	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B527	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B527	55	9"x9" grey w/ white smears FT	M		Pos	144	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	room B527	55.5	floor tile adhesive (sample 55)	M	ND		144	SF	N	N	0	7/15/94	DAH/TJS							
5	room B527	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B527(hatch	1	<4" white fibrous PI	T		Pos	25	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B527(hatch	2	<4" PFI on white fibrous	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B527(hatch	5	<4" felt with tar PI	T		Pos	14	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B527(hatch	20	4"-8" felt w/ tar PI	T		Pos	14	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B527(hatch	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
5	room B527(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B527(hatch	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	Room B528	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
5	Room B528	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
5	Room B528	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer							074-95-040

5	Room B528	62	12"x12" cream w/tan FT	M	ND		210	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B528	62.5	floor tile adhesive (sample 62)	M		Pos	210	SF	N	N	1	4/27/95	Allen/Archer	20%					074-95-040
5	Room B528-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B528-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B528-1		inaccessible above ceiling																
5	Room B529	1	<4" white fibrous PI (7/24/92)	T		Pos	24	LF	F	N	2	4/27/95	Allen/Arche	15%					074-95-040
5	Room B529	2	<4" PFI on white fibrous (7/24/92)	T		Pos	6	EA	F	N	2	4/27/95	Allen/Arche	5%	5%				074-95-040
5	Room B529	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B529	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B529	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B529	68	12"x12" olive w/white & brown FT	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
5	Room B529	68.5	floor tile adhesive (sample 68)	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
5	Room B529-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B529-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B529-1		inaccessible above ceiling																
5	Room B530	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B530	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B530	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B530	68	12"x12" olive w/white & brown FT	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
5	Room B530	68.5	floor tile adhesive (sample 68)	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
5	Room B530-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B530-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B530-1		inaccessible above ceiling																
5	Room B531	1	<4" white fibrous PI (7/24/92)	T		Pos	24	LF	F	N	2	4/27/95	Allen/Arche	15%					074-95-040
5	Room B531	2	<4" PFI on white fibrous (7/24/92)	T		Pos	2	EA	F	N	2	4/27/95	Allen/Arche	5%	5%				074-95-040
5	Room B531	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B531	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B531	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B531	68	12"x12" olive w/white & brown FT	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
5	Room B531	68.5	floor tile adhesive (sample 68)	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040

5	Room B531-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B531-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B531-1		inaccessible above ceiling																
5	Room B532	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B532	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B532	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B532	68	12"x12" olive w/white & brown FT	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B532	68.5	floor tile adhesive (sample 68)	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B532-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B532-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B532-1		inaccessible above ceiling																
5	Room B534	1	<4" white fibrous PI (7/24/92)	T		Pos	24	LF	F	N	2	4/27/95	Allen/Arche		15%				074-95-040
5	Room B534	2	<4" PFI on white fibrous (7/24/92)	T		Pos	6	EA	F	N	2	4/27/95	Allen/Arche		5%	5%			074-95-040
5	Room B534	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B534	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B534	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B534	68	12"x12" olive w/white & brown FT	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B534	68.5	floor tile adhesive (sample 68)	M		Pos	128	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B534-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B534-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B534-1		inaccessible above ceiling																
5	Room B535	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B535	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B535	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B535	46	9"x9" off white w/charcoal FT	M		Pos	15	SF	N	N	1	4/27/95	Allen/Archer		5%				074-95-040
5	Room B535	46.5	floor tile adhesive (sample 46)	M		Pos	15	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B535	51	9"x9" light grey w/black & white FT	M		Pos	285	SF	N	N	1	4/27/95	Allen/Archer		15%				074-95-040
5	Room B535	51.5	floor tile adhesive (sample 51)	M		Pos	285	SF	N	N	1	4/27/95	Allen/Archer		10%				074-95-040
5	Room B535(hatc	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B536	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040

5	Room B536	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B536	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B536	46	9"x9" off white w/charcoal FT	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B536	46.5	floor tile adhesive (sample 46)	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
5	Room B536(hatch)		inaccessible															
5	Room B537	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	46	9"x9" off white w/charcoal FT	M		Pos	104	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B537	46.5	floor tile adhesive (sample 46)	M		Pos	104	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
5	Room B537	82	12"x12" accoustic CT (7/24/92)	M	ND		104	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	82.5	ceiling tile adhesive (sample 82)	M	ND		104	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537	88	2'x2' nailhole long fissure CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-1	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-1	48	9"x9" cream w/brown & beige CT	M		Pos	64	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B537-1	48.5	floor tile adhesive (sample 48)	M		Pos	64	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
5	Room B537-1	93	2'x2' pinhole mini-crater CT	M	ND		64	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-2	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-2	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-2(ha	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-2(ha	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-3	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-3	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-3	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B537-3	48	9"x9" cream w/brown & beige CT	M		Pos	60	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B537-3	48.5	floor tile adhesive (sample 48)	M		Pos	60	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
5	Rooms B538 thru B562 Please See Observations and Recommendations																	

5	Room B560-3	9	<4" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B560-3	10	<4" fibrous PFI on FG (7/24/92)	T		Pos	50	EA	F	N	2	4/27/95	Allen/Archer	5%					074-95-040
5	Room B560-3	36	red brick mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer	<1%					074-95-040
5	Room B560-3	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B560-3	98	black tar on duct (4/8/92)	M		Pos	50	SF	N	N	1	4/27/95	Allen/Archer	20%					074-95-040
5	Room B563	9	<4" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	82	12"x12" accoustic CT (7/24/92)	M	ND		225	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	82.5	ceiling tile adhesive (sample 82)	M	ND		225	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563	87	2'x2' nailhole fissure CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563(hatc	23	9"-14" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563(hatc	24	9"-14" fibrous PFI on FG	T	ND		4	EA	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563(hatc	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563(hatc	37	clay tile mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B563(hatc	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564	49	9"x9" cream w/beige FT	M		Pos	180	SF	N	N	1	4/27/95	Allen/Archer	15%					074-95-040
5	Room B564	49.5	floor tile adhesive (sample 49)	M		Pos	180	SF	N	N	1	4/27/95	Allen/Archer	15%					074-95-040
5	Room B564	79	12"x12" pinhole worm CT	M	ND		200	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564	79.5	ceiling tile adhesive (sample 79)	M	ND		200	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1	1	<4" white fibrous PI (7/24/92)	T		Pos	12	LF	F	N	2	4/27/95	Allen/Arche	15%					074-95-040
5	Room B564-1	2	<4" PFI on white fibrous (7/24/92)	T		Pos	2	EA	F	N	2	4/27/95	Allen/Arche	5%	5%				074-95-040
5	Room B564-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1	49	9"x9" cream w/beige FT	M		Pos	140	SF	N	N	1	4/27/95	Allen/Archer	15%					074-95-040
5	Room B564-1	49.5	floor tile adhesive (sample 49)	M		Pos	140	SF	N	N	1	4/27/95	Allen/Archer	15%					074-95-040

5	Room B564-1/B5	1	<4" white fibrous PI (7/24/92)	T		Pos	165	LF	F	N	2	4/27/95	Allen/Arche	15%					074-95-040
5	Room B564-1/B5	2	<4" PFI on white fibrous (7/24/92)	T		Pos	38	EA	F	L	3	4/27/95	Allen/Arche	5%	5%				074-95-040
5	Room B564-1/B5	9	<4" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1/B5	10	<4" fibrous PFI on FG (7/24/92)	T		Pos	10	EA	F	L	3	4/27/95	Allen/Archer		5%				074-95-040
5	Room B564-1/B5	31	fiberglass duct insulation (7/24/92)	T	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1/B5	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1/B5	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-1/B5	36	red brick mortar	M	ND			SF	F	N	0	4/27/95	Allen/Archer		<1%				074-95-040
5	Room B564-1/B5	105	suspect pipe wrap	T		Pos	6	LF	F	N	2	4/27/95	Allen/Archer		10%				074-95-040
5	Room B564-2	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-2	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-2	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-2	50	9"x9" beige w/brown & cream FT	M	ND		105	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-2	50.5	floor tile adhesive (sample 50)	M	ND		105	SF	N	N	0	4/27/95	Allen/Archer		<1%				074-95-040
5	Room B564-2	79	12"x12" pinhole worm CT	M	ND		105	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-2	79.5	ceiling tile adhesive (sample 79)	M	ND		105	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	50	9"x9" beige w/brown & cream FT	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	50.5	floor tile adhesive (sample 50)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer		<1%				074-95-040
5	Room B564-3	79	12"x12" pinhole worm CT	M	ND		100	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-3	79.5	ceiling tile adhesive (sample 79)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	1	<4" white fibrous PI (7/24/92)	T		Pos	18	LF	F	N	2	4/27/95	Allen/Arche	15%					074-95-040
5	Room B564-4	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	49	9"x9" cream w/beige FT	M		Pos	80	SF	N	N	1	4/27/95	Allen/Archer		15%				074-95-040
5	Room B564-4	49.5	floor tile adhesive (sample 49)	M		Pos	80	SF	N	N	1	4/27/95	Allen/Archer		15%				074-95-040
5	Room B564-4	79	12"x12" pinhole worm CT	M	ND		80	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	79.5	ceiling tile adhesive (sample 79)	M	ND		80	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
5	Room B564-4	96	black sink (7/24/92)	M		Pos	2	SF	N	N	1	4/27/95	Allen/Archer		30%				074-95-040

5	Room B564-5	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-5	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-5	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-5	49	9"x9" cream w/beige FT	M		Pos	15	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-5	49.5	floor tile adhesive (sample 49)	M		Pos	15	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-5	79	12"x12" pinhole worm CT	M	ND		75	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-5	79.5	ceiling tile adhesive (sample 79)	M	ND		75	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-6	1	<4" white fibrous PI (7/24/92)	T		Pos	8	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
5	Room B564-6	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-6	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-6	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-6	49	9"x9" cream w/beige FT	M		Pos	120	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-6	49.5	floor tile adhesive (sample 49)	M		Pos	120	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-6	79	12"x12" pinhole worm CT	M	ND		120	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-6	79.5	ceiling tile adhesive (sample 79)	M	ND		120	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-7	1	<4" white fibrous PI (7/24/92)	T		Pos	6	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
5	Room B564-7	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-7	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-7	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-7	49	9"x9" cream w/beige FT	M		Pos	140	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-7	49.5	floor tile adhesive (sample 49)	M		Pos	140	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B564-7	79	12"x12" pinhole worm CT	M	ND		140	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-7	79.5	ceiling tile adhesive (sample 79)	M	ND		140	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	50	9"x9" beige w/brown & cream FT	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	50.5	floor tile adhesive (sample 50)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer	<1%				074-95-040
5	Room B564-8	79	12"x12" pinhole worm CT	M	ND		100	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-8	79.5	ceiling tile adhesive (sample 79)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-9	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-9	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-9	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040

5	Room B564-9	50	9"x9" beige w/brown & cream FT	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-9	50.5	floor tile adhesive (sample 50)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer	<1%				074-95-040
5	Room B564-9	79	12"x12" pinhole worm CT	M	ND		100	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B564-9	79.5	ceiling tile adhesive (sample 79)	M	ND		100	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B565	1	<4" white fibrous PI (7/24/92)	T		Pos	10	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
5	Room B565	31	fiberglass duct insulation (7/24/92)	T	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B565	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B565	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B565	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B565	49	9"x9" cream w/beige FT	M		Pos	195	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B565	49.5	floor tile adhesive (sample 49)	M		Pos	195	SF	N	N	1	4/27/95	Allen/Archer	15%				074-95-040
5	Room B565	95	canvass vibration joint	M		Pos	2	EA	N	N	1	4/27/95	Allen/Archer	55%				074-95-040
5	Room B565		inaccessible above ceiling															
5	Room B566	7	<4" fiberglass w/tar PI (7/24/92)	T	ND			LF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B566	8	<4" fibrous PFI on FG w/tar (7/24/92)	T		Pos	4	EA	F	N	2	4/27/95	Allen/Archer	50%				074-95-040
5	Room B566	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B566	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B566	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B566	48	9"x9" cream w/brown & beige CT	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B566	48.5	floor tile adhesive (sample 48)	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
5	Room B567	9	<4" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567	10	<4" fibrous PFI on FG (7/24/92)	T		Pos	2	EA	F	L	3	4/27/95	Allen/Archer	5%				074-95-040
5	Room B567	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-2	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-2	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-2	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B567-2	46	9"x9" off white w/charcoal FT	M		Pos	6	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B567-2	46.5	floor tile adhesive (sample 46)	M		Pos	6	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040

5	Room B568	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B568	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B568	54	9"x9" olive w/white FT	M		Pos	90	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
5	Room B568	54.5	floor tile adhesive (sample 54)	M		Pos	90	SF	N	N	1	4/27/95	Allen/Archer	20%				074-95-040
5	Room B570	1	<4" white fibrous PI (7/24/92)	T		Pos	45	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
5	Room B570	2	<4" PFI on white fibrous (7/24/92)	T		Pos	10	EA	F	N	2	4/27/95	Allen/Arche	5%	5%			074-95-040
5	Room B570	7	<4" fiberglass w/tar PI (7/24/92)	T	ND		2	LF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B570	8	<4" fibrous PFI on FG w/tar (7/24/92)	T		Pos	6	EA	F	N	2	4/27/95	Allen/Archer	50%				074-95-040
5	Room B570	11	4"-8" white fibrous PI (7/24/92)	T		Pos	64	LF	F	N	2	4/27/95	Allen/Arche	10%	5%			074-95-040
5	Room B570	12	4"-8" PFI on white fibrous (7/24/92)	T		Pos	28	EA	F	N	2	4/27/95	Allen/Arche	10%	10%			074-95-040
5	Room B570	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B570	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B571	1	<4" white fibrous PI (7/24/92)	T		Pos	20	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
5	Room B571	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B571	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B571	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B571	62	12"x12" cream w/tan FT	M	ND		320	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
5	Room B571	62.5	floor tile adhesive (sample 62)	M		Pos	320	SF	N	N	1	4/27/95	Allen/Archer	20%				074-95-040
5	Room B571	85	2'x2' pinhole fissure CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
5	room B573	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS					
5	room B573	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS					
5	room B573	55	9"x9" grey w/ white smears FT	M		Pos	165	SF	N	N	1	7/15/94	DAH/TJS	20%				
5	room B573	55.5	floor tile adhesive (sample 55)	M	ND		165	SF	N	N	0	7/15/94	DAH/TJS					
5	room B573	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS					
5	room B573	1001	unable to view above ceiling															
5	room B574	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS					
5	room B574	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS					
5	room B574	55	9"x9" grey w/ white smears FT	M		Pos	132	SF	N	N	1	7/15/94	DAH/TJS	20%				
5	room B574	55.5	floor tile adhesive (sample 55)	M	ND		132	SF	N	N	0	7/15/94	DAH/TJS					
5	room B574	99	9"x9" grey w/ white & black streaks FT			Pos	3	SF	N	N	1							
5	room B574	99.5	floor tile adhesive (sample 99)	M		Pos	3	SF	N	N	1	7/15/94	DAH/TJS	10%				
5	room B574	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS					
5	room B574	1001	unable to view above ceiling															

5	room B574-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B574-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B574-1	55	9"x9" grey w/ white smears FT	M		Pos	48	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B574-1	55.5	floor tile adhesive (sample 55)	M	ND		48	SF	N	N	0	7/15/94	DAH/TJS						
5	room B574-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B574-1	1001	unable to view above ceiling																
5	room B575	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B575	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B575	55	9"x9" grey w/ white smears FT	M		Pos	6	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B575	55.5	floor tile adhesive (sample 55)	M	ND		6	SF	N	N	0	7/15/94	DAH/TJS						
5	room B575	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B575	224	12"x12" grey mottled FT	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		20%				
5	room B575	224.5	floor tile adhesive (sample 224)	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		15%				
5	room B575	1001	unable to view above ceiling																
5	room B578	1	<4" white fibrous PI	T		Pos	31	LF	F	L	3	7/15/94	DAH/TJS	7%	5%				
5	room B578	2	<4" PFI on white fibrous	T		Pos	11	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B578	5	<4" felt with tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B578	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B578	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B578	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B578	55	9"x9" grey w/ white smears FT	M		Pos	20	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B578	55.5	floor tile adhesive (sample 55)	M	ND		20	SF	N	N	0	7/15/94	DAH/TJS						
5	room B578	68	9"x9" olive w/white streaks FT	M		Pos	1	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B578	68.5	floor tile adhesive (sample 68)	M	ND		1	SF	N	N	0	9/8/94	DAH/TJS						
5	room B578	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B578	1001	unable to view above ceiling																
5	room B578(above	5	<4" felt with tar PI	T		Pos	65	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B578(above	6	<4" fibrous PFI on felt	T		Pos	14	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B578(above	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	1	<4" white fibrous PI	T		Pos	34	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B580	2	<4" PFI on white fibrous	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B580	5	<4" felt with tar PI	T		Pos	61	LF	F	N	2	7/15/94	DAH/TJS		60%				

5	room B580	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B580	16	4"-8" white fibrous PI	T		Pos	25	LF	F	N	2	7/15/94	DAH/TJS	7%	7%				
5	room B580	17	4"-8" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	3%	7%				
5	room B580	20	4"-8" felt w/ tar PI	T		Pos	25	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B580	21	4"-8" PFI on felt	T		Pos	15	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B580	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	109	2'x2' tiny pinhole w/ fissures CT	M	ND		20	SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	138	2'x2' pock-marked CT	M	ND		390	SF	F	N	0	9/8/94	DAH/TJS						
5	room B580	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B580	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580	155	black tar on duct	M		Pos	75	SF	N	N	1	8/5/94	DAH/TJS		5%				
5	room B580	219	12"x12" beige, tan & cream mottled I	M		Pos	470	SF	N	N	1	8/5/94	DAH/TJS		5%				
5	room B580	219.5	floor tile adhesive (sample 219)	M		Pos	470	SF	N	N	1	8/5/94	DAH/TJS		5%				
5	room B580-1	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B580-1	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B580-1	20	4"-8" felt w/ tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B580-1	21	4"-8" PFI on felt	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B580-1	24	4"-8" cork w/ tar PI	T	ND		20	LF	N	N	0	7/15/94	DAH/TJS						
5	room B580-1	25	4"-8" PFI on cork	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	15%	35%				
5	room B580-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-1	109	2'x2' tiny pinhole w/ fissures CT	M	ND		8	SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-1	138	2'x2' pock-marked CT	M	ND		44	SF	F	N	0	9/8/94	DAH/TJS						
5	room B580-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B580-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-1	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-1	155	black tar on duct	M		Pos	45	SF	N	N	1	8/5/94	DAH/TJS		5%				
5	room B580-1	164	white sink coating	M		Pos	1	EA	N	N	1	9/8/94	DAH/TJS		15%				
5	room B580-2	20	4"-8" felt w/ tar PI	T		Pos	3	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B580-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-2	126	2'x4' pinhole fissured CT	M	ND		18	SF	F	N	0	9/8/94	DAH/TJS						
5	room B580-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B580-2	219	12"x12" beige, tan & cream mottled I	M		Pos	18	SF	N	N	1	8/5/94	DAH/TJS		5%				
5	room B580-2	219.5	floor tile adhesive (sample 219)	M		Pos	18	SF	N	N	1	8/5/94	DAH/TJS		5%				

5	room B582	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B582	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B582	55	9"x9" grey w/ white smears FT	M		Pos	136	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B582	55.5	floor tile adhesive (sample 55)	M	ND		186	SF	N	N	0	7/15/94	DAH/TJS						
5	room B582	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B582	1001	unable to view above ceiling																
5	room B584	9	<4" cork w/ tar PI	T	ND		36	LF	N	N	0	7/15/94	DAH/TJS						
5	room B584	10	<4" PFI on cork	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	15%	15%				
5	room B584	20	4"-8" felt w/ tar PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B584	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B584	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584	50	9"x9" white w/ black smears FT	M		Pos	64	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B584	50.5	floor tile adhesive (sample 50)	M		Pos	64	SF	N	N	1	7/15/94	DAH/TJS		2%				
5	room B584	138	2'x2' pock-marked CT	M	ND		58	SF	F	N	0	9/8/94	DAH/TJS						
5	room B584	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B584	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-1	50	9"x9" white w/ black smears FT	M		Pos	84	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B584-1	50.5	floor tile adhesive (sample 50)	M		Pos	84	SF	N	N	1	7/15/94	DAH/TJS		2%				
5	room B584-1	102	1'x1' small pegboard CT	M		Pos	82	SF	F	N	2	8/5/94	DAH/TJS		3%				
5	room B584-1	102.5	ceiling tile adhesive (sample 102)	M	ND		84	SF	N	N	0	8/5/94	DAH/TJS						
5	room B584-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B584-1(abc	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B584-1(abc	6	<4" fibrous PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B584-1(abc	20	4"-8" felt w/ tar PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B584-1(abc	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B584-1(abc	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-2	1	<4" white fibrous PI	T		Pos	20	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B584-2	2	<4" PFI on white fibrous	T		Pos	6	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B584-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						

5	room B584-2	50	9"x9" white w/ black smears FT	M		Pos	86	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B584-2	50.5	floor tile adhesive (sample 50)	M		Pos	86	SF	N	N	1	7/15/94	DAH/TJS		2%				
5	room B584-2	138	2'x2' pock-marked CT	M	ND		58	SF	F	N	0	9/8/94	DAH/TJS						
5	room B584-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B584-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B584-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B586	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B586	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B586	55	9"x9" grey w/ white smears FT	M		Pos	202	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B586	55.5	floor tile adhesive (sample 55)	M	ND		202	SF	N	N	0	7/15/94	DAH/TJS						
5	room B586	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B586	153	12"x12" cork panel adhesive	M	ND		4	SF	N	N	0	9/8/94	DAH/TJS						
5	room B586	218	12"x12" olive w/ white smears FT	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		12%				
5	room B586	218.5	floor tile adhesive (sample 218)	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		15%				
5	room B586(hatch	1	<4" white fibrous PI	T		Pos	37	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B586(hatch	2	<4" PFI on white fibrous	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B586(hatch	5	<4" felt with tar PI	T		Pos	9	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B586(hatch	6	<4" fibrous PFI on felt	T		Pos	4	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B586(hatch	20	4"-8" felt w/ tar PI	T		Pos	25	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B586(hatch	21	4"-8" PFI on felt	T		Pos	24	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B586(hatch	43	spray-on fireproofing	S	ND		126	SF	F	N	0	9/8/94	DAH/TJS						
5	room B586(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B586(hatch	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590	55	9"x9" grey w/ white smears FT	M		Pos	212	SF	N	L	3	7/15/94	DAH/TJS		20%				
5	room B590	55.5	floor tile adhesive (sample 55)	M	ND		212	SF	N	N	0	7/15/94	DAH/TJS						
5	room B590	68	9"x9" olive w/white streaks FT	M		Pos	20	SF	N	L	1	7/15/94	DAH/TJS		20%				
5	room B590	68.5	floor tile adhesive (sample 68)	M	ND		20	SF	N	N	0	9/8/94	DAH/TJS						
5	room B590	101	1'X1' fissured CT	M	ND		72	SF	F	N	0	7/15/94	DAH/TJS						
5	room B590	101.5	ceiling tile adhesive (sample 101)	M	ND		72	SF	N	N	0	7/15/94	DAH/TJS						
5	room B590	103	1'x1' large fissure CT	M	ND		168	SF	F	N	0	9/8/94	DAH/TJS						
5	room B590	103.5	ceiling tile adhesive (sample 103)	M	ND		168	SF	N	N	0	9/8/94	DAH/TJS						
5	room B590	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						

5	room B590	206	9"x9" olive w/ green & white streaks	M		Pos	8	SF	N	N	1	9/8/94	DAH/TJS		5%				
5	room B590	206.5	floor tile adhesive(sample 206)	M	ND		8	SF	N	N	0	9/8/94	DAH/TJS						
5	room B590	218	12"x12" olive w/ white smears FT	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		12%				
5	room B590	218.5	floor tile adhesive (sample 218)	M		Pos	4	SF	N	N	1	9/8/94	DAH/TJS		15%				
5	room B590(hatch	5	<4" felt with tar PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B590(hatch	6	<4" fibrous PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
5	room B590(hatch	20	4"-8" felt w/ tar PI	T		Pos	19	LF	F	N	2	7/15/94	DAH/TJS		60%				
5	room B590(hatch	21	4"-8" PFI on felt	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
5	room B590(hatch	43	spray-on fireproofing	S	ND		40	SF	F	N	0	9/8/94	DAH/TJS						
5	room B590(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590(hatch	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590(hatch	157	brown duct adhesive	M	ND			LF	N	N	0	8/5/94	DAH/TJS						
5	room B590-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590-1	55	9"x9" grey w/ white smears FT	M		Pos	126	SF	N	N	1	7/15/94	DAH/TJS		20%				
5	room B590-1	55.5	floor tile adhesive (sample 55)	M	ND		126	SF	N	N	0	7/15/94	DAH/TJS						
5	room B590-1	135	2'x2' batwing CT	M	ND		110	SF	F	N	0	9/8/94	DAH/TJS						
5	room B590-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B590-1	153	12"x12" cork panel adhesive	M	ND		6	SF	N	N	0	9/8/94	DAH/TJS						
5	room B590-1(abc	1	<4" white fibrous PI	T		Pos	24	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B590-1(abc	2	<4" PFI on white fibrous	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B590-1(abc	43	spray-on fireproofing	S	ND		40	SF	F	N	0	9/8/94	DAH/TJS						
5	room B590-1(abc	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						
5	room B590-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
5	room B590-2	55	9"x9" grey w/ white smears FT	M		Pos	100	SF	N	L	1	7/15/94	DAH/TJS		20%				
5	room B590-2	55.5	floor tile adhesive (sample 55)	M	ND		100	SF	N	N	0	7/15/94	DAH/TJS						
5	room B590-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
5	room B590-2(abc	1	<4" white fibrous PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS	7%	5%				
5	room B590-2(abc	2	<4" PFI on white fibrous	T		Pos	16	EA	F	N	2	7/15/94	DAH/TJS		35%				
5	room B590-2(abc	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS						

5	room B590-2(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-3	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-3	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-3	55	9"x9" grey w/ white smears FT	M		Pos	100	SF	N	L	1	7/15/94	DAH/TJS		20%					
5	room B590-3	55.5	floor tile adhesive (sample 55)	M	ND		100	SF	N	N	0	7/15/94	DAH/TJS							
5	room B590-3	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B590-3(abc	1	<4" white fibrous PI	T		Pos	27	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B590-3(abc	2	<4" PFI on white fibrous	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B590-3(abc	16	4"-8" white fibrous PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	room B590-3(abc	17	4"-8" PFI on white fibrous	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
5	room B590-3(abc	20	4"-8" felt w/ tar PI	T		Pos	5	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B590-3(abc	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	room B590-3(abc	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
5	room B590-3(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-4	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-4	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B590-4	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B590-4	218	12"x12" olive w/ white smears FT	M		Pos	6	SF	N	N	1	9/8/94	DAH/TJS		12%					
5	room B590-4	218.5	floor tile adhesive (sample 218)	M		Pos	6	SF	N	N	1	9/8/94	DAH/TJS		15%					
5	room B592	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B592	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B592	55	9"x9" grey w/ white smears FT	M		Pos	232	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	room B592	55.5	floor tile adhesive (sample 55)	M	ND		2332	SF	N	N	0	7/15/94	DAH/TJS							
5	room B592	100	1'x1' pegboard CT	M	ND		232	SF	F	N	0	7/15/94	DAH/TJS							
5	room B592	100.5	ceiling tile adhesive (sample 100)	M		Pos	232	SF	N	N	1	9/8/94	DAH/TJS		10%					
5	room B592	135	2'x2' batwing CT	M	ND		200	SF	F	N	0	9/8/94	DAH/TJS							
5	room B592	150	chalkboard	M	ND		1	EA	N	N	0	9/8/94	DAH/TJS							
5	room B592(above	1	<4" white fibrous PI	T		Pos	28	LF	F	N	2	7/15/94	DAH/TJS	7%	5%					
5	room B592(above	2	<4" PFI on white fibrous	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS		35%					
5	room B592(above	16	4"-8" white fibrous PI	T		Pos	36	LF	F	N	2	7/15/94	DAH/TJS	7%	7%					
5	room B592(above	17	4"-8" PFI on white fibrous	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	3%	7%					
5	room B592(above	20	4"-8" felt w/ tar PI	T		Pos	15	LF	F	N	2	7/15/94	DAH/TJS		60%					

5	room B592(above)	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%						
5	room B592(above)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B592(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B592(above)	157	brown duct adhesive	M	ND			LF	N	N	0	8/5/94	DAH/TJS								
5	room B592(above)	184	black duct adhesive	M		Pos	30	LF	N	N	1	8/5/94	DAH/TJS		5%						
5	room B594	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B594	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B594	147	cloth vibration joint	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS								
5	room B594(hatch)	20	4"-8" felt w/ tar PI	T		Pos	8	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	room B594(hatch)	21	4"-8" PFI on felt	T		Pos	1	EA	F	N	2	7/15/94	DAH/TJS	10%	15%						
5	room B594(hatch)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B594(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B594(hatch)	184	black duct adhesive	M		Pos		LF	N	N	1	8/5/94	DAH/TJS		5%						
5	room B594(hatch)	1003	unable to fully view space																		
5	room B594-1	1	<4" white fibrous PI	T		Pos	3	LF	F	L	3	7/15/94	DAH/TJS	7%	5%						
5	room B594-1	5	<4" felt with tar PI	T		Pos	30	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	room B594-1	20	4"-8" felt w/ tar PI	T		Pos	15	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	room B594-1	25	4"-8" PFI on cork	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	15%	35%						
5	room B594-1	43	spray-on fireproofing	S	ND		1	SF	F	N	0	9/8/94	DAH/TJS								
5	room B594-1	116	2'x2' single-sized pinhole CT	M	ND		1	SF	F	N	0	7/15/94	DAH/TJS								
5	room B594-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596(above)	20	4"-8" felt w/ tar PI	T		Pos	19	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	room B596(above)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596-1	5	<4" felt with tar PI	T		Pos	12	LF	F	N	2	7/15/94	DAH/TJS		60%						
5	room B596-1	6	<4" fibrous PFI on felt	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
5	room B596-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
5	room B596-1	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								

5	room B596-2	5	<4" felt with tar PI	T		Pos	48	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B596-2	6	<4" fibrous PFI on felt	T		Pos	7	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
5	room B596-2	20	4"-8" felt w/ tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%					
5	room B596-2	21	4"-8" PFI on felt	T		Pos	5	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
5	room B596-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B596-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B596-2	184	black duct adhesive	M		Pos	10	LF	N	N	1	8/5/94	DAH/TJS		5%					
5	room B598	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B598	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	room B598	55	9"x9" grey w/ white smears FT	M		Pos	14	SF	N	N	1	7/15/94	DAH/TJS		20%					
5	room B598	55.5	floor tile adhesive (sample 55)	M	ND		14	SF	N	N	0	7/15/94	DAH/TJS							
5	room B598	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
5	room B598(above	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
5	See Observations & Recommendations																			