

Flr	Location	Samp#	Description	Code	N.D.	Pos	Quan	Unit	Fri	Cond	Rate	Samp Date	Survey	Amos	Chrys	Croc	Trem	Actin	Anth	Project #
6	hall B602-B605	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B602-B605	55	9"x9" grey w/ white smears FT	M		Pos	469	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	hall B602-B605	55.5	floor tile adhesive (sample 55)	M	ND		469	SF	N	N	0	7/15/94	DAH/TJS							
6	hall B602-B605	68	9"x9" olive w/white streaks FT	M		Pos	18	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	hall B602-B605	68.5	floor tile adhesive (sample 68)	M	ND		18	SF	N	N	0	9/8/94	DAH/TJS							
6	hall B602-B605	99	9"x9" grey w/ white & black streaks FT			Pos	6	SF	N	N	1	7/15/94	DAH/TJS		7%					
6	hall B602-B605	99.5	floor tile adhesive (sample 99)	M		Pos	6	SF	N	N	1	7/15/94	DAH/TJS		10%					
6	hall B602-B605	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
6	hall B602-B605	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	hall B602-B605	221	12"x12" gray w/black & white specks	M		Pos	26	SF	N	N	1	8/5/94	DAH/TJS		3%					
6	hall B602-B605	221.5	floor tile adhesive (sample 221)	M		Pos	26	SF	N	N	1	8/5/94	DAH/TJS		3%					
6	hall B602-B605	242	9"x9" tan w/ brown & cream streaks	M		Pos	3	SF	N	N	1	33089	DAH/TJS		10%					
6	hall B602-B605	242.5	floor tile adhesive (sample 242)	M		Pos	3	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	hall B602-B605	243	9"x9" greenish and white FT	M		Pos	6	SF	N	N	1	8/5/94	DAH/TJS		3%					
6	hall B602-B605	243.5	floor tile adhesive (sample 243)	M	ND		6	SF	N	N	0	33089	DAH/TJS							
6	hall B602-B605(h	13	<4" PFI on fiberglass	T	ND		2	EA	F	N	0	9/8/94	DAH/TJS							
6	hall B602-B605(h	28	4"-8" PFI on fiberglass	T		Pos	6	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
6	hall B602-B605(h	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B602-B605(h	100.5	ceiling tile adhesive (sample 100)	M		Pos	560	SF	N	N	1	9/8/94	DAH/TJS		10%					
6	hall B602-B605(h	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B602-B605(h	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B602-B605(h	157	brown duct adhesive	M	ND		96	LF	N	N	0	8/5/94	DAH/TJS							
6	hall B602-B605(h	178	tar paper duct wrap	M	ND		24	SF	F	N	0	8/5/94	DAH/TJS							
6	hall B602-B605(h	1003	unable to fully view space																	
6	hall B606-B620	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	71	12"x12" beige w/ brown & white sme	M	ND		512	SF	N	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	71.5	floor tile adhesive (sample 71)	M		Pos	512	SF	N	N	1	8/5/94	DAH/TJS		2%					
6	hall B606-B620	73	12"x12" cream w/ tan, green & grey l	M	ND		416	SF	N	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	73.5	floor tile adhesive (sample 73)	M	ND		416	SF	N	N	0	7/15/94	DAH/TJS		<1%					
6	hall B606-B620	101	1'X1' fissured CT	M	ND		16	SF	F	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	101.5	ceiling tile adhesive (sample 101)	M	ND		16	SF	N	N	0	7/15/94	DAH/TJS							
6	hall B606-B620	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
6	hall B606-B620	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							

6	hall B606-B620	251	1'x1' rough CT	M	ND		912	SF	F	N	0	9/8/94	DAH/TJS							
6	hall B606-B620	251.5	ceiling tile adhesive (sample 251)	M	ND		912	SF	N	N	0	9/8/94	DAH/TJS							
6	hall B606-B620(h	28	4"-8" PFI on fiberglass	T		Pos	5	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
6	hall B606-B620(h	43	spray-on fireproofing	S	ND		20	SF	F	N	0	9/8/94	DAH/TJS							
6	hall B606-B620(h	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B606-B620(h	157	brown duct adhesive	M	ND		12	LF	N	N	0	8/5/94	DAH/TJS							
6	hall B606-B620(h	178	tar paper duct wrap	M	ND		3	SF	F	N	0	8/5/94	DAH/TJS							
6	hall B621-B628	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B621-B628	73	12"x12" cream w/ tan, green & grey	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS							
6	hall B621-B628	73.5	floor tile adhesive (sample 73)	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS		<1%					
6	hall B621-B628	140	sheetrock & mud	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
6	hall B621-B628	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	hall B621-B628	251	1'x1' rough CT	M	ND		410	SF	F	N	0	9/8/94	DAH/TJS							
6	hall B621-B628	251.5	ceiling tile adhesive (sample 251)	M	ND		410	SF	N	N	0	9/8/94	DAH/TJS							
6	hall B621-B628	1002	floor tile under carpet				380													
6	hall B621-B628(h	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B621-B628(h	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	hall B630 to B633	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B630 to B633	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B630 to B633	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B630 to B633	52	9"x9" scarlet & grey FT	M		Pos	180	SF	N	N	1	4/27/95	Allen/Archer		10%					074-95-040
6	hall B630 to B633	52.5	floor tile adhesive (sample 52)	M		Pos	180	SF	N	N	1	4/27/95	Allen/Archer		10%					074-95-040
6	hall B630 to B633	80	12"x12" fissured splined CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B639 to B644	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B639 to B644	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B639 to B644	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B639 to B644	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B639 to B644	52	9"x9" scarlet & grey FT	M		Pos	504	SF	N	N	1	4/27/95	Allen/Archer		10%					074-95-040
6	hall B639 to B644	52.5	floor tile adhesive (sample 52)	M		Pos	504	SF	N	N	1	4/27/95	Allen/Archer		10%					074-95-040
6	hall B639 to B644	80	12"x12" fissured splined CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	hall B660 to B671	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040

6	hall B660 to B671	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	hall B660 to B671	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	hall B660 to B671	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	hall B660 to B671	52	9"x9" scarlet & grey FT	M		Pos	632	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	hall B660 to B671	52.5	floor tile adhesive (sample 52)	M		Pos	632	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	hall B660 to B671	80	12"x12" fissured splined CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	room B602	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602(above)	20	4"-8" felt w/ tar PI	T		Pos	37	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B602(above)	21	4"-8" PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
6	room B602(above)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602-1	5	<4" felt with tar PI	T		Pos	116	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B602-1	6	<4" fibrous PFI on felt	T		Pos	39	EA	F	L	3	7/15/94	DAH/TJS	12%	3%				
6	room B602-1	20	4"-8" felt w/ tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B602-1	21	4"-8" PFI on felt	T		Pos	1	EA	F	M	4	7/15/94	DAH/TJS	10%	15%				
6	room B602-1	43	spray-on fireproofing	S	ND		60	SF	F	N	0	9/8/94	DAH/TJS						
6	room B602-1	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602-1	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B602-1		felt PI & PFI debris	M		Pos	2	SF	F	H	4								
6	room B603	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B603	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B603	55	9"x9" grey w/ white smears FT	M		Pos	72	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B603	55.5	floor tile adhesive (sample 55)	M	ND		72	SF	N	N	0	7/15/94	DAH/TJS						
6	room B603	102	1'x1' small pegboard CT	M		Pos	184	SF	F	N	2	8/5/94	DAH/TJS		3%				
6	room B603	102.5	ceiling tile adhesive (sample 102)	M	ND		184	SF	F	N	0	8/5/94	DAH/TJS						
6	room B603	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B603	1001	unable to view above ceiling																
6	room B604	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B604	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B604	55	9"x9" grey w/ white smears FT	M		Pos	96	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B604	55.5	floor tile adhesive (sample 55)	M	ND		96	SF	N	N	0	7/15/94	DAH/TJS						

6	room B604	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B604	1001	unable to view above ceiling																	
6	room B604-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-1	55	9"x9" grey w/ white smears FT	M		Pos	156	SF	N	N	1	7/15/94	DAH/TJS	20%						
6	room B604-1	55.5	floor tile adhesive (sample 55)	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS							
6	room B604-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B604-1	250	1'x1' polka dot CT	M	ND		156	SF	F	N	0	8/5/94	DAH/TJS							
6	room B604-1	250.5	ceiling tile adhesive (sample 250)	M	ND		156	SF	N	N	0	8/5/94	DAH/TJS	<1%						
6	room B604-1	1001	unable to view above ceiling																	
6	room B604-1a	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-1a	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-1a	1001	unable to view above ceiling																	
6	room B604-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B604-2	55	9"x9" grey w/ white smears FT	M		Pos	50	SF	N	N	1	7/15/94	DAH/TJS	20%						
6	room B604-2	55.5	floor tile adhesive (sample 55)	M	ND		50	SF	N	N	0	7/15/94	DAH/TJS							
6	room B604-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B604-2	1001	unable to view above ceiling																	
6	room B605	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B605	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B605	55	9"x9" grey w/ white smears FT	M		Pos	170	SF	N	N	1	7/15/94	DAH/TJS	20%						
6	room B605	55.5	floor tile adhesive (sample 55)	M	ND		170	SF	N	N	0	7/15/94	DAH/TJS							
6	room B605	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B605	1001	unable to view above ceiling																	
6	room B605-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B605-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B605-1	55	9"x9" grey w/ white smears FT	M		Pos	62	SF	N	N	1	7/15/94	DAH/TJS	20%						
6	room B605-1	55.5	floor tile adhesive (sample 55)	M	ND		62	SF	N	N	0	7/15/94	DAH/TJS							
6	room B605-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B605-1	1001	unable to view above ceiling																	

6	room B605-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-2	55	9"x9" grey w/ white smears FT	M		Pos	122	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B605-2	55.5	floor tile adhesive (sample 55)	M	ND		122	SF	N	N	0	7/15/94	DAH/TJS						
6	room B605-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B605-2	153	12"x12" cork panel adhesive	M	ND		21	SF	N	N	0	9/8/94	DAH/TJS						
6	room B605-2	250	1'x1' polka dot CT	M	ND		122	SF	F	N	0	8/5/94	DAH/TJS						
6	room B605-2	250.5	ceiling tile adhesive (sample 250)	M	ND		122	SF	N	N	0	8/5/94	DAH/TJS		<1%				
6	room B605-2	1001	unable to view above ceiling																
6	room B605-3	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-3	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-3	55	9"x9" grey w/ white smears FT	M		Pos	54	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B605-3	55.5	floor tile adhesive (sample 55)	M	ND		54	SF	N	N	0	7/15/94	DAH/TJS						
6	room B605-3	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B605-3	1001	unable to view above ceiling																
6	room B605-4	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-4	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-4	55	9"x9" grey w/ white smears FT	M		Pos	54	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B605-4	55.5	floor tile adhesive (sample 55)	M	ND		54	SF	N	N	0	7/15/94	DAH/TJS						
6	room B605-4	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B605-4	1001	unable to view above ceiling																
6	room B605-5	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-5	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B605-5	55	9"x9" grey w/ white smears FT	M		Pos	130	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B605-5	55.5	floor tile adhesive (sample 55)	M	ND		130	SF	N	N	0	7/15/94	DAH/TJS						
6	room B605-5	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B605-5	250	1'x1' polka dot CT	M	ND		130	SF	F	N	0	8/5/94	DAH/TJS						
6	room B605-5	250.5	ceiling tile adhesive (sample 250)	M	ND		130	SF	N	N	0	8/5/94	DAH/TJS		<1%				
6	room B605-5	1001	unable to view above ceiling																
6	room B606	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B606	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B606	55	9"x9" grey w/ white smears FT	M		Pos	90	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B606	55.5	floor tile adhesive (sample 55)	M	ND		90	SF	N	N	0	7/15/94	DAH/TJS						

6	room B606	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B606	1001	unable to view above ceiling																	
6	room B608	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B608	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B608	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B608	55.5	floor tile adhesive (sample 55)	M	ND		145	SF	N	N	0	7/15/94	DAH/TJS							
6	room B608	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B608	1001	unable to view above ceiling																	
6	room B608-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B608-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B608-2	5	<4" felt with tar PI	T		Pos	14	LF	F	N	2	7/15/94	DAH/TJS		60%					
6	room B608-2	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	12%	3%					
6	room B608-2	28	4"-8" PFI on fiberglass	T		Pos	3	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
6	room B608-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B608-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B609	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B609	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B609	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B609	55.5	floor tile adhesive (sample 55)	M	ND			SF	N	N	0	7/15/94	DAH/TJS							
6	room B609	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B609	1001	unable to view above ceiling																	
6	room B609-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B609-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B610	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B610	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B610	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B610	55.5	floor tile adhesive (sample 55)	M	ND			SF	N	N	0	7/15/94	DAH/TJS							
6	room B610	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B610	1001	unable to view above ceiling																	
6	room B610-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							

6	room B610-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B610-2	5	<4" felt with tar PI	T		Pos	44	LF	F	N	2	7/15/94	DAH/TJS		60%						
6	room B610-2	6	<4" fibrous PFI on felt	T		Pos	38	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
6	room B610-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B610-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B611	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B611	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B611	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%						
6	room B611	55.5	floor tile adhesive (sample 55)	M	ND		145	SF	N	N	0	7/15/94	DAH/TJS								
6	room B611	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
6	room B611	1001	unable to view above ceiling																		
6	room B611-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B611-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%						
6	room B612	55.5	floor tile adhesive (sample 55)	M	ND		145	SF	N	N	0	7/15/94	DAH/TJS								
6	room B612	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
6	room B612	1001	unable to view above ceiling																		
6	room B612-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612-1(hat	43	spray-on fireproofing	S	ND		15	SF	F	N	0	9/8/94	DAH/TJS								
6	room B612-1(hat	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612-2	5	<4" felt with tar PI	T		Pos	20	LF	F	N	2	7/15/94	DAH/TJS		60%						
6	room B612-2	6	<4" fibrous PFI on felt	T		Pos	23	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
6	room B612-2	43	spray-on fireproofing	S	ND		15	SF	F	N	0	9/8/94	DAH/TJS								
6	room B612-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B612-2	185	tar paper	M		Pos	5	SF	N	N	1	9/8/94	DAH/TJS		2%						

6	room B614	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614	55	9"x9" grey w/ white smears FT	M		Pos	228	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B614	55.5	floor tile adhesive (sample 55)	M	ND		228	SF	N	N	0	7/15/94	DAH/TJS						
6	room B614	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B614	1001	unable to view above ceiling																
6	room B614-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-1(abc	28	4"-8" PFI on fiberglass	T		Pos	1	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
6	room B614-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-2	5	<4" felt with tar PI	T		Pos	39	LF	F	N	2	7/15/94	DAH/TJS			60%			
6	room B614-2	6	<4" fibrous PFI on felt	T		Pos	26	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
6	room B614-2	28	4"-8" PFI on fiberglass	T		Pos	4	EA	F	N	2	9/8/94	DAH/TJS	20%	10%				
6	room B614-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-3	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-3	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-3	55	9"x9" grey w/ white smears FT	M		Pos	3	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B614-3	55.5	floor tile adhesive (sample 55)	M	ND		3	SF	N	N	0	7/15/94	DAH/TJS						
6	room B614-3	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B614-3	1001	unable to view above ceiling																
6	room B614-4	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-4	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B614-4	55	9"x9" grey w/ white smears FT	M		Pos	3	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B614-4	55.5	floor tile adhesive (sample 55)	M	ND		3	SF	N	N	0	7/15/94	DAH/TJS						
6	room B614-4	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B614-4	1001	unable to view above ceiling																
6	room B615	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B615	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B615	55	9"x9" grey w/ white smears FT	M		Pos	212	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B615	55.5	floor tile adhesive (sample 55)	M	ND		212	SF	N	N	0	7/15/94	DAH/TJS						

6	room B615	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B615	1001	unable to view above ceiling																	
6	room B615(hatch)		NSMP																	
6	room B615-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B615-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B615-1(abc	28	4"-8" PFI on fiberglass	T		Pos	2	EA	F	N	2	9/8/94	DAH/TJS	20%	10%					
6	room B615-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94								
6	room B616	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B616	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B616	55	9"x9" grey w/ white smears FT	M		Pos	28	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B616	55.5	floor tile adhesive (sample 55)	M	ND		28	SF	N	N	0	7/15/94	DAH/TJS							
6	room B616	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B616	1001	unable to view above ceiling																	
6	room B620	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B620	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B620	58	9"x9" black w/ white smears FT	M		Pos	360	SF	N	N	1	8/5/94	DAH/TJS		23%					
6	room B620	58.5	floor tile adhesive (sample 58)	M		Pos	360	SF	N	N	1	9/8/94	DAH/TJS		10%					
6	room B620	73	12"x12" cream w/ tan, green & grey l	M	ND		440	SF	N	N	0	7/15/94	DAH/TJS							
6	room B620	73.5	floor tile adhesive (sample 73)	M	ND		440	SF	N	N	0	7/15/94	DAH/TJS							
6	room B620	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B620	1001	unable to view above ceiling																	
6	room B621	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B621	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B621	60	9"x9" white w/ faint grey specks FT	M		Pos	6	SF	N	N	1	7/15/94	DAH/TJS		5%					
6	room B621	60.5	floor tile adhesive (sample 60)	M		Pos	6	SF	N	N	1	7/15/94	DAH/TJS		3%					
6	room B621	83	12"x12" cream w/ brown and grey sp	M		Pos	27	SF	N	N	1	7/15/94	DAH/TJS		7%					
6	room B621	83.5	floor tile adhesive (sample 83)	M		Pos	27	SF	N	N	1	7/15/94	DAH/TJS		5%					
6	room B621	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B621	167	black sink coating	M		Pos		EA	N	N	1	7/15/94	DAH/TJS		10%					
6	room B621	208	9"x9" olive w/ grey smears FT	M		Pos	55	SF	N	N	1	9/8/94	DAH/TJS		12%					
6	room B621	208.5	floor tile adhesive (sample 208)	M	ND		55	SF	N	N	0	9/8/94	DAH/TJS							

6	room B621	209	9"x9" tan w/ brown & cream swirls FT	M		Pos	2	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	room B621	209.5	floor tile adhesive (sample 209)	M		Pos	2	SF	N	N	1	8/5/94	DAH/TJS		10%					
6	room B621	241	9"x9" light grey w/ streaks FT	M		Pos	6	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	room B621	241.5	floor tile adhesive (sample 241)	M		Pos	6	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	room B621(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B621-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B621-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B621-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B621-1	208	9"x9" olive w/ grey smears FT	M		Pos	3	SF	N	N	1	9/8/94	DAH/TJS		12%					
6	room B621-1	208.5	floor tile adhesive (sample 208)	M	ND		3	SF	N	N	0	9/8/94	DAH/TJS							
6	room B621-1	241	9"x9" light grey w/ streaks FT	M		Pos	3	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	room B621-1	241.5	floor tile adhesive (sample 241)	M		Pos	3	SF	N	N	1	8/5/94	DAH/TJS		5%					
6	room B621-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B622	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B622	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B622	78	12"x12" white w/ brown smears FT	M		Pos	72	SF	N	N	1	9/8/94	DAH/TJS		3%					
6	room B622	78.5	floor tile adhesive (sample 78)	M		Pos	72	SF	N	N	1	9/8/94	DAH/TJS		5%					
6	room B622	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B622	1001	unable to view above ceiling																	
6	room B624	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B624	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B624	55	9"x9" grey w/ white smears FT	M		Pos	144	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B624	55.5	floor tile adhesive (sample 55)	M	ND		144	SF	N	N	0	7/15/94	DAH/TJS							
6	room B624	1001	unable to view above ceiling																	
6	room B624-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B624-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B624-1	1001	unable to view above ceiling																	
6	room B625	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B625	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B625	1001	unable to view above ceiling																	

6	Room B631	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B633		inaccessible																
6	Room B634	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B634	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B634	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B634	52	9"x9" scarlet & grey FT	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B634	52.5	floor tile adhesive (sample 52)	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B634	82	12"x12" accoustic CT (7/24/92)	M	ND		130	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B634	82.5	ceiling tile adhesive (sample 82)	M	ND		130	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B635	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B635	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B635	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B635	52	9"x9" scarlet & grey FT	M		Pos	132	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B635	52.5	floor tile adhesive (sample 52)	M		Pos	132	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B635	82	12"x12" accoustic CT (7/24/92)	M	ND		132	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B635	82.5	ceiling tile adhesive (sample 82)	M	ND		132	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B636	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B636	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B636	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B636	52	9"x9" scarlet & grey FT	M		Pos	144	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B636	52.5	floor tile adhesive (sample 52)	M		Pos	144	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B636	82	12"x12" accoustic CT (7/24/92)	M	ND		144	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B636	82.5	ceiling tile adhesive (sample 82)	M	ND		144	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	52	9"x9" scarlet & grey FT	M		Pos	210	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B639	52.5	floor tile adhesive (sample 52)	M		Pos	210	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B639	82	12"x12" accoustic CT (7/24/92)	M	ND		210	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B639	82.5	ceiling tile adhesive (sample 82)	M	ND		210	SF	N	N	0	4/27/95	Allen/Archer						074-95-040

6	Room B640	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B640	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B640	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B640	52	9"x9" scarlet & grey FT	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B640	52.5	floor tile adhesive (sample 52)	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B640	82	12"x12" accoustic CT (7/24/92)	M	ND		130	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B640	82.5	ceiling tile adhesive (sample 82)	M	ND		130	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B641	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B641	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B641	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B641	52	9"x9" scarlet & grey FT	M		Pos	168	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B641	52.5	floor tile adhesive (sample 52)	M		Pos	168	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B641	82	12"x12" accoustic CT (7/24/92)	M	ND		168	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B641	82.5	ceiling tile adhesive (sample 82)	M	ND		168	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B642	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B642	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B642	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B642	52	9"x9" scarlet & grey FT	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B642	52.5	floor tile adhesive (sample 52)	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B642	82	12"x12" accoustic CT (7/24/92)	M	ND		130	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B642	82.5	ceiling tile adhesive (sample 82)	M	ND		130	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B644	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B644	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B644	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B644	52	9"x9" scarlet & grey FT	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B644	52.5	floor tile adhesive (sample 52)	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B644	82	12"x12" accoustic CT (7/24/92)	M	ND		190	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B644	82.5	ceiling tile adhesive (sample 82)	M	ND		190	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B645	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B645	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B645	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B645	52	9"x9" scarlet & grey FT	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B645	52.5	floor tile adhesive (sample 52)	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040

6	Room B645	82	12"x12" accoustic CT (7/24/92)	M	ND		190	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B645	82.5	ceiling tile adhesive (sample 82)	M	ND		190	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B646	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B646	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B646	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B646	52	9"x9" scarlet & grey FT	M		Pos	600	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B646	52.5	floor tile adhesive (sample 52)	M		Pos	600	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B646	78	12"x12" crater fissure CT	M	ND		600	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B646	78.5	ceiling tile adhesive (sample 78)	M	ND		600	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	23	9"-14" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B652	53	9"x9" brown FT	M		Pos	12	SF	N	N	1	4/27/95	Allen/Archer	10%					074-95-040
6	Room B652	53.5	floor tile adhesive (sample 53)	M		Pos	12	SF	N	N	1	4/27/95	Allen/Archer	15%					074-95-040
6	Room B654	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B654	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B654	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B654	82	12"x12" accoustic CT (7/24/92)	M	ND		120	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B654	82.5	ceiling tile adhesive (sample 82)	M	ND		120	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B655	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B655	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B655	82	12"x12" accoustic CT (7/24/92)	M	ND		24	SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B655	82.5	ceiling tile adhesive (sample 82)	M	ND		24	SF	N	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B657	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B657	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040
6	Room B657(hatch)		inaccessible																
6	Room B658	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer						074-95-040

6	Room B658	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B658	82	12"x12" accoustic CT (7/24/92)	M	ND		72	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B658	82.5	ceiling tile adhesive (sample 82)	M	ND		72	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	9	<4" fiberglass PI	T	ND			LF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	10	<4" fibrous PFI on FG (7/24/92)	T		Pos	5	EA	F	N	2	4/27/95	Allen/Archer	5%				074-95-040
6	Room B659	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	68	12"x12" olive w/white & brown FT	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B659	68.5	floor tile adhesive (sample 68)	M		Pos	130	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B659	82	12"x12" accoustic CT (7/24/92)	M	ND		130	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B659	82.5	ceiling tile adhesive (sample 82)	M	ND		130	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B660	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B660	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B662	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B662	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B662	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B662	52	9"x9" scarlet & grey FT	M		Pos	25	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B662	52.5	floor tile adhesive (sample 52)	M		Pos	25	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B663	1	<4" white fibrous PI (7/24/92)	T		Pos	20	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
6	Room B663	2	<4" PFI on white fibrous (7/24/92)	T		Pos	6	EA	F	N	2	4/27/95	Allen/Arche	5%	5%			074-95-040
6	Room B663	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B663	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B663	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B663	52	9"x9" scarlet & grey FT	M		Pos	120	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B663	52.5	floor tile adhesive (sample 52)	M		Pos	120	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B663	82	12"x12" accoustic CT (7/24/92)	M	ND		120	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B663	82.5	ceiling tile adhesive (sample 82)	M	ND		120	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B665	1	<4" white fibrous PI (7/24/92)	T		Pos	8	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
6	Room B665	2	<4" PFI on white fibrous (7/24/92)	T		Pos	2	EA	F	N	2	4/27/95	Allen/Arche	5%	5%			074-95-040
6	Room B665	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B665	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040

6	Room B665	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B665	82	12"x12" accoustic CT (7/24/92)	M	ND		360	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B665	82.5	ceiling tile adhesive (sample 82)	M	ND		360	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B666	1	<4" white fibrous PI (7/24/92)	T		Pos	9	LF	F	N	2	4/27/95	Allen/Arche	15%				074-95-040
6	Room B666	2	<4" PFI on white fibrous (7/24/92)	T		Pos	1	EA	F	N	2	4/27/95	Allen/Arche	5%	5%			074-95-040
6	Room B666	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B666	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B666	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B666	52	9"x9" scarlet & grey FT	M		Pos	165	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B666	52.5	floor tile adhesive (sample 52)	M		Pos	165	SF	N	N	1	4/27/95	Allen/Archer	10%				074-95-040
6	Room B666	82	12"x12" accoustic CT (7/24/92)	M	ND		165	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B666	82.5	ceiling tile adhesive (sample 82)	M	ND		165	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	39	sheetrock & taping compound	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	54	9"x9" olive w/white FT	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
6	Room B668	54.5	floor tile adhesive (sample 54)	M		Pos	150	SF	N	N	1	4/27/95	Allen/Archer	20%				074-95-040
6	Room B668	82	12"x12" accoustic CT (7/24/92)	M	ND		150	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B668	82.5	ceiling tile adhesive (sample 82)	M	ND		150	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669	62	12"x12" cream w/tan FT	M	ND		60	SF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669	62.5	floor tile adhesive (sample 62)	M		Pos	60	SF	N	N	1	4/27/95	Allen/Archer	20%				074-95-040
6	Room B669	80	12"x12" fissured splined CT	M	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669-1	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669-1	54	9"x9" olive w/white FT	M		Pos	36	SF	N	N	1	4/27/95	Allen/Archer	5%				074-95-040
6	Room B669-1	54.5	floor tile adhesive (sample 54)	M		Pos	36	SF	N	N	1	4/27/95	Allen/Archer	20%				074-95-040
6	Room B669-1	82	12"x12" accoustic CT (7/24/92)	M	ND		36	SF	F	N	0	4/27/95	Allen/Archer					074-95-040
6	Room B669-1	82.5	ceiling tile adhesive (sample 82)	M	ND		36	SF	N	N	0	4/27/95	Allen/Archer					074-95-040

6	Room B670	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B670	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B670	82	12"x12" accoustic CT (7/24/92)	M	ND		40	SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B670	82.5	ceiling tile adhesive (sample 82)	M	ND		40	SF	N	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B671	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B671	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673	40	baseboard adhesive (7/24/92)	M	ND			LF	N	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673	52	9"x9" scarlet & grey FT	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer						10%	074-95-040
6	Room B673	52.5	floor tile adhesive (sample 52)	M		Pos	190	SF	N	N	1	4/27/95	Allen/Archer						10%	074-95-040
6	Room B673	82	12"x12" accoustic CT (7/24/92)	M	ND		190	SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673	82.5	ceiling tile adhesive (sample 82)	M	ND		190	SF	N	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673(hatch)		NSMV		ND															
6	Room B673-1	34	ceiling plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	Room B673-1	35	wall plaster (7/24/95)	S	ND			SF	F	N	0	4/27/95	Allen/Archer							074-95-040
6	room B675	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B675	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B675	55	9"x9" grey w/ white smears FT	M		Pos	230	SF	N	N	1	7/15/94	DAH/TJS						20%	
6	room B675	55.5	floor tile adhesive (sample 55)	M	ND		230	SF	N	N	0	7/15/94	DAH/TJS							
6	room B675	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B675	149	lab sink	M	ND		1	EA	N	N	0	8/5/94	DAH/TJS							
6	room B675	1001	unable to view above ceiling																	
6	room B680	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680	73	12"x12" cream w/ tan, green & grey	M	ND		198	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680	73.5	floor tile adhesive (sample 73)	M	ND		19	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680	102	1'x1' small pegboard CT	M		Pos	198	SF	F	N	2	8/5/94	DAH/TJS						3%	
6	room B680	102.5	ceiling tile adhesive (sample 102)	M	ND		198	SF	F	N	0	8/5/94	DAH/TJS							
6	room B680	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							

6	room B680	175	grey countertop	M	ND		80	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680(hatch	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680(hatch	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680(hatch	157	brown duct adhesive	M	ND		36	LF	N	N	0	8/5/94	DAH/TJS							
6	room B680(hatch	178	tar paper duct wrap	M	ND		9	SF	F	N	0	8/5/94	DAH/TJS							
6	room B680-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-1	73	12"x12" cream w/ tan, green & grey l	M	ND		111	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-1	73.5	floor tile adhesive (sample 73)	M	ND		111	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-1	102	1'x1' small pegboard CT	M		Pos	99	SF	F	N	2	8/5/94	DAH/TJS		3%					
6	room B680-1	102.5	ceiling tile adhesive (sample 102)	M	ND		99	SF	F	N	0	8/5/94	DAH/TJS							
6	room B680-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B680-2	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-2	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-2	73	12"x12" cream w/ tan, green & grey l	M	ND		8	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-2	73.5	floor tile adhesive (sample 73)	M	ND		8	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-2	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B680-2	167	black sink coating	M		Pos	1	EA	N	N	1	7/15/94	DAH/TJS		10%					
6	room B680-2(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-3	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-3	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-3	73	12"x12" cream w/ tan, green & grey l	M	ND		6	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-3	73.5	floor tile adhesive (sample 73)	M	ND		6	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-3	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B680-3	175	grey countertop	M	ND		10	SF	N	N	0	7/15/94	DAH/TJS							
6	room B680-3(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-4	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B680-4	48	textured spray-on	S		Pos		SF	F	N	2	9/8/94	DAH/TJS		12%					
6	room B680-4	153	12"x12" cork panel adhesive	M	ND		4	SF	N	N	0	9/8/94	DAH/TJS							

6	room B680-4(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B681	5	<4" felt with tar PI	T		Pos	21	LF	F	N	2	7/15/94	DAH/TJS		60%						
6	room B681	6	<4" fibrous PFI on felt	T		Pos	19	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
6	room B681	43	spray-on fireproofing	S	ND		22	SF	F	N	0	9/8/94	DAH/TJS								
6	room B681	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B681	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B681	157	brown duct adhesive	M	ND		20	LF	N	N	0	8/5/94	DAH/TJS								
6	room B681	178	tar paper duct wrap	M	ND		5	SF	F	N	0	8/5/94	DAH/TJS								
6	room B682	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B682	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B682	55	9"x9" grey w/ white smears FT	M		Pos	196	SF	N	N	1	7/15/94	DAH/TJS		20%						
6	room B682	55.5	floor tile adhesive (sample 55)	M	ND		196	SF	N	N	0	7/15/94	DAH/TJS								
6	room B682	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
6	room B682	1001	unable to view above ceiling																		
6	room B682-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B682-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B682-1(abc	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B683	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B683	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B683	55	9"x9" grey w/ white smears FT	M		Pos	182	SF	N	N	1	7/15/94	DAH/TJS		20%						
6	room B683	55.5	floor tile adhesive (sample 55)	M	ND		182	SF	N	N	0	7/15/94	DAH/TJS								
6	room B683	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS								
6	room B683	1001	unable to view above ceiling																		
6	room B683-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B683-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B684	5	<4" felt with tar PI	T		Pos	38	LF	F	N	2	7/15/94	DAH/TJS		60%						
6	room B684	6	<4" fibrous PFI on felt	T		Pos	37	EA	F	N	2	7/15/94	DAH/TJS	12%	3%						
6	room B684	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								
6	room B684	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS								

6	room B685	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B685	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B685	55	9"x9" grey w/ white smears FT	M		Pos	145	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B685	55.5	floor tile adhesive (sample 55)	M	ND		145	SF	N	N	0	7/15/94	DAH/TJS						
6	room B685	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B685	1001	unable to view above ceiling																
6	room B685-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B685-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B686	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B686	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B686	55	9"x9" grey w/ white smears FT	M		Pos	144	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B686	55.5	floor tile adhesive (sample 55)	M	ND		144	SF	N	N	0	7/15/94	DAH/TJS						
6	room B686	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/1994	DAH/TJS						
6	room B686	201	9"x9" charcoal w/ white smears FT	M		Pos	1	SF	N	N	1	7/15/1994	DAH/TJS		3%				
6	room B686	201.5	floor tile adhesive (sample 201)	M		Pos	1	SF	N	N	1	7/15/94	DAH/TJS		5%				
6	room B686	1001	unable to view above ceiling																
6	room B686-1	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B686-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B687	5	<4" felt with tar PI	T		Pos	43	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B687	6	<4" fibrous PFI on felt	T		Pos	37	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
6	room B687	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B688	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B688	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B688	55	9"x9" grey w/ white smears FT	M		Pos	188	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B688	55.5	floor tile adhesive (sample 55)	M	ND		188	SF	N	N	0	7/15/94	DAH/TJS						
6	room B688	60	9"x9" white w/ faint grey specks FT	M		Pos	1	SF	N	N	1	7/15/94	DAH/TJS		5%				
6	room B688	60.5	floor tile adhesive (sample 60)	M		Pos	1	SF	N	N	1	7/15/94	DAH/TJS		3%				
6	room B688	68	9"x9" olive w/white streaks FT	M		Pos	0.5	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B688	68.5	floor tile adhesive (sample 68)	M	ND		0.5	SF	N	N	0	9/8/94	DAH/TJS						
6	room B688	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B688	242	9"x9" tan w/ brown & cream streaks	M		Pos	5	SF	N	N	1	33089	DAH/TJS		10%				
6	room B688	242.5	floor tile adhesive (sample 242)	M		Pos	5	SF	N	N	1	8/5/94	DAH/TJS		5%				

6	room B692-1	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B692-1	55	9"x9" grey w/ white smears FT	M		Pos	190	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B692-1	55.5	floor tile adhesive (sample 55)	M	ND		190	SF	N	N	0	7/15/94	DAH/TJS						
6	room B692-1	101	1'X1' fissured CT	M	ND		190	SF	F	N	0	7/15/94	DAH/TJS						
6	room B692-1	101.5	ceiling tile adhesive (sample 101)	M	ND		190	SF	N	N	0	7/15/94	DAH/TJS						
6	room B692-1	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B692-1	1001	unable to view above ceiling																
6	room B692-1a	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B692-1a	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B692-1a	1001	unable to view above ceiling																
6	room B694	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B694	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B694	55	9"x9" grey w/ white smears FT	M		Pos	156	SF	N	N	1	7/15/94	DAH/TJS		20%				
6	room B694	55.5	floor tile adhesive (sample 55)	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS						
6	room B694	101	1'X1' fissured CT	M	ND		156	SF	F	N	0	7/15/94	DAH/TJS						
6	room B694	101.5	ceiling tile adhesive (sample 101)	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS						
6	room B694	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS						
6	room B694	1001	unable to view above ceiling																
6	room B694(above)	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B694(above)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B694(above)	157	brown duct adhesive	M	ND		65	LF	N	N	0	8/5/94	DAH/TJS						
6	room B694(above)	178	tar paper duct wrap	M	ND		16	SF	F	N	0	8/5/94	DAH/TJS						
6	room B696	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B696	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B696(hatch)	20	4"-8" felt w/ tar PI	T		Pos	22	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B696(hatch)	21	4"-8" PFI on felt	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	10%	15%				
6	room B696(hatch)	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS						
6	room B696-2	5	<4" felt with tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B696-2	5	<4" felt with tar PI	T		Pos	26	LF	F	N	2	7/15/94	DAH/TJS		60%				
6	room B696-2	6	<4" fibrous PFI on felt	T		Pos	8	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				
6	room B696-2	6	<4" fibrous PFI on felt	T		Pos	9	EA	F	N	2	7/15/94	DAH/TJS	12%	3%				

6	room B696-2	20	4"-8" felt w/ tar PI	T		Pos	6	LF	F	N	2	7/15/94	DAH/TJS		60%					
6	room B696-2	20	4"-8" felt w/ tar PI	T		Pos	10	LF	F	N	2	7/15/94	DAH/TJS		60%					
6	room B696-2	21	4"-8" PFI on felt	T		Pos	2	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
6	room B696-2	21	4"-8" PFI on felt	T		Pos	3	EA	F	N	2	7/15/94	DAH/TJS	10%	15%					
6	room B696-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B696-2	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B696-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B696-2	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B698	44	ceiling plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B698	45	wall plaster	S	ND			SF	F	N	0	7/15/94	DAH/TJS							
6	room B698	55	9"x9" grey w/ white smears FT	M		Pos	156	SF	N	N	1	7/15/94	DAH/TJS		20%					
6	room B698	55.5	floor tile adhesive (sample 55)	M	ND		156	SF	N	N	0	7/15/94	DAH/TJS							
6	room B698	141	baseboard adhesive	M	ND			LF	F	N	0	8/5/94	DAH/TJS							
6	room B698(above	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	28	4"-8" PFI on fiberglass	T		Pos	2	EA	F	N		9/8/94	DAH/TJS	20%	10%					
7	attic off stair J	43	spray-on fireproofing	S	ND		40	SF	F	N		9/8/94	DAH/TJS							
7	attic off stair J	46	patching plaster	S	ND		6	SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	142	brick mortar	M	ND			SF	F	N	0	9/8/94	DAH/TJS							
7	attic off stair J	143	concrete block mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	144	clay tile mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	145	white block and mortar	M	ND			SF	F	N	0	7/15/94	DAH/TJS							
7	attic off stair J	155	black tar on duct	M		Pos	16	SF	N	N	1	8/5/94	DAH/TJS		5%					
7	attic off stair J	290	vermiculite insulation	M	ND		360	SF	F	N	0		DAH/TJS							